

Work Order Code	Problem Type	Work Description	Problem Location	Date Work Requested	Worker Resolution	Actual Labor Hours
1507100001	MAINTENANCE ODW GATE/FENCE	BETWEEN EXECUTIVE LOT AND H LOT, NORTH BREEZEWAY AREA, CORNER POST HAS SEPERATED FROM FENCE	BETWEEN EXECUTIVE LOT AND H LOT	7/21/2015	SECURED CORNER POST WITH FOUR SCREWS	0.00
1507100022	MAINTENANCE ODW LEAKS	B313 ROOF LEAK	B313	7/22/2015	7-22-15: LOCATED AND PATCHED FOUR SPOTS ON SEAM WHICH WERE DEFECTIVE. LOCATION WAS NEAR FIREWALL THAT RUNS EAST TO WEST FROM DOOR 3. 7-23-15: REPAIRED TWO PLACES ON ROOF WHERE THE SEAMS HAD FAILED (JASON SHOWED ME THE LOCATIONS).	3.50
1507100108	MAINTENANCE ODW PLUMBING	W'S R/R B211 HANDICAP SINK WATERFLOW TOO POWERFUL. INSIDE HANDICAP BUTTON NOT FUNCTIONING PROPERLY.	W'S R/R B211	7/24/2015	ADJUSTED WATERFLOW TO SINK. OPERATED HANDICAP PUSH BUTTON NUMEROUS TIMES (USING FINGER, PALM) AND IT WORKED PROPERLY.	0.50
1507100109	MAINTENANCE ODW KITCHEN EQUIP	MEAT WALK-IN BOX NOT DEFROSTING		7/24/2015	REPLACED DEFECTIVE DEFROST TIMER AND CHECKED FOR PROPER OPERATION. OK. PARAGON DEFROST TIMER \$128.60.	1.00
1507100110	MAINTENANCE ODW KITCHEN EQUIP	PRODUCE WALK-IN BOX NOT DEFROSTING	ROOF	7/24/2015	REPLACED DEFECTIVE DEFROST TIMER AND CHECKED FOR PROPER OPERATION. OK. PARAGON DEFROST TIMER \$128.60	1.00
1507100111	MAINTENANCE ODW PLUMBING CLOG	WATER FOUNTAIN DRAIN CLOGGED	POLE 5X	7/24/2015	UNCLOGGED DRAIN	0.75
1507100112	MAINTENANCE ODW EXT. LIGHTING	AREA 11 LIGHT FIXTURE OUT BETWEEN POLES 4Y AND 5Y	AREA 11	7/24/2015	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
1507100113	MAINTENANCE ODW PLUMBING CLOG	RM A306 COMMODE IS CLOGGED		7/24/2015	UNCLOGGED THE COMMODE	0.50
1507100114	MAINTENANCE ODW EXT. LIGHTING	AREA 1 LAMPS ARE OUT		7/24/2015	REPLACED LAMPS	0.75
1507100115	MAINTENANCE ODW EXT. LIGHTING	TWO SPOT LIGHT BULBS BURNED OUT BY HANDWASHING SINKS	RM 1003	7/24/2015	REPLACED TWO LIGHT BULBS	0.50
1507100116	MAINTENANCE ODW TEMPERATURE HOT	MAG HALL RMS 30 AND 32 TOO HOT	MAG HALL RMS 30 AND 32	7/24/2015	TEMP IN RM 32 76 DEG. LOWRED SET POINT 2 DEG. TEMP IN RM 30 73.1 DEG. NO ACTION TAKEN.	0.50
1507100117	MAINTENANCE ODW TEMPERATURE HOT	POLE 8F AND 8H TOO HOT	POLE 8F AND 8H	7/24/2015	SPACE TEMP 72.5 DEG. NO ACTION TAKEN.	0.50
1507100192	MAINTENANCE ODW DOOR	DOOR 18 MAKES A MOANING SOUND UPON OPENING AND CLOSING	DOOR 18	7/24/2015	LUBED HINGES. OK.	0.00
1507100191	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET STOPPED UP	M'S R/R A308	7/24/2015	REMOVED A LARGE AMOUNT OF PAPER TOWELS FROM COMMODE AND PLUNGED	0.50
1507100190	MAINTENANCE ODW PLUMBING CLOG	W'S A1003 TOILET CLOGGED	W'S R/R A1003	7/24/2015	UNCLOGGED WITH PLUNGER	0.50
1507100189	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 #3 TOILET CLOGGED	M'S R/R A308	7/24/2015	PLUNGED TOILET. OK.	0.50
1507100188	MAINTENANCE ODW EXT. LIGHTING	AREA 9 LIGHT FIXTURE OUT BETWEEN POLES 7X AND 8X	AREA 9	7/24/2015	REPLACED BALLAST AND FOUR LIGHT BULBS	0.75
1507100187	MAINTENANCE ODW EXT. LIGHTING	OUTSIDE FRONT LOBBY CAN LIGHTS OUT	OUTSIDE FRONT LOBBY	7/24/2015	REPLACED LAMPS	0.75
1507100186	MAINTENANCE ODW INT. LIGHTING	RM 32 CEILING LICK FLICKERING	RM 32	7/24/2015	REPLACED TWO FLOURESCENT TUBES	0.50
1507100185	MAINTENANCE ODW BLDG/EQUIP. REP	INTERSECTION OF HALLWAY 18 AND DOCK HALLWAY CHAIR RAIL IS MISSING	INTERSECTION OF HALLWAY 18 AND DOCK HALLWAY	7/24/2015	REPLACED END CAP	0.50
1507100184	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 TOILET CLOGGED	W'S R/R A306	7/24/2015	UNCLOGGED WITH PLUNGER	0.50
1507100196	MAINTENANCE ODW EXT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	7/24/2015	REPLACED 18 LIGHT BULBS AND VACUUMED FIVE LIGHT FIXTURES	1.50
1507100174	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 #6 TOILET CLOGGED	W'S R/R 600	7/24/2015	UNCLOGGED WITH PLUNGER	0.50
1507100173	MAINTENANCE ODW UTILITY WORK	VISITOR'S PARKING LOT SIGN FELL DOWN	VISITOR'S PARKING LOT	7/24/2015	REATTACHED SIGN BACK TO FENCE	0.50
1507100172	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 SINKS 1 AND 2 CLOGGED	W'S R/R 1003	7/24/2015	SNAKED OUT DRAIN	1.50
1507100171	MAINTENANCE ODW PLUMBING CLOG	RM 411 HEALTH UNIT COMMODE CLOGGED	RM 411	7/24/2015	UNCLOGGED THE COMMODE	0.50
1507100170	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 CLOGGED	W'S R/R 306	7/24/2015	PLUNGED TOILET, FLUSHED, OK	0.50
1507100169	MAINTENANCE ODW INDOOR AIR QUAL	RM 48 NEEDS MORE AIR	RM 48	7/24/2015	CHECKED SPACE TEMP, 71.3 DEG F. LOWERED SET POINT TO 70 DEG F.	0.50
1507100168	MAINTENANCE ODW EXT. LIGHTING	RM 903 OVERHEAD LIGHTS OUT	RM 903	7/24/2015	REPLACED FOUR LIGHT BULBS	0.50
1507100167	MAINTENANCE ODW EXT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	7/24/2015	REPLACED FOUR LIGHT BULBS	0.50
1507100166	MAINTENANCE ODW PLUMBING CLOG	COURTYARD KITCHEN FLOOR DRAIN BEHIND CHECK OUT COUNTER DRAINING SLOW	COURTYARD KITCHEN	7/24/2015	CLEARED DRAIN WITH SNAKE AND WET VAC	0.50
1507100165	MAINTENANCE ODW DOOR	RM 390 AUTO DOOR WILL NOT CLOSE	RM 903	7/24/2015	PUT LEFT DOOR BACK ON TRACK	0.50
1507100164	MAINTENANCE ODW EXT. LIGHTING	RM 804 LIGHTS OUT	RM 804	7/24/2015	REPLACED TWO LIGHT BULBS	0.50
1507100163	MAINTENANCE ODW EXT. LIGHTING	RM 809 LIGHTS OUT	RM 809	7/24/2015	REPLACED TWO FLOURESCENT TUBES	0.50
1507100162	MAINTENANCE ODW EXT. LIGHTING	M'S R/R 810 LIGHTS OUT	M'S R/R 810	7/24/2015	REPLACED TWO FLOURESCENT TUBES	0.50
1507100183	MAINTENANCE ODW EXT. LIGHTING	A102 LIGHTS OUT IN CONTROL SHACK	A102	7/24/2015	REPLACED LAMPS	0.50
1507100182	MAINTENANCE ODW PLUMBING	AREA 8 ODOR COMING FROM WATER FOUNTAIN BETWEEN 810 AND 811	AREA 8	7/24/2015	REMOVED COVER, VACUUMED OUT SEVERAL ROACHES AND DIRT. COIL WAS CLEAN. NO ODOR AT THIS TIME.	0.50
1507100197	MAINTENANCE ODW PLUMBING	CHILDCARE TEACHER'S LOUNGE SINK LEAKING	CHILDCARE TEACHER'S LOUNGE	7/24/2015	ADJUSTED PACKING NUT BELOW GOOSENECK	0.50
1507100200	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 HANDICAP STALL TOILET CLOGGED	M'S R/R 810	7/24/2015	CLEARED CLOGGED COMMODE OF PAPER TOWELS	0.50
1507100201	MAINTENANCE ODW EXT. LIGHTING	AREA 3 POLE 4E LIGHT LENS IS READY TO FALL	AREA 3 POLE 4E	7/24/2015	REPAIRED LIGHT LENSE WITH DOUBLE STICKY BACK TAPE	0.50
1507100202	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET CLOGGED	M'S R/R A308	7/24/2015	UNCLOGGED THE COMMODE	0.50
1507100203	MAINTENANCE ODW DOOR	B BLDG, RM B102 THE OFFICE DOOR IS DIFFICULT TO UNLOCK	B BLDG, RM B102	7/24/2015	LUBED ENTIRE LOCK AND KEY CYLINDER	1.00

1507100206	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 POLE 8 F TOO HOT	AREA 1	7/27/2015	DECREASED TEMP 2 DEG TO 71 DEG	0.50
1507100253	MAINTENANCE ODW EXT. LIGHTING	M'S R/R 602 LIGHTS OUT	M'S R/R 602	7/27/2015	REPLACED LAMPS	0.50
1507100254	MAINTENANCE ODW EXT. LIGHTING	W'S R/R 600 LIGHTS OUT	W'S R/R 600	7/27/2015	REPLACED LAMPS	0.50
1507100255	MAINTENANCE ODW EXT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	7/27/2015	REPLACED EIGHT LIGHT BULBS AND VACUUMED TWO LENSES	0.50
1507100256	MAINTENANCE ODW EXT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	7/27/2015	REPLACED EIGHT LIGHT BULBS AND VACUUMED TWO LENSES	0.50
1507100258	MAINTENANCE ODW RR PARTITION	M'S R/R 35 ROD FELL OFF BETWEEN PARTITION	M'S R/R 35	7/27/2015	SILICONED FRAME INTO PLACE	0.50
1507100352	MAINTENANCE ODW DOOR	CONTROL CENTER'S DOOR CLOSING MECHANISM IS LEAKING	CONTROL CENTER	7/28/2015	7-29-15: REPLACED CLOSER AND HARDWARE. 7-30-15: ADJUSTED BACK-CHECK SPEED TO MAKE DOOR SECURELY LATCH ON MAG LOCK.	4.50
1507100322	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP TOILET CLOGGED	W'S R/R 34	7/28/2015	PLUNGED, FLUSHED TWO TIMES, OK.	0.50
1507100323	MAINTENANCE ODW ELECTRICAL	PRINT ROOM ORANGE FLASHING LIGHT THAT IS TIED TO DOORBELL NEEDS TO BE RELOCATED TO THE CENTER OF THE ROOM	PRINT ROOM	7/28/2015	RELOCATED LIGHT TO CENTER OF ROOM. USED 25 FEET OF MC CABLE.	3.00
1507100345	MAINTENANCE ODW PLUMBING	W'S R/R 600 TOILET FLUSHING CONTINUOUSLY	W'S R/R 600	7/28/2015	REPLACED BATTERIES IN FLUSH HEAD	0.50
1507100351	MAINTENANCE ODW PLUMBING CLOG	MR/R STALL 2 CLOG		7/28/2015	PLUNGED THE TOILET, FLUSHED, OK	0.50
1507100518	MAINTENANCE ODW EXT. LIGHTING	OUTSIDE MAG HALL - FLAG LIGHTS REMAIN ON	OUTSIDE MAG HALL	7/29/2015	REPLACED PHOTO CONTROL	1.00
1507100519	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 #2 TOILET CLOGGED	W'S R/R B302	7/29/2015	UNCLOGGED THE COMMODE	0.50
1507100520	MAINTENANCE ODW EXT. LIGHTING	AREA 10 LIGHT OUT AT NOW CORNER OF POLE 6V	AREA 10	7/29/2015	REPLACED BALLAST AND FOUR LIGHT BULBS	1.00
1507100517	MAINTENANCE ODW EXT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	7/29/2015	REPLACED SIX LIGHT BULBS AND ONE LIGHT BALLAST. VACUUMED TWO LIGHT FIXTURES.	1.50
1507100528	MAINTENANCE ODW PLUMBING	M'S R/R 1005 URINAL #2 NOT WORKING	M'S R/R 1005	7/29/2015	ADJUSTED WATER FLOW ON URINAL #2. ALSO REMOVED PAPER TOWELS FROM COMMODE.	0.50
1507100529	MAINTENANCE ODW PLUMBING CLOG	RM 200A CARPET IS WET	RM 200A	7/29/2015	FOUND WET TILE IN RM 200A. CUT ACCESS AND INSTALLED PANEL BEHIND KEY BOX. MOVED SHELVING IN STORAGE ROOM TO ACCESS CLEAN OUT AND SNAKED DRAIN. DRAIN IS NOW CLEAR.	4.00
1507100539	MAINTENANCE ODW NOISE	B200A JOHNSON CONTROLS FIXTURE FELL OFF THE WALL	B200A	7/30/2015	REINSTALLED THERMOSTAT ON WALL	1.00
1507100540	MAINTENANCE ODW TEMPERATURE HOT	POLE 8H/8F NEEDS MORE AIR	POLE 8H/8F	7/30/2015	SPACE TEMP 72.4 DEG. LOWERED 14-1 AND 8-1 TO SPACE SET POINT OF 70 DEG.	0.50
1507100541	MAINTENANCE ODW PLUMBING	W'S R/R 600 LAST HANDICAP STALL, PIPE LEAKING WHEN FLUSHING TOILET	W'S R/R 600	7/30/2015	REPLACED VACUUM BREAKER TO CORRECT LEAK	1.00
1507100569	MAINTENANCE ODW DOOR	RM 603 FIRST SET OF SLIDING DOORS NEEDS TO BE LOOKED AT (OPENING/CLOSING TOO QUICKLY)	RM 603	7/30/2015	OPENING/CLOSING SPEEDS OK. THERE WAS A REDUCED DELAY BETWEEN "FULL OPEN" AND "START TO CLOSE." RESET DOOR CONTROLLER. DELAY IS BACK TO NORMAL.	0.50
1507100578	MAINTENANCE ODW UTILITY WORK	BADGE ROOM COVE BASE NEEDS REGLUED	BADGE ROOM	7/31/2015	REATTACHED LOOSE COVE BASE WITH ADHESIVE	0.50
1507100580	MAINTENANCE ODW EXT. LIGHTING	MAG HALL RM 389 CEILING LIGHTS OUT	MAG HALL RM 39	7/31/2015	REPLACED LAMPS	0.50
1507100581	MAINTENANCE ODW EXT. LIGHTING	SCAMPS LIGHT COVER IS SAGGING	SCAMPS	7/31/2015	PUT LIGHT COVER BACK INTO PLACE	0.50
1507100582	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST NEAR POLE 4J CEILING LIGHTS OUT	AREA 3 EAST NEAR POLE 4J	7/31/2015	REPLACED LAMPS	0.50
1507100583	MAINTENANCE ODW EXT. LIGHTING	AREA 4 WEST NEAR POLE 4L LIGHTS OUT	AREA 4 WEST NEAR POLE 4L	7/31/2015	REPLACED LAMPS	0.50
1507100595	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP TOILET CLOGGED	W'S R/R 34	7/31/2015	PLUNGED THE TOILET, FLUSHED, OK.	0.50
1508102584	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 404 #3 TOILET CLOGGED	W'S R/R 404	8/3/2015	PLUNGED TOILET, FLUSHED, OK. NOTIFIED HOUSEKEEPING STALL NEEDED MOPPED.	0.50
1508102585	MAINTENANCE ODW BLINDS	CHILDCARE RM 130 BLINDS FELL OFF	CHILDCARE RM 130	8/3/2015	REHUNG BLIND	1.00
1508102604	MAINTENANCE ODW PLUMBING	W'S R/R 404 #6 TOILET CONSTANTLY RUNNING	W'S R/R 404	8/3/2015	REPLACED BATTERIES AND DIAPHRAGM	1.00
1508102622	MAINTENANCE ODW EXT. LIGHTING	AREA 11 SEVERAL OVERHEAD LIGHTS OUT	AREA 11	8/3/2015	REPLACED 28 LIGHT BULBS	1.00
1508102637	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #1 TOILET CLOGGED	M'S R/R 1005	8/3/2015	UNCLOGGED THE COMMODE	0.50
1508102636	MAINTENANCE ODW PLUMBING	M'S R/R 602 HANDICAP STALL IS LEAKING FROM PIPE	M'S R/R 602	8/3/2015	REPLACED SPUD WASHER AND O-RING BETWEEN SHUT OFF VALVE AND FLUSH HEAD. USED ONE SPUD WASHER AND ONE O-RING.	1.00
1508102635	MAINTENANCE ODW EXT. LIGHTING	AREA 1 SEVERAL LAMPS OUT	AREA 1	8/3/2015	REPLACED LAMPS	0.75
1508102634	MAINTENANCE ODW INT. LIGHTING	AREA 6 LAMPS OUT	AREA 6	8/3/2015	REPLACED LAMPS	0.50
1508102633	MAINTENANCE ODW EXT. LIGHTING	AREA 3 EAST LIGHTS OUT	AREA 3 EAST	8/3/2015	REPLACED LAMPS	0.50
1508102632	MAINTENANCE ODW EXT. LIGHTING	DOOR21 POLE 5P AND 5D LIGHTS OUT	DOOR 21	8/4/2015	REPLACED LAMPS AND ONE BROKEN LENS COVER	1.00
1508102631	MAINTENANCE ODW EXT. LIGHTING	404 SEVERAL LAMPS OUT	404	8/4/2015	REPLACED LAMPS	0.50
1508102629	MAINTENANCE ODW EXT. LIGHTING	AREA 3 LAMPS OUT NEAR POLE 5C	AREA 3	8/4/2015	REPLACED LAMPS	0.50
1508102628	MAINTENANCE ODW EXT. LIGHTING	AREA 4 LIGHTS OUT NEAR POLE 5O	AREA 4	8/4/2015	REPLACED LAMPS	0.50
1508102627	MAINTENANCE ODW DOOR	DOCK - BAY #1 LIFT GATE WILL NOT GO DOWN	DOCK - BAY #1	8/4/2015	HOLD-DOWN BAR FOR PIT COVER BECAME LODGED UNDER LIFT MECHANISM, PREVENTING IT FROM LOWERING FULLY. RELOCATED HOLD-DOWN BAR AND TESTED LIFT FOR PROPER OPERATION. OK.	0.50
1508102638	MAINTENANCE ODW PLUMBING CLOG	M'S R/R AREA 7 TOILET CLOGGED	M'S R/R AREA 7	8/4/2015	PLUNGED TOILET, OK	0.50
1508102811	MAINTENANCE ODW TEMPERATURE HOT	Offline ticket tracking - NEEDS AIR. GETTING STUFFY.	8H AND 8F	7/13/2015	COMPLETE	0.00
1508102811	MAINTENANCE ODW TEMPERATURE HOT	Offline ticket tracking - NEEDS AIR. GETTING STUFFY.	8H AND 8F	7/13/2015	COMPLETE	0.50
1508102812	MAINTENANCE ODW TEMPERATURE HOT	Offline ticket tracking - NEEDS AIR. GETTING STUFFY.	8H AND 8F	7/13/2015	SPACE TEMP 72.5 DEG. NO ACTION TAKEN.	0.50

1508102813	MAINTENANCE ODW DOOR	Offline ticket tracking - DOOR MAKES A MOANING SOUND UPON OPENING AND CLOSING	DOOR 18	7/13/2015	LUBED HINGES. OK.	0.50
1508102814	MAINTENANCE ODW PLUMBING	Offline ticket tracking - TOILET CLOGGED	M'S R/R A308	7/13/2015	REMOVED LARGE AMOUNT OF PAPER TOWELS AND PLUNGED.	0.50
1508102815	MAINTENANCE ODW PLUMBING	Offline ticket tracking - TOILET CLOGGED	W'S A1003	7/13/2015	UNCLOGGED WITH PLUNGER	0.50
1508102816	MAINTENANCE ODW PLUMBING	Offline ticket tracking - #3 TOILET CLOGGED	M'S R/R A308	7/14/2015	PLUNGED TOILET. OK.	0.50
1508102817	MAINTENANCE ODW INT. LIGHTING	Offline ticket tracking - AREA 9 LIGHT FIXTURE OUT BETWEEN POLES 7X AND 8X		7/14/2015	REPLACED BALLAST AND FOUR LIGHT BULBS	0.80
1508102818	MAINTENANCE ODW INT. LIGHTING	Offline ticket tracking - OUTSIDE FRONT LOBBY CAN LIGHTS OUT		7/15/2015	REPLACED LAMPS	0.80
1508102819	MAINTENANCE ODW PLUMBING	Offline ticket tracking - FAUCET IN TEACHER'S LOUNGE LEAKING	CHILDCARE   CHILDCARE	7/15/2015	ADJUSTED PACKING NUT BELOW GOOSENECK	0.50
1508102820	MAINTENANCE ODW BLDG/EQUIP. REP	Offline ticket tracking - HALLWAY 18 AND DOCK HALLWAY - A PIECE OF CHAIR RAIL AT INTERSECTION IS MISSING		7/15/2015	REPLACED END CAP	0.50
1508102821	MAINTENANCE ODW INT. LIGHTING	Offline ticket tracking - OVERHEAD LIGHTS OUT		7/15/2015	REPLACED 18 LIGHT BULBS AND VACUUMED 5 LIGHT FIXTURES	1.50
1508102822	MAINTENANCE ODW PLUMBING	Offline ticket tracking - W'S R/R 306 #8 TOILET CLOGGED		7/15/2015	UNCLOGGED WITH PLUNGER	0.50
1508102823	MAINTENANCE ODW PLUMBING	Offline ticket tracking - W'S R/R 600 #6 TOILET CLOGGED	W'S R/R 600	7/15/2015	UNCLOGGED WITH PLUNGER	0.50
1508102824	MAINTENANCE ODW BLDG/EQUIP. REP	Offline ticket tracking - SIGN BY VISITOR'S PARKING LOT FELL		7/16/2015	REATTACHED SIGN BACK TO FENCE	0.50
1508102825	MAINTENANCE ODW PLUMBING	Offline ticket tracking - SINKS #1 AND #2 ARE CLOGGED	W'S A1003	7/16/2015	SNAKED OUT DRAIN	1.50
1508102826	MAINTENANCE ODW PLUMBING	Offline ticket tracking - COMMODORE IN HEALTH UNIT IS CLOGGED		7/16/2015	UNCLOGGED THE COMMODORE	0.50
1508102827	MAINTENANCE ODW PLUMBING	Offline ticket tracking - #8 TOILET CLOGGED	W'S RR A306	7/17/2015	PLUNGED TOILET, FLUSHED, OK	0.50
1508102850	MAINTENANCE ODW CEILING TILE	THERE IS A STAINED CEILING TILE IN THE OFFICE TO THE RIGHT OF LOBBY. CHECK WITH JAY OR SHELLEY IF YOU HAVE ANY QUESTIONS.	LOBBY	8/5/2015	PUT CEILING TILE BACK IN PLACE. REPLACED STAINED CEILING TILE. WRAPPED SWEATING PIPE ABOVE CEILING.	0.75
1508102851	MAINTENANCE ODW EXT. LIGHTING	AREA 4 WEST LAMPS OUT BETWEEN POLES 4M AND 5M	AREA 4 WEST	8/5/2015	REPLACED LAMPS	0.50
1508102853	MAINTENANCE ODW EXT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	8/5/2015	REPLACED BULBS	0.50
1508102852	MAINTENANCE ODW PLUMBING	M'S R/R 810 URINAL #2 CONSTANTLY FLUSHING	M'S R/R 810	8/5/2015	REPLACED BATTERIES	0.50
1508102885	MAINTENANCE ODW EXT. LIGHTING	AREA 4 WEST LIGHTS OUT SOUTH OF POLE 4M	AREA 4 WEST	8/6/2015	REPLACED LAMPS OVER SOUTH HALL RAIL	0.50
1508102886	MAINTENANCE ODW EXT. LIGHTING	MAG HALL RM 35 LIGHTS OUT	MAG HALL RM 35	8/6/2015	REPLACED BULBS	0.50
1508102887	MAINTENANCE ODW EXT. LIGHTING	AREA 3 EAST LIGHTS OUT SOUTH OF POLE 4G. LENS COVER CRACKED.	AREA 3 EAST	8/6/2015	REPLACED LIGHTS AND ONE LENS COVER	1.00
1508102888	MAINTENANCE ODW EXT. LIGHTING	AREA 5 LIGHT NOT WORKING	AREA 5	8/6/2015	REPLACED LAMPS AND BALLAST	1.25
1508102938	MAINTENANCE ODW NOISE	DOCK GUARD DESK A/C UNIT NOT OPERATING PROPERLY	DOCK GUARD DESK	8/6/2015	RAN UNIT FOR 30 MINUTES. REPLACED FILTER MEDIA. FUNCTIONING NORMALLY.	1.00
1508102952	MAINTENANCE ODW DOOR	AREA 8 DOCK DOOR #3 ROLL UP DOOR WILL NOT CLOSE	AREA 8	8/7/2015	BOTTOM GUIDE OFF TRACK. REINSTALLED GUIDE AND LUBED TRACKS.	3.00
1508102953	MAINTENANCE ODW PLUMBING	M'S R/R B309 URINAL #1 WILL NOT FLUSH	M'S R/R B309	8/7/2015	REPLACED BATTERIES	0.50
1508102955	MAINTENANCE ODW NOISE	RM 3 PNEUMATIC THERMOSTAT IS FALLING OFF OF WALL. AHU 13-3-4	RM 3	8/7/2015	REANCHORED THERMOSTAT BACK TO WALL	0.50
1508102958	MAINTENANCE ODW PLUMBING	M'S R/R 403 BATTERY IS DEAD ON FLUSH VALVE	M'S R/R 403	8/7/2015	REPLACED BATTERIES	0.50
1508103004	MAINTENANCE ODW EXT. LIGHTING	AREA 11 OVERHEAD LIGHTS OUT	AREA 11	8/10/2015	REPLACED LIGHT BULBS	1.50
1508103003	MAINTENANCE ODW EXT. LIGHTING	AREA 12 LIGHT FIXTURE NOT WORKING	AREA 12	8/10/2015	REPLACED LAMPS AND BALLAST	1.25
1508103002	MAINTENANCE ODW UTILITY WORK	AREA 10 RAMP BY POLE 7S BLACK RUBBER COVERING RAMP IS LOOSE	AREA 10	8/10/2015	REGLUED LOOSE EDGE AT BOTTOM OF RAMP AND THREE OTHER SMALL AREAS ON RAMP	0.50
1508103001	MAINTENANCE ODW PLUMBING	W'S R/R 600 HANDICAP TOILET CONTINUOUSLY FLUSHING	W'S R/R 600	8/10/2015	REPLACED BATTERIES TO FLUSH HEAD	0.50
1508103096	MAINTENANCE ODW PLUMBING	CHILDCARE RM 126 TOILET WILL NOT STOP FLUSHING	CHILDCARE RM 126	8/11/2015	bled air from valve to unstick. FUNCTIONING NORMALLY.	0.50
1508103101	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #2 TOILET STOPPED UP	M'S R/R B309	8/11/2015	PLUNGED TOILET, FLUSHED, OK.	0.50
1508103127	MAINTENANCE ODW NOISE	604B BELTS MAKING A LOUD NOISE	604B	8/12/2015	ADJUSTED THE MOTOR SO PULLIES WOULD LINE UP PROPERLY. NOISE IS GONE.	1.00
1508103141	MAINTENANCE ODW EXT. LIGHTING	4 LIGHTS BY THE OUTSIDE WINDOW OF POLE 8JJ ARE BURNED OUT	POLE 8JJ	8/12/2015	AREA 12 - B102. TD: REPLACED BALLAST AND FOUR LAMPS. MM/MR: FOUND OPEN NEUTRAL IN A JUNCTION BOX. CORRECTED PROBLEM, LIGHT IS NOW OPERATING.	3.00
1508103145	MAINTENANCE ODW NOISE	R/R BY DOCK - LOUD NOISE COMING FROM AREA	R/R BY DOCK	8/12/2015	AHU 18 CHW BOOSTER PUMP HAS DEFECTIVE MOTOR BEARINGS. REBUILT MOTOR AND PUMP USING NEW BEARINGS AND SEAL. REINSTALLED PUMP AND CHECKED FOR PROPER OPERATION AND ABSENCE OF LEAKS. OK. PUMP SEAL: \$118.71; BEARING (6203LL): \$8.64; BEARING (6205LL): 15.63; GASKET: \$4.00	7.00
1508103157	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A309 FIRST STALL'S TOILET PAPER DISPENSER IS BROKEN	W'S R/R A309	8/13/2015	REPLACED TP DISPENSER	0.50
1508103165	MAINTENANCE ODW EXT. LIGHTING	RM 815 LIGHTS OUT	RM 815	8/13/2015	REPLACED LIGHT BULBS	0.50
1508103164	MAINTENANCE ODW EXT. LIGHTING	RM 813 LIGHTS OUT	RM 83	8/13/2015	REPLACED LIGHT BULBS	0.50
1508103163	MAINTENANCE ODW DOOR	AERA 1 DOOR 18 HINGES ARE SQUEAKING	AREA 1 DOOR 18	8/13/2015	LUBED HINGES WITH SPRAY LUBE	0.50

1508103162	MAINTENANCE ODW EXT. LIGHTING	RM 809 LIGHTS OUT	RM 809	8/13/2015	REPLACED LIGHT BULBS	0.50
1508103394	MAINTENANCE ODW PLUMBING	M'S R/R 39 WATER FROM FAUCET CONTINUOUSLY RUNNING	M'S R/R 35	8/13/2015	REPLACED BATTERIES	1.00
1508103393	MAINTENANCE ODW EXT. LIGHTING	AREA 3 LAMPS OUT SOUTH OF POLE 4D	AREA 3	8/14/2015	REPLACED LAMPS	0.50
1508103392	MAINTENANCE ODW PLUMBING	M'S R/R 39 URINAL OVERFLOWING	M'S R/R 39	8/14/2015	REPLCD BATTERIES	0.50
1508103269	MAINTENANCE ODW EXT. LIGHTING	604 LIGHT FIXTURE NOT WORKING AND LIGHTS OUT	604	8/17/2015	REPLACED BALLAST IN FIXTURE AND REPLACED LAMPS.	1.50
1508103270	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R B309 HANDICAP BUTTON NOT WORKING	M'S R/R B309	8/17/2015	REPLACED 9V BATTERY ON INTERIOR HC BUTTON	0.50
1508103272	MAINTENANCE ODW PLUMBING	M'S R/R A308 URINAL OVERFLOWING	M'S R/R A308	8/17/2015	REPLACED DIAPHRAGM AND FLUSH HEAD WITH NEW	1.00
1508103273	MAINTENANCE ODW UTILITY WORK	CONCRETE PAD SOUTH OF DOOR 21 NEEDS TO BE MOVED WHERE THE BUTT CAN IS (SEE JAY FOR SPECIFIC INSTRUCTIONS)	SOUTH OF DOOR 21	8/17/2015	MOVED PAD TO 25 FOOT DISTANCE AND SET ASHTRAY ON TOP	0.50
1508103285	MAINTENANCE ODW TEMPERATURE HOT	MAG HALL RM 32 TOO HOT	MAG HALL RM 32	8/18/2015	UNIT 13-3-4 OUTPUTTING MAXIMUM COOLING. CHILLED WATER VALVE AT 100% OPEN. SPACE TEMP IS 74 DEG F, 63.5% RH.	0.50
1508103347	MAINTENANCE ODW PLUMBING	M'S R/R 1005 URINAL #2 OVERFLOWING	M'S R/R 1005	8/19/2015	REPLACED FLUSH HEAD. FUNCTIONING NORMALLY.	0.50
1508103348	MAINTENANCE ODW PLUMBING	M'S R/R 810 URINAL #2 LEAKING AT FLUSH HEAD	M'S R/R 810	8/19/2015	TIGHTENED COLLAR.	0.50
1508103349	MAINTENANCE ODW EXT. LIGHTING	AREA 1 LAMP OUT OVER EMPLOYEE'S WORK AREA	AREA 1	8/19/2015	REPLACED LAMP	0.50
1508103350	MAINTENANCE ODW CEILING TILE	R, 700C TWO CEILING TILES STAINED IN RM 700C BY ENTRANCE TO 700D	RMM 700C	8/19/2015	REPLACED CEILING TILES WITH NEW. COULD NOT FIND LEAK ABOVE CEILING AND STAINS WERE OLD.	0.50
1508103367	MAINTENANCE ODW EXT. LIGHTING	CHILDCARE STAFF LOUNGE RESTROOM LIGHTS OUT	CHILDCARE	8/20/2015	REPLACED LAMPS. REPLACED LAMPS IN FIXTURE IN NORTH HALL OUTSIDE RM 123.	0.50
1508103374	MAINTENANCE ODW EXT. LIGHTING	CHILDCARE RM 126 LIGHTS OUT	CHILDCARE RM 126	8/20/2015	REPLACED THREE LAMPS IN ONE. THE OTHER LIGHT REPLACED DIMMING BALLAST AND THREE LAMPS.	4.00
1508103368	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 126 CHILDREN'S SINKS SLOW	CHILDCARE RM 126	8/20/2015	PLUNGED SINK, OK.	0.50
1508103369	MAINTENANCE ODW UTILITY WORK	CHILDCARE RM 130 BASEBOARD BEHIND COTS IS COMING OFF OF WALL	CHILDCARE RM 130	8/20/2015	REATTACHED USING POWER GRIP	0.75
1508103370	MAINTENANCE ODW LEAKS	CHILDCARE RM 130 WINDOW NEAR "CLASSROOM EXPECTATIONS" IS LEAKING	CHILDCARE RM 130	8/20/2015	NO SIGN OF LEAKAGE OF ANY KIND ABOVE CEILING OR ANYWHERE ELSE.	0.50
1508103372	MAINTENANCE ODW UTILITY WORK	CHILDCARE GARDEN COURTYARD SCREEN NEEDS HUNG	CHILDCARE GARDEN COURTYARD	8/20/2015	REHUNG SCREEN	0.50
1508103373	MAINTENANCE ODW CEILING TILE	CHILDCARE HALLWAY ACROSS FROM ADULT RESTROOM ARE STAINED ON THE WINDOW SIDE	CHILDCARE	8/20/2015	REPLACED TWO TILES. CUT TILES SO THEY WILL NOW SIT CORRECTLY INTO GRID.	1.25
1508103387	MAINTENANCE ODW KITCHEN EQUIP	CHILDCARE GARBAGE DISPOSAL IS MISSING SEVERAL SPLASH BAFFLES	CHILDCARE GARBAGE DISPOSAL	8/20/2015	INSTALLED NEW SPLASH BAFFLE IN DISPOSAL	1.00
1508103391	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 109 SOAP DISPENSER HEIGHT NEEDS ADJUSTED.	CHILDCARE RM 109	8/20/2015	DISPENSER HAS BEEN RELOCATED. MUDDIED, SANDED, PAINTED WITH TWO COATS OF LATEX PAINT.	2.00
1508103390	MAINTENANCE ODW PAINTING	CHILDCARE RM 109 CHIPPING PAINT ON WINDOW SILL (TODDLER 1)	CHILDCARE RM 109	8/20/2015	TOUCHED UP PAINT ON WINDOW SILL	0.50
1508103389	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 128 BOTTOM OF HANDWASHING SINK CABINET IS MISSING VENEER COVERING	CHILDCARE RM 128	8/20/2015	PATCHED WHERE VENEER WAS MISSING AND PAINTED	1.00
1508103388	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 109 BROKEN CABINET DOOR LOCKS UNDER CHANGING TABLE	CHILDCARE RM 109	8/20/2015	REPLACED RIGHT SIDE SAFETY LATCH BECAUSE IT WAS ERRATIC (WORKED SOMETIMES).	0.50
1508103386	MAINTENANCE ODW UTILITY WORK	CHILDCARE RM 128 BROKEN CABINET DOOR LOCK	CHILDCARE RM 128	8/20/2015	REMOVED TWO SAFETY LATCHES. REMOUNTED FIRST AND THIRD LATCH ON THE LEFT SIDE OF ROOM. MAGNET HOLES WERE COMPLETELY THROUGH THE DOOR.	1.25
1508103385	MAINTENANCE ODW PAINTING	CHILDCARE RM 130 (KINDERGARTEN CLASSROOM) HAS A CRACK ON THE WALL IN THE CHILDREN'S BATHROOM	CHILDCARE RM 130	8/20/2015	PATCHED CRACK AND PAINTED WITH 2 COATS OF PAINT	1.00
1508103384	MAINTENANCE ODW UTILITY WORK	CHILDCARE PLAY AREA FENCING BETWEEN LARGE AND SMALL PLAYAERA NEAR CORNER COLUMN NEEDS REATTACHED TO COLUMN AND ANCHOR TO SUPPORT COLUMN NEEDS TO BE REANCHORED.	CHILDCARE PLAY AREA	8/20/2015	REANCHORED FENCE TO COLUMN. 8-31-15: REMOVED EXISTING ANCHOR, INSTALLED LARGER SIZED ANCHOR, NEW BOLTS, FENCE TIGHT. TIGHTENED EXISTING BOLTS. OK.	2.00
1508103383	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE SHED NEAR GATEHOUSE 4 HAS LOOSE SHINGLES	CHILDCARE SHED	8/20/2015	REPLACED 4 SHINGLES THAT WERE MISSING OR TORN. LOWE'S: \$16.88. ROOFING WHOLESALE: \$117.76.	1.00
1508103382	MAINTENANCE ODW DOOR	SECOND SET OF DOORS BY RM 603 MAKING A LOUD NOISE. ALSO, DOORS BANG TOGETHER WHEN CLOSING.	RM 603	8/20/2015	JM AND TD TESTED BOTH SETS OF DOORS. FUNCTIONING NORMALLY.	0.50
1508103409	MAINTENANCE ODW UTILITY WORK	CHILDCARE RM 109 CABINET UNDER ADULT SINK HAS A BROKEN LOCK ON THE LEFT HAND SIDE	CHILDCARE RM 109	8/20/2015	LOCK NOT BROKEN. A LARGE BASKET UNDER SINK WAS PUSHING AGAINST DOOR. MOVED BASKET, BOTH DOORS FUNCTIONING NORMALLY.	0.50
1508103402	MAINTENANCE ODW UTILITY WORK	CHILDCARE DOOR GUARD IS MISSING ON THE DOOR CLOSET TO THE CAFETERIA	CHILDCARE	8/20/2015	CUT TO FIT A REPLACEMENT GUARD. OK.	2.00
1508103408	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 #1 TOILET CLOGGED	W'S R/R 600	8/20/2015	UNCLOGGED THE COMMODE	0.50
1508103423	MAINTENANCE ODW PLUMBING CLOG	41E HEALTH UNIT SINK CLOGGED	HEALTH UNIT	8/21/2015	RESPONDED AT 8:45 AM. WAITED 10 MIN. COULD NOT GET TO JOB DUE TO ROOM BEING OCCUPIED. RETURNED TO HEALTH UNIT AT 9:30 AM AND PLUNGED SINK. OK.	1.00
1508103424	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B211 #6 TOILET PAPER DISPENSER IS BROKEN	W'S R/R B211	8/21/2015	REPLACED TOILET PAPER DISPENSER	0.50
1508103425	MAINTENANCE ODW EXT. LIGHTING	W'S R/R B211 LOBBY LIGHTS OUT	W'S R/R B211 LOBBY	8/21/2015	REPLACED SIX 4' LAMPS, ONE COMPACT FLOURSCENT AND ONE 2' LAMP	0.50
1508103426	MAINTENANCE ODW INT. LIGHTING	W'S R/R B302 LIGHTS OUT IN LOBBY AND LIGHT CRATE IS LOOSE	W'S R/R B302	8/21/2015	REATTACHED CRATE AND REPLACED LAMPS	0.75

1508103453	MAINTENANCE ODW CEILING TILE	CEILING TILE THAT GOES AROUND A BIG AIR VENT AT DOOR 18 IS TOO SHORT	DOOR 18	8/24/2015	REPLACED CEILING TILE.	1.00
1508103473	MAINTENANCE ODW EXT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	8/24/2015	REPLACED LIGHT BULBS	0.50
1508103474	MAINTENANCE ODW EXT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	8/24/2015	REPLACED LIGHT BULBS	0.50
1508103478	MAINTENANCE ODW EXT. LIGHTING	AREA 11 SEVERAL OVERHEAD LIGHTS OUT	AREA 11	8/24/2015	REPLACED LIGHT BULBS	0.75
1508103479	MAINTENANCE ODW EXT. LIGHTING	W'S R/R A1003 SEVERAL OVERHEAD LIGHTS OUT	W'S R/R A1003	8/24/2015	REPLACED LIGHT BULBS	0.75
1508103506	MAINTENANCE ODW PLUMBING CLOG	COMMAND CENTER SINK CLOGGED	COMMAND CENTER	8/25/2015	SNAKED SINK AND REPLACED PART OF THE DRAIN LINE AFTER "P" TRAP	3.00
1508103508	MAINTENANCE ODW KITCHEN EQUIP	B CANTEEN WALK-IN BOX IS BLOWING WARM AIR	B CANTEEN	8/25/2015	FOUND EVAPORATOR ICED-UP. THAWED EVAP AND RESTARTED CONDENSING UNIT. CHECKED UNIT PRESSURES (22 SUCTION, 195 DISCHARGE). SIGHT GLASS CLEAR. CHECKED THERMOSTAT OPERATION IN WALK-IN BOX. OK. MOST LIKELY CAUSE FOR ICING IS DOOR LEFT OPEN. SUPERHEAT OK.	4.00
1508103517	MAINTENANCE ODW PLUMBING	W'S R/R 34 HANDICAP TOILET WILL NOT FLUSH	W'S R/R 34	8/25/2015	REPLACED FILL VALVE ASSEMBLY. OK. (LOWE'S: \$12.83)	1.00
1508103518	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 TOILET #1 CLOGGED	M'S R/R 810	8/25/2015	UNCLOGGED WITH PLUNGER	0.50
1508103548	MAINTENANCE ODW PLUMBING	CHILDCARE STAFF LOUNGE SINK IS LEAKING	CHILDCARE STAFF LOUNGE	8/26/2015	8-26-15: FAUCET IS LEAKING. 8-27-15: REPLACED FAUCET.	0.00
1508103554	MAINTENANCE ODW EXT. LIGHTING	AREA 4WEST LAMPS OUT NEAR POLE 5L	AREA 4WEST	8/26/2015	REPLACED LAMPS	0.50
1508103555	MAINTENANCE ODW EXT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	8/26/2015	REPLACED THREE LIGHT BULBS, ONE LIGHT BALLAST AND VACUUMED LIGHT FIXTURE.	1.00
1508103556	MAINTENANCE ODW EXT. LIGHTING	DOOR 18 HALLWAY LAMPS OUT	DOOR 18 HALLWAY	8/26/2015	REPLACED LAMPS	0.50
1508103595	MAINTENANCE ODW EXT. LIGHTING	AREA 12 BALLAST IS BAD	AREA 12	8/26/2015	REPLACED BALLAST	1.00
1508103594	MAINTENANCE ODW PLUMBING	CHILDCARE HALLWAY BATHROOM TOILET IS LEAKING. DRYWALL IS DAMP AND NEEDS REPLACED.	CHILDCARE HALLWAY BATHROOM	8/27/2015	8-27-15: REBUILT HANDLE ASSEMBLY (MM). 8-30-15: REMOVED DAMAGED DRYWALL AND REPLACED WITH NEW (LT).	7.50
1508103593	MAINTENANCE ODW GATE/FENCE	CAR CRASHED THROUGH FENCE. FENCE NEEDS REPAIRED.	GATEHOUSE 1	8/27/2015	AFTER CARS WERE TOWED, REPLACED DAMAGED FENCE WITH TWO SECTIONS OF CHAIN LINK.	3.50
1508103609	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 34 TOILET CLOGGED	MAG HALL 34	8/27/2015	UNCLOGGED WITH PLUNGER	0.50
1508103610	MAINTENANCE ODW EXT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	8/27/2015	REPLACED 11 LIGHT BULBS. REPLACED 1 LIGHT BALLAST. VACUUMED 3 LIGHT FIXTURES.	1.50
1508103657	MAINTENANCE ODW INT. LIGHTING	LIGHTS NOT WORKING	POLE 7DD	8/27/2015	REPLACED BALLAST	0.00
1508103611	MAINTENANCE ODW ELECTRICAL	B CANTEEN BREAKER TRIPPED	B CANTEEN	8/27/2015	RESET BREAKER IN RM B312	0.50
1508103666	MAINTENANCE ODW CEILING TILE	AREA 7 CEILING TILE BY WATER FOUNTAIN RIGHT OF MEN'S R/R HAS A HOLE	AREA 7	8/28/2015	REPLACED CEILING TILE	0.50
1508103673	MAINTENANCE ODW INT. LIGHTING	DOOR 21 LIGHT OUT ABOVE DOOR	DOOR 21	8/28/2015	TURND LIGHT SWITCH ON INSIDE DOOR 21	0.50
1508103674	MAINTENANCE ODW EXT. LIGHTING	FLAG POLE FLAG LIGHT NOT WORKING	FLAG POLE	8/28/2015	REPLACED PHOTO CELL	1.00
1508103675	MAINTENANCE ODW EXT. LIGHTING	CENTRAL PLANT 2 LIGHTS OUT NORTH SIDE OF CENTRAL PLANT	CENTRAL PLANT	8/28/2015	REPLACED 2 PHOTO CELLS (\$15.00 X 2)	0.10
1508103676	MAINTENANCE ODW EXT. LIGHTING	NORTH LOT POLE LIGHT NO. 14 OUT	NORTH LOT	8/28/2015	REPLACED BALLAST AND LAMP. (BALLAST \$770.00; LAMP \$50.00)	2.00
1508103678	MAINTENANCE ODW EXT. LIGHTING	GARDENER'S RM LIGHT IS OUT	GARDENER'S RM	8/28/2015	REPLACED PHOTO CELL (\$15.00)	1.00
1508103679	MAINTENANCE ODW EXT. LIGHTING	DOOR B3 LIGHTS OUT ABOVE DOOR	DOOR B3	8/28/2015	REPLACED 2 FLOOD LIGHTS	0.50
1508103684	MAINTENANCE ODW EXT. LIGHTING	NORTH A BUILDING LIGHT OUT	NORTH A BUILDING	8/28/2015	REPLACED LAMP (\$40.00)	1.00
1508103680	MAINTENANCE ODW INT. LIGHTING	POLE 9 LIGHT OUT	POLE 9	8/28/2015	REPLACED BALLAST AND LAMP (BALLAST \$770.00; LAMP \$50.00)	2.00
1508103681	MAINTENANCE ODW EXT. LIGHTING	POLE 36 LIGHT OUT	POLE 36	8/28/2015	REPLACED LAMP AND CAP (LAMP \$50.00; CAP \$55.00)	2.00
1508103682	MAINTENANCE ODW INT. LIGHTING	DOOR B101 LIGHT OUT ABOVE DOOR	DOOR B101	8/28/2015	REPLACED LAMP (\$40.00)	1.00
1508103683	MAINTENANCE ODW INT. LIGHTING	A BUILDING LIGHT ON FRONT OF A BUILDING NOT WORKING	A BUILDING	8/28/2015	REPLACED LAMP (\$30.00)	1.00
1508103728	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 35 TOILET CLOGGED	M'S R/R 35	8/28/2015	PLUNGED TOILET. OK.	0.50
1508103730	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET CONTINUOUSLY RUNNING	W'S R/R A309	8/28/2015	REPLACED BATTERIES. OK.	0.50
1508103729	MAINTENANCE ODW EXT. LIGHTING	M'S R/R 602 LIGHTS OUT	M'S R/R 602	8/31/2015	RERPLACED LAMPS	0.50
1508103727	MAINTENANCE ODW PLUMBING	CHILDCARE R/R FAUCET LEAKING	CHILDCARE R/R	8/31/2015	REPLACED WITH NEW LINE. \$24.00	2.00
1508103731	MAINTENANCE ODW PLUMBING	M'S R/R 35 URINAL LEAKING AROUND VACUUM BREAKER	M'S R/R 35	8/31/2015	REPLACED VACUUM BREAKER AND O-RING BETWEEN MANUAL VALVE AND FLUSH HEAD	0.50
1509102698	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 CLOGGED	W'S R/R 306	9/1/2015	UNCLOGGED WITH PLUNGER	0.50
1509102699	MAINTENANCE ODW DOOR	EXTERIOR DOOR TO RM 128 HAS A WEAK BATTERY ON EMERGENCY EXIT	CHILDCARE RM 128	9/1/2015	REPLACED BATTERY	0.50
1509102700	MAINTENANCE ODW EXT. LIGHTING	AREA 5 LIGHT FIXTURE NOT WORKING	AREA 5	9/1/2015	REWIRED FIXTURE AND CHANGED BALLAST	1.00
1509102711	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP TOILET CLOGGED	W'S R/R 34	9/2/2015	REMOVED 1/2 LOAF OF BREAD. FLUSHED TOMAKE SURE NO CLOGS. OK.	0.50
1509102712	MAINTENANCE ODW EXT. LIGHTING	MSU LIGHTS OUT	MSU	9/2/2015	REPLACED BALLAST AND LIGHT BULBS	1.00
1509102721	MAINTENANCE ODW PLUMBING	B212 MECHANICAL RM - DRAIN PIPE NOT DRIPPING INTO DRAIN	B212	9/3/2015	THREADED A 1-1/2" X 2" NIPPLE INTO DRAIN CONNECTION TO ALLOW CONDENSATE TO DRIP DIRECTLY INTO DRAIN.	0.50
1509102722	MAINTENANCE ODW EXT. LIGHTING	AREA 4 WEST FIXTURE OUT SW CORNER OF POLE 5M	AREA 4 WEST	9/3/2015	REPLACED BALLAST AND LAMPS	0.50
1509102724	MAINTENANCE ODW PLUMBING	W'S R/R 309 TOILET #3 LEAKING	W'S R/R 309	9/3/2015	PLUNGED TOILET. OK.	0.50
1509102727	MAINTENANCE ODW EXT. LIGHTING	AREA 3 LIGHTS OUT NEAR POLE 4G	AREA 3	9/3/2015	REPLACED LAMPS	0.50
1509102728	MAINTENANCE ODW EXT. LIGHTING	M'S R/R A308 CAN LIGHTS AND 4' LIGHTS OUT	M'S R/R A308	9/3/2015	REPLACED LAMPS	0.50
1509102736	MAINTENANCE ODW EXT. LIGHTING	LIGHT GOING OUT BY POLE 4G	POLE 4G	9/3/2015	REPLACED BALLAST AND LAMPS IN TWO FIXTURES	0.50
1509102737	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #4 CLOGGED	M'S R/R B309	9/3/2015	UNCLOGGED THE COMMUNE	0.50

1509102738	MAINTENANCE ODW EXT. LIGHTING	DOOR 21 HALL LIGHTS OUT AT POLE 5V	DOOR 21 HALL	9/3/2015	REPLACED LAMPS	0.50
1509102743	MAINTENANCE ODW CEILING TILE	RM 118 - CEILING TILE ABOVE JAY'S DESK HAS A WET LOOKING SPOT	RM 118	9/3/2015	9-3-15: TAPE ON SEAM OF INSULATION FAILED CAUSING CONDENSATION. INSTALLED FOIL TAPE TO PREVENT CONDENSATION. 9-4-15: REPLACED 2 TILES.	1.50
1509102750	MAINTENANCE ODW PLUMBING	W'S R/R A5 WATER CONTINUOUSLY RUNNING IN TOILET	W'S R/R A5	9/3/2015	STALL #3. TURNED OFF WATER. REPLACED FLUSH HEAD WITH USED STOCK.	0.50
1509102751	MAINTENANCE ODW DOOR	RM 2 DOOR SLAMS SHUT EACH TIME IT CLOSSES.	RM 2	9/3/2015	9-3-15: ATTEMPTED TO REPLACE CLOSER. NO NEW CLOSERS IN STOCK. 9-4-15: OCCUPANT SAYS SHE WOULD PREFER NOT TO HAVE A CLOSER ON DOOR. CLOSER HAS BEEN REMOVED.	2.50
1509102753	MAINTENANCE ODW UTILITY WORK	RELOCATE TWO EGG CRATES IN RMS 1 AND 2	RMS 1 AND 2	9/3/2015	RELOCATED EGG CRATE GRILLES TO EXTREME ENDS OF EACH ROOM IN ORDER TO ELIMINATE NOISE/CONVERSATIONS BEING HEARD BETWEEN ROOMS.	4.00
1509102759	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #4 TOILET CLOGGED	W'S R/R B211	9/4/2015	UNCLOGGED WITH PLUNGER.	0.50
1509102760	MAINTENANCE ODW RESTROOM FIXTURE	COMMODOE IN RM 115 NEEDS TO BE CAULKED TO WALL	CHILDCARE RM 115	9/4/2015	CAULKED AROUND COMMODOE	0.50
1509102761	MAINTENANCE ODW BLDG/EQUIP. REP	CENTRAL PLANT CHILLER #1 DOWN ON "EVAP TRANS OR PROBE" ERROR, CAUSED BY FAULTY LEAVING CHW TEMP SENSOR	CENTRAL PLANT	9/4/2015	ORDERED NEW SENSOR AND REPLACED, CHECKED SENSOR AGAINST GAUGE. BOTH READING THE SAME TEMP. CHECKED CHILLER EVAPORATOR SATURATION TEMP AGAINST LEAVING CHW TEMP. OK. YORK TEMP SENSOR: \$67.00	1.00
1509102763	MAINTENANCE ODW UTILITY WORK	CORNER OF NORTH HALLWAY AND WAREHOUSE, CHAIR RAIL IS OFF	CORNER OF NORTH HALLWAY AND WAREHOUSE	9/4/2015	REPLACED CORNER OF RAIL	0.50
1509102774	MAINTENANCE ODW RESTROOM FIXTURE	Men's RR 602 both handicap doors need repaired. On two stalls in RR 602; the partition wall is broke holding the top hinge pin on the door.	602   BUILDING A-AREA 6	9/8/2015	9-10-15: INSTALLED PIANO HINGE ON #2. NEED TO ORDER ANOTHER HINGE FOR #3. 9-15-15: INSTALLED HINGE ON #3. TOTAL COST FOR TWO PIANO HINGES \$193.82.	4.00
1509102832	MAINTENANCE ODW FLOOR TILE	CHILDCARE FLOOR TILES COMING LOOSE IN CHILDREN'S DINING ROOM	CHILDCARE	9/9/2015	REPLACED TWO FLOOR TILES	0.75
1509102833	MAINTENANCE ODW EXT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	9/9/2015	REPLACED LAMPS	0.50
1509102834	MAINTENANCE ODW CEILING TILE	RM 694 CEILING TILES ARE STAINED	RM 604	9/9/2015	REPLACED TILE	0.50
1509102835	MAINTENANCE ODW EXT. LIGHTING	AREA 3 EAST LIGHTS OUT SOUTH OF POLE 4H	AREA 3 EAST	9/9/2015	REPLACED LAMPS	0.50
1509102853	MAINTENANCE ODW EXT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	9/9/2015	REPLACED LAMPS	1.00
1509102837	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 TOILET CLOGGED	W'S R/R 306	9/9/2015	PLUNGED TOILET. OK. CHECKED ALL TOILET SEATS AND TIGHTENED AS NEEDED.	0.50
1509102839	MAINTENANCE ODW PLUMBING	M'S R/R 810 URINAL #2 NOT FLUSHING	M'S R/R 810	9/9/2015	CHANGED BATTERIES. OK.	0.50
1509102891	MAINTENANCE ODW UTILITY WORK	B LOT - TWO HOLES NEED TO BE CUT IN TABLE AT A PLANT COOLING TOWER FOR ASHTRAYS TO SIT IN	B LOT	9/10/2015	CUT HOLES AND CLEANED UP	1.00
1509102892	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 TOILET #3 CLOGGED	M'S R/R 1005	9/10/2015	UNCLOGGED WITH PLUNGER	0.50
1509102893	MAINTENANCE ODW PLUMBING	M'S R/R 602 HANDICAP TOILET WILL NOT FLUSH	M'S R/R 602	9/10/2015	FLUSHED TOILET NUMEROUS TIMES. DOES NOT APPEAR TO BE A PROBLEM.	0.50
1509102894	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET OVERFLOWING	W'S R/R A309	9/10/2015	PLUNGED TOILET, FLUSHED. OK.	0.50
1509102901	MAINTENANCE ODW CEILING TILE	EAST COURTYARD HALLWAY CEILING TILE IS LOOSE	EAST COURTYARD HALLWAY	9/10/2015	REALIGNED SIX LOOSE CEILING TILES AROUND THE PERIMETER OF THE COURTYARD.	0.50
1509102927	MAINTENANCE ODW EXT. LIGHTING	AREA 4 SOUTH OF POLE 4O LIGHTS OUT	AREA 4	9/11/2015	REPLACED LAMPS	0.50
1509102928	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 TOILET #4 CLOGGED	M'S R/R 1005	9/11/2015	UNCLOGGED THE COMMODOE	0.50
1509102979	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 CLOGGED	M'S R/R B309	9/14/2015	UNCLOGGED THE COMMODOE	0.50
1509102980	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	9/14/2015	UNCLOGGED THE COMMODOE	0.50
1509102998	MAINTENANCE ODW PLUMBING	M'S R/R B309 HANDICAP TOILET WILL NOT STOP FLUSHING	M'S R/R B309	9/14/2015	ALL TOILETS AND URINALS ARE OPERATING PROPERLY	0.50
1509103001	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP STALL CLOGGED	W'S R/R 34	9/14/2015	PLUNGED TOILET. OK.	0.50
1509103052	MAINTENANCE ODW ELECTRICAL	SKYLITE CANTEEN MICROWAVE OVENS BREAKERS HAVE BLOWN	SKYLITE CANTEEN	9/15/2015	RESET BREAKER IN RM 312	0.50
1509103053	MAINTENANCE ODW INDOOR AIR QUAL	AREA 3 SW AIR FLOW NEEDS ADJUSTED BETWEEN POLES 3B AND 3C	AREA 3 SW	9/15/2015	BLOCKED FLOW ON DIFFUSER AT POLE 3C, RM 310. THE OTHER DIFFUSER WAS DAMPERED DOWN. VERY LOW AIR FLOW. NOTHING NEEDED FOR THAT ONE.	0.50
1509103054	MAINTENANCE ODW EXT. LIGHTING	W'S R/R A309 CANNISTER LIGHTS OUT	W'S R/R A309	9/15/2015	REPLACED LAMPS	0.50
1509103064	MAINTENANCE ODW EXT. LIGHTING	MAG HALL RM 21 ON THE LEFT-HAND SIDE THERE'S A LIGHT THAT'S BLINKING	MAG HALL RM 21	9/15/2015	CHECKED LIGHTS IN ROOM 21. RM 24 HAVING THE SAME TROUBLE. APPEARS TO BE POWER SURGES WE HAVE HAD TROUBLE WITH IN THE PAST.	0.50
1509103088	MAINTENANCE ODW CEILING TILE	RM 200, BADGE ROOM TWO CEILING TILES NEED REPLACED (ABOVE CUBICLE A2-007 AND A2-003)	RM 200, BADGE ROOM	9/16/2015	REPLACED 6 CEILING TILES	3.00
1509103089	MAINTENANCE ODW EXT. LIGHTING	MADISON ST. PARKING LOT NEEDS OUTSIDE LIGHTS PUT UP FOR NTEU LABOR RECOGNITION	MADISON ST. PARKING LOT	9/16/2015	INSTALLED OUTSIDE LIGHTS FOR NTEU	2.00
1509103098	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 IS CLOGGED	M'S R/R B309	9/16/2015	UNCLOGGED WITH PLUNGER	0.50
1509103099	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 5 TOILET #1 TOILET CLOGGED	MAG HALL 5	9/16/2015	FLUSHED TOILET, FUNCTIONING NORMALLY	0.50
1509103100	MAINTENANCE ODW EXT. LIGHTING	POLE 4J ACROSS FROM PODS A3-027 AND A3-026 - LIGHT COVER NEEDS REINSERTED	POLE 4J	9/16/2015	COVER LOOSE AT ONE CORNER. SECURED LATCH. COVER OK.	0.50
1509103110	MAINTENANCE ODW UTILITY WORK	Replace rotten landscape timber at the picnic table area next to central plant cooling tower. This is a tripping hazard and the Union is having their picnic next week.		9/16/2015	REPLACED LANDSCAPE TIMBER AT CENTRAL PLANT. REPLACED LANDSCAPE TIMBER AS GATE 2. \$15.54	1.00
1509103131	MAINTENANCE ODW PLUMBING	W'S R/R 1003 TOILET WILL NOT STOP FLUSHING	W'S R/R 1003	9/17/2015	TOILET #9 - FREED FLUSH BUTTON. OK.	0.50

1509103143	MAINTENANCE ODW CARPET	FRONT LOBBY BY GUARD STATION - CARPET TILE NEEDS REPLACED. REPLACEMENT PIECES CAN BE FOUND IN B304.	FRONT LOBBY BY GUARD STATION	9/17/2015	MOVED DESK, REPLACED CARPET TILE	0.50
1509103155	MAINTENANCE ODW DOOR	W'S R/R A600 INTERIOR HANDICAP BUTTON NOT WORKING	W'S R/R A600	9/17/2015	REPLACED BATTERIES	0.50
1509103158	MAINTENANCE ODW TEMPERATURE HOT	POLES 6V AND 7V TOO HOT	POLELS 6V AND 7V	9/17/2015	LOWERED SET POINT TO 73 DEG.	0.50
1509103181	MAINTENANCE ODW EXT. LIGHTING	LOBBY - TWO SPOT LIGHTS ARE OUT	LOBBY	9/18/2015	REPLACED 2 BURNED OUT LIGHTS	0.75
1509103264	MAINTENANCE ODW EXT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	9/21/2015	REPLACED LIGHT BULBS	0.50
1509103265	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	9/21/2015	UNCLOGGED THE COMMODO	0.50
1509103271	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #4 CLOGGED	M'S R/R B309	9/21/2015	UNCLOGGED THE COMMODO	0.50
1509103266	MAINTENANCE ODW PLUMBING	M'S R/R 1005 #1 URINAL HAS LOW FLOW	M'S R/R 1005	9/21/2015	PLUNGED URINAL. OK.	0.50
1509103269	MAINTENANCE ODW PLUMBING	W'S R/R A1003 SINK #3 CONSTANTLY RUNNING	W'S R/R A1003	9/21/2015	REPLACED SOLENOID. FAUCET NOW OPERATING CORRECTLY. WIPED UP FROM LEAKING WATER.	0.75
1509103282	MAINTENANCE ODW PLUMBING	W'S R/R A5 (MAG HALL) TOILET #3 WILL NOT FLUSH	W'S R/R A5	9/22/2015	REPLACED DIAPHRAGM	0.50
1509103285	MAINTENANCE ODW EXT. LIGHTING	POLE 7HH LIGHT FLICKERING	POLE 7HH	9/22/2015	REPLACED LAMP OVER CUBICLE GDI-A12-032	0.50
1509103344	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 123 SINK IS CLOGGED	CHILDCARE RM 123	9/23/2015	PLUNGED SINK. REMOVED PAINT BRUSHES. NEED TO SNAKE THROUGH CLEAN OUT IN LUNCH ROOM. SNAKED DRAIN AFTER LUNCH. RAN SINKS. CLOG IS CLEARED.	1.00
1509103353	MAINTENANCE ODW PAINTING	MAG HALL W'S R/R 34 WALLPAPER LOOSE AT SEAMS/MISSING PIECES.	MAG HALL W'S R/R 34	9/23/2015	REGLUED SEAMS IN VARIOUS PLACES AND PATCHED WALLPAPER THAT WAS MISSING.	2.00
1509103381	MAINTENANCE ODW EXT. LIGHTING	AREA 13 LIGHTS OUT	AREA 13	9/24/2015	REPLACED LAMPS	1.00
1509103380	MAINTENANCE ODW BLDG/EQUIP. REP	Crash rail needs secured to the wall in the Child Care cafeteria to the left of the wash fountain.	CHILDCARE	9/24/2015	WALL ANCHORS WERE LOOSE. TIGHENED. NOW RAIL IS OK.	0.75
1509103379	MAINTENANCE ODW EXT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	9/24/2015	AREA 12 (NOT AREA 10) REPLACED BULBS	1.50
1509103378	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP STALL CLOGGED	W'S R/R 34	9/24/2015	PLUNGED TOILET. OK.	0.50
1509103376	MAINTENANCE ODW BLDG/EQUIP. REP	Child Care; paint water stained wall below water fountain in cafeteria and paint wall below crash rail to the left of hand wash station.	CHILD CARE	9/24/2015	STAIN BLOCKED WATER STAINS AND PAINTED THE AREAS LISTED ON ODW	1.00
1509103377	MAINTENANCE ODW BLINDS	CHILDCARE RM 126 BLINDS FELL	CHILDCARE RM 126	9/24/2015	BLINDS OK. NYLON CHAIN HAD BEEN PULLED OUT OF BLIND MECHANISM. REATTACHED CHAIN AND CHECKED BLIND OPERATION. OK.	0.50
1509103425	MAINTENANCE ODW PLUMBING	W'S R/R 700 TOILET #7 WILL NOT FLUSH	W'S R/R 700	9/24/2015	REPLACED FLUSH HEAD WITH REBUILT STOCK	0.50
1509103426	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R 700 STALL #5 TOILET PAPER DISPENSER WILL NOT LOCK	W'S R/R 700	9/24/2015	REPLACED TOILET PAPER DISPENSER	0.50
1509103430	MAINTENANCE ODW EXT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	9/25/2015	REPLACED LIGHT BULBS AND CLEANED THREE LIGHT LENSES	1.00
1509103431	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	9/25/2015	REPLACED LIGHT BULBS AND CLEANED ONE LIGHT LENS	0.50
1509103432	MAINTENANCE ODW WATER FOUNTAIN	POLE 5X FOUNTAIN HAS CLOGGED DRAIN. (W10-021)	POLE 5X	9/25/2015	UNCLOGGED WITH VACUUM	0.50
1509103434	MAINTENANCE ODW ELECTRICAL	AREA 9 FOUR FLOOR OUTLETS MISSING COVERS	AREA 9	9/25/2015	REPLACED WSI COVERS	0.50
1509103435	MAINTENANCE ODW EXT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	9/25/2015	REPLACED LIGHT BULBS AND VACUUMED FOUR LIGHT FIXTURES	1.25
1509103439	MAINTENANCE ODW UTILITY WORK	HEALTH UNIT NEEDS LOCK BOX HUNG. "X" MARKS THE SPOT.	HEALTH UNIT	9/25/2015	HUNG LOCK BOX	1.00
1509103457	MAINTENANCE ODW EXT. LIGHTING	Light are out in my office. I believe the guy with the pig tails has something to do with it.	103C	9/25/2015	TIGHTENED LOOSE WIRE NUT	0.50
1509103468	MAINTENANCE ODW PAINTING	Childcare- Repair all minor nicks and touch up painting as needed in RM's 123, 126, and 128.	CHILDCARE	9/28/2015	PATCHED WALLS ON 9/29/15. PAINTED PATCHES ON 9/30/15. 10-4-15: PATCHED, PAINTED ALL SURFACES AS NEEDED.	7.00
1509103487	MAINTENANCE ODW EXT. LIGHTING	SCAMPS OVERHEAD LIGHTS OUT	SCAMPS	9/28/2015	REPLACED LIGHT BULBS	0.50
1509103489	MAINTENANCE ODW EXT. LIGHTING	RM 815 LIGHTS OUT	RM 815	9/28/2015	REPLACED LIGHT BULBS	0.50
1509103491	MAINTENANCE ODW PLUMBING	M'S R/R 308 TOILET CLOGGED	M'S R/R 308	9/28/2015	UNCLOGGED THE COMMODO	0.50
1509103492	MAINTENANCE ODW EXT. LIGHTING	AREA 1 LIGHT FIXTURE AND LAMPS OUT	AREA 1	9/28/2015	REPLACED BALLAST IN FIXTURE AND REPLACED LAMPS	2.00
1509103493	MAINTENANCE ODW PLUMBING	W'S R/R 600 TOILET WILL NOT STOP FLUSHING	W'S R/R 600	9/28/2015	CHANGED FLUSH HEAD. OK.	0.50
1509103536	MAINTENANCE ODW INT. LIGHTING	THIRD ROW OVER FROM POLE 5P A LIGHT KEEPS FLICKERING	POLE 5P	9/29/2015	REPLACED LAMPS	0.50
1509103537	MAINTENANCE ODW WATER FOUNTAIN	DOOR 21 WATER FOUNTAIN PRODUCING DISCOLORED WATER	DOOR 21	9/29/2015	RAN FOUNTAIN, WATER WAS CLEAR	0.50
1509103543	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #1 OVERFLOWING	W'S R/R B211	9/29/2015	UNCLOGGED WITH PLUNGER. HELPED WITH CLEAN-UP.	0.50
1509103544	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT NEAR POLE 4C	AREA 3	9/29/2015	REPLACED LAMPS	0.50
1509103545	MAINTENANCE ODW PAINTING	North side of B Canteen on the west wall needs drywall repaired next to hand sanitizer.	B CANTEEN	9/29/2015	COMPLETED. MUDDED AND PAINTED.	1.00
1509103548	MAINTENANCE ODW EXT. LIGHTING	W'S R/R B302 EGG CRATE FELL	W'S R/R B302	9/29/2015	PUT EGG CRATE BACK INTO ITS PROPER PLACE	0.50
1509103588	MAINTENANCE ODW PLUMBING	W'S R/R A700H TOILET CONSTANTLY FLUSHING	W'S R/R A700H	9/30/2015	CHANGED BATTERIES IN FLUSH HEAD	0.50
1510102797	MAINTENANCE ODW EXT. LIGHTING	POLE 7DD LIGHT FIXTURE IS HANGING DOWN	POLE 7DD	10/1/2015	PUT LENS IN PLACE	1.00
1510102798	MAINTENANCE ODW EXT. LIGHTING	CONTROL CENTER LIGHTS OUT OVER SECURITY SAFE	CONTROL CENTER	10/1/2015	REPLACED 4 LAMPS	1.00
1510102801	MAINTENANCE ODW PAINTING	CHILDCARE RM 130 HAS CHIPPING AND PEELING PAINT	CHILDCARE RM 130	10/1/2015	PATCHED AND PAINTED VARIOUS SPOTS	1.00
1510102802	MAINTENANCE ODW PAINTING	CHILDCARE RM 109 PEELING PAINT AND FLAKING DRYWALL NEXT TO DOOR LEADING OUTSIDE	CHILDCAREN RM 109	10/1/2015	PATCHED WALL AND PAINTED	1.00
1510102803	MAINTENANCE ODW INT. LIGHTING	RM 804 OVERHEAD LIGHTS OUT	RM 804	10/1/2015	REPLACED LIGHT BULBS	0.50
1510102804	MAINTENANCE ODW EXT. LIGHTING	AREA 11 OVERHEAD LIGHTS OUT	AREA 11	10/1/2015	REPLACED LIGHT BULBS	0.75
1510102805	MAINTENANCE ODW DOOR	CHILDCARE RM 107 EXIT DOOR ALARM "CHIRPING"	CHILDCARE RM 107	10/1/2015	REPLACED BATTERY	0.50

1510102806	MAINTENANCE ODW PAINTING	AREA 7 WALL ON BOTH SIDES OF PUSH BUTTON NEEDS PATCHED AND PAINTED	AREA 7	10/1/2015	PATCHED AND PAINTED WALL. 10-13-15: TOOK PAINT SAMPLE TO MATCH COLOR ON WALL. TOUCHED UP PATCHES THEN REPAINTED THE WALL.	3.00
1510102842	MAINTENANCE ODW BLDG/EQUIP. REP	Clean Maintenance shop; The maintenance shop is not a storage area. Please put all tools and material in the appropriate locations.	MAINTENANCE SHOP	10/2/2015	CLEANED UP MAINTENANCE SHOP	1.00
1510102895	MAINTENANCE ODW SAFETY ISSUE	POLE 4R - LADDER BLOCKING DOOR PREVENTING WORKER TO ENTER OFFICE.	POLE 4R	10/5/2015	REMOVED LADDER AND PUT IT IN RM 409	0.50
1510102894	MAINTENANCE ODW PLUMBING	CHILDCARE GARDEN AREA - PIPES ARE COMING OUT FROM THE 6X6 BOX	CHILDCARE GARDEN AREA	10/5/2015	PUSHED BOX BACK INTO WALL. 10-6-15: REINSTALLED USING EXTERIOR CONSTRUCTION ADHESIVE. NEEDS 24 HOURS TO CURE AND 7 DAYS FOR A FULL SET-UP.	2.00
1510102913	MAINTENANCE ODW TEMPERATURE HOT	SECURITY OFFICE - CAN ADJUST TEMPERATURE BUT WILL NOT COOL	SECURITY OFFICE	10/5/2015	UNIT WAS IN ECONOMIZER MODE WITH MECHANICAL COOLING LOCKED OUT. UNIT WAS MECHANICALLY COOLING BY THE TIME I CHECKED. NOW COOLING OK.	0.50
1510102914	MAINTENANCE ODW ELECTRICAL	CANTEEN B FUSE BLOWN	CANTEEN B	10/5/2015	RESET BREAKER IN B312	0.50
1510102919	MAINTENANCE ODW CEILING TILE	AREA 1 SOUTH OF POLE 8K 2 STAINED CEILING TILES. CHECK FOR LEAKS.	AREA 1	10/5/2015	REPLACED TILE NORTH OF POLE 8K. 10-11-15: REPLACED TILE OVER CUBICLE GDI-A1-012 AND ONE TILE WEST OF CUBICLE.	1.00
1510102986	MAINTENANCE ODW UTILITY WORK	DOOR 7 EEO SIGN NEEDS TO BE RELOCATED TO RM 2 IN MAG HALL	DOOR 7	10/6/2015	SWITCHED SIGNS. RM 7 NOW READS "OFFICE" AND RM 2 NOW READS "EEO."	0.50
1510102987	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 404 TOILET #3 CLOGGED	W'S R/R 404	10/6/2015	UNCLOGGED THE COMMODE	0.50
1510102988	MAINTENANCE ODW EXT. LIGHTING	AREA 10 LIGHTS OUT SW OF POLE 6W	AREA 10	10/6/2015	REPLACED BALLAST AND LIGHT BULBS	0.75
1510102989	MAINTENANCE ODW PLUMBING	M'S R/R 810 URINAL #2 WILL NOT FLUSH	M'S R/R 810	10/6/2015	WATER HAD CORRODED BATTERY CONTACTS. SANDED CONTACT AND REPLACED BATTERIES.	0.75
1510102990	MAINTENANCE ODW PLUMBING	W'S R/R 1003 TOILETS 9, 10, 12 AND 14 ARE FLUSHING AND THE RESTROOM IS EMPTY	W'S R/R 1003	10/6/2015	ADJUSTED FLUSH HEAD'S RANGE LOWER SO THAT AJAR STALL DOORS COULDN'T CAUSE COMMODOES TO FLUSH	1.00
1510102991	MAINTENANCE ODW DOOR	DOOR 15 WILL NOT SECURE	DOOR 15	10/6/2015	TOOK APART PANIC BAR AND LUBRICATED ALL MOVING PARTS FROM TOP TO BOTTOM. DOOR IS SECURED.	1.00
1510102992	MAINTENANCE ODW DOOR	M'S R/R 1005 LEFT SIDDE CABINET DOOR WILL NOT COMPLETELY CLOSE	M'S R/R 1005	10/6/2015	TIGHTENED UP ALL HINGE HARDWARE ON TWO CABINET DOORS	0.50
1510103011	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 TOILET OVER-FLOWING	W'S R/R A309	10/7/2015	UNCLOGGED COMMODE. REMOVED A ROLL OF TOILET PAPER.	0.50
1510103012	MAINTENANCE ODW CEILING TILE	AREA 11 HW VALVE LEAKED AND THERE ARE STAINED TILES	AREA 11	10/7/2015	REPLACED VALVE. REPLACED CEILING TILES.	4.00
1510103013	MAINTENANCE ODW PLUMBING	M'S R/R A309 TOILET #5 WILL NOT FLUSH	M'S R/R B309	10/7/2015	REPLACED BATTERIES IN FLUSH HEAD	0.50
1510103017	MAINTENANCE ODW ELECTRICAL	SENSORS ARE NOT TURNING LIGHTS ON. THE LIGHTS ARE CURRENTLY TIED INTO THE OLD PRINT ROOM LIGHT CIRCUIT AND NEEDS TO BE TIED INTO AREA 14 OR EMERGENCY LIGHT CIRCUIT	POLE 2JJ	10/7/2015	MOVED THREE LIGHTS FROM OLD PRINT ROOM CIRCUIT TO AREA 14 LIGHT CIRCUIT.	6.00
1510103029	MAINTENANCE ODW EXT. LIGHTING	POLE 4M LIGHTS OUT OVER DESK	POLE 4M	10/8/2015	REPLACED BALLAST	2.00
1510103041	MAINTENANCE ODW EXT. LIGHTING	AREA 11 BALLAST AND LAMPS OUT SW CORNER OF 4S	AREA 11	10/8/2015	REPLACED BALLAST AND LAMPS.	1.00
1510103065	MAINTENANCE ODW BLINDS	CHILDCARE RM 130 WINDOW SHADE HAS FALLEN AND NEEDS REHUNG	CHILDCARE RM 130	10/9/2015	REHUNG SHADE AND SHIMMED BRACKETS.	0.50
1510103066	MAINTENANCE ODW DOOR	CHILDCARE RM 123 DOOR GUARD ON THE OUTSIDE, BOTTOM OF DOOR NEEDS PUT BACK IN TRACK	CHILDCARE RM 123	10/9/2015	PUT GUARD BACK ON TRACK	0.50
1510103067	MAINTENANCE ODW EXT. LIGHTING	CHILDCARE STAFF LOUNGE LIGHT OUT ABOVE SINK	CHILDCARE STAFF LOUNGE	10/9/2015	REPLACED LIGHT BULBS	0.50
1510103068	MAINTENANCE ODW DOOR	CHILDCARE RM 107 TOP SECTION OF DOOR IS DRAGGING	CHILDCARE RM 107	10/9/2015	TIGHTENED DOWN ALL HINGE SCREWS ON TOP SECTION OF DOOR. TIGHTENED SCREWS ON DOOR OPEN HOLDER MOUNTED ON TOP OF DOOR.	0.50
1510103069	MAINTENANCE ODW UTILITY WORK	CHILDCARE LARGE PLAY AREA - FIRE TRUCK PANELS HAVE PULLED APART. ONE SECTION IS MISSING A SCREW/BOLT; ADJACENT SECTION SCREW/BOLT IS LOOSE.	CHILDCARE LARGE PLAY AREA	10/9/2015	TIGHTENED SCREWS AND ADDED SCREWS TO SECURE PANELS TIGHTLY INTO PLACE.	0.50
1510103070	MAINTENANCE ODW EXT. LIGHTING	AREA 4 LIGHTS OUT SOUTH OF POLE 5O	AREA 4	10/9/2015	ADDITIONAL LIGHTS OUT AT POLE 4Q AND 4M. REPLACED 16 LAMPS.	2.00
1510103071	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 404 #7 TOILET CLOGGED	W'S R/R 404	10/9/2015	UNCLOGGED WITH PLUNGER	0.50
1510103173	MAINTENANCE ODW PLUMBING	W'S R/R B302 HANDICAP STALL TOILET IS LEAKING	W'S R/R B302	10/13/2015	REPLACED MOUNTING GASKET	1.50
1510103175	MAINTENANCE ODW PAINTING	DOOR 18 SOUTH WALL SCUFFED AND MARKED UP	DOOR 18	10/13/2015	PAINTED WALL FROM DOUBLE GLASS DOOR TO DOUBLE GLASS DOOR (SOUTH WALL)	1.50
1510103177	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 OVERFLOWING	W'S R/R 306	10/14/2015	FLOOR WAS DRY. FLUSHED TOILET 3 TIMES. NO PROBLEM. NO FURTHER ACTION TAKEN.	0.50
1510103194	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 TOILET #1 CLOGGED	M'S R/R A810	10/14/2015	PLUNGED TOILET AND TIGHTENED SEAT BOLTS	0.50
1510103298	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 CLOGGED	W'S R/R 306	10/15/2015	UNCLOGGED WITH PLUNGER	0.50
1510103299	MAINTENANCE ODW PLUMBING	M'S R/R 700 TOILET #1 CONSTANTLY FLUSHING	M'S R/R 700	10/15/2015	REPLACED BATTERIES	0.50
1510103300	MAINTENANCE ODW WATER FOUNTAIN	AREA 11 WATER FOUNTAIN AT POLE 5X IS CLOGGED	AREA 11	10/15/2015	CLEARED DRAIN WITH WET VAC	0.50
1510103301	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #14 CLOGGED	W'S R/R B211	10/15/2015	UNCLOGGED WITH PLUNGER	0.50
1510103315	MAINTENANCE ODW NOISE	RM 15 HISSING SOUND COMING FROM EGG CRATE	RM 15	10/15/2015	REPLACED PNEUMATIC VALVE DIAPHRAGM WITH REBUILT STOCK.	3.00
1510103316	MAINTENANCE ODW PLUMBING	W'S R/R 34 TOILET CONSTANTLY FLUSHING	W'S R/R 34	10/15/2015	REPLACED FLUSH HEAD WITH REBUILT ONE	0.50
1510103317	MAINTENANCE ODW PLUMBING	W'S R/R 700 TOILET NEXT TO SHOWER WILL NOT FLUSH	W'S R/R 700	10/15/2015	REPLACED BATTERIES	0.50

1510103345	MAINTENANCE ODW PLUMBING	W'S R/R 306 STALL #5 WILL NOT FLUSH	W'S R/R 306	10/15/2015	CHECKED COMMODE. COMMODE FLUSHING JUST FINE.	0.50
1510103354	MAINTENANCE ODW NOISE	FILTERS NEED REPLACED. CHECK ALARM LIGHT IN AREAS.	HEPA EXHAUST #5	10/16/2015	REPLACED FILTERS. ALARM LIGHT OUT.	0.50
1510103355	MAINTENANCE ODW NOISE	HEPA EXHAUST #7 PREFILTERS NEED TO BE REPLACED	HEPA EXHAUST #7	10/16/2015	REPLACED AIR FILTERS AND POLE INDICATOR LIGHT WENT OUT	0.50
1510103356	MAINTENANCE ODW EXT. LIGHTING	MAG HALL 15 LIGHTS OUT	MAG HALL 15	10/16/2015	REPLACED LAMPS	0.50
1510103357	MAINTENANCE ODW PLUMBING	W'S R/R 600 TOILET #7 CONSTANTLY RUNNING	W'S R/R 600	10/16/2015	REPLACED FLUSH HEAD WITH REBUILT ONE	0.50
1510103361	MAINTENANCE ODW ELECTRICAL	CANTEEN B FUSE BLOWN	CANTEEN B	10/16/2015	RESEET BREAKER IN PANEL IN CANTEEN	0.50
1510103412	MAINTENANCE ODW WATER FOUNTAIN	DOOR 21 DRINKING FOUNTAIN IS SPRAYING WATER IN TWO DIFFERENT DIRECTIONS	DOOR 21	10/19/2015	CLEANED OUT BOTH NOZZLES WITH A PAPERCLIP.	0.50
1510103413	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 SINK #3 WILL NOT DRAIN	W'S R/R A309	10/19/2015	SNAKED OUT DRAIN	1.00
1510103414	MAINTENANCE ODW EXT. LIGHTING	AREA 6 LIGHT FIXTURE AND LIGHTS OUT	AREA 6	10/19/2015	REPLACED BALLAST AND LAMPS	0.50
1510103451	MAINTENANCE ODW PLUMBING	W'S R/R B211 HANDICAP SINK - WATER WILL NOT TURN ON	W'S R/R B211	10/19/2015	REPLACED SOLENOID	1.00
1510103452	MAINTENANCE ODW BLDG/EQUIP. REP	We need Jeff to change the light zoning programing in Metasys. He can get with Jay for all the details.		10/20/2015	MODIFIED METASYS PROGRAMMING FOR LIGHTING ZONES: ZONE 3-3 WILL BRING ON ZONE 4-1. ZONE 11-1 MOTION DETECTOR WILL BRING ON BOTH LIGHTING ZONES IN AREA 11. EITHER MOTION DETECTOR IN ZONES 12-3 OR 12-4 WILL BRING ON BOTH LIGHTING ZONES.	1.00
1510103458	MAINTENANCE ODW EXT. LIGHTING	POLES 5G AND 4G CEILING LIGHT IS FLASHING	POLES 5G 4G	10/20/2015	REPLACED LAMPS	0.50
1510103468	MAINTENANCE ODW LEAKS	GATE HOUSE 5 LEAKS WHEN IT RAINS	GATE HOUSE 5	10/20/2015	REMOVED OLD SEALANT AROUND WINDOWS AND DOOR. APPLIED NEW SEALANT. APPLIED NEW SEALANT TO ROOF.	1.50
1510103469	MAINTENANCE ODW TEMPERATURE COLD	AREA 3 IS TOO COLD	AREA 3	10/20/2015	CHECKED TEMP. WAS 73 DEG. RAISED ONE DEG TO 74 DEG.	0.50
1510103513	MAINTENANCE ODW EXT. LIGHTING	4J AND UNION OFFICE LIGHT LENS MISSING	4J AND UNION OFFICE	10/21/2015	REPLACED LENS COVER	0.50
1510103601	MAINTENANCE ODW PLUMBING CLOG	CHILD CARE RM 103 SINK CLOGGED	CHILD CARE RM 103	10/22/2015	CLEARED CLOGGED SINK DRAIN. REBUILT WASTE LINE FROM SINK BASKET TO THE WALL. HOME DEPOT: \$29.38	6.00
1510103626	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 CLOGGED	M'S R/R B309	10/22/2015	#3 WAS NOT CLOGGED. CHECKED ALL TOILETS TO MAKE SURE I WAS GIVEN THE RIGHT STALL NUMBER. NO TOILETS WERE CLOGGED.	0.50
1510103627	MAINTENANCE ODW INT. LIGHTING	W'S R/R 1003 LIGHTS OUT ABOVE SINKS	W'S R/R 1003	10/22/2015	REPLACED LIGHT BULBS	0.50
1510103653	MAINTENANCE ODW EXT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	10/23/2015	REPLACED LIGHT BULBS AND VACUUMED LIGHT LENSES	0.75
1510103657	MAINTENANCE ODW EXT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	10/23/2015	REPLACED LIGHT BULBS, VACUUMED LIGHT FIXTURES, REPLACED REGULAR BALLAST IN ONE EMERGENCY LIGHT FIXTURE	1.50
1510103697	MAINTENANCE ODW EXT. LIGHTING	MAG HALL - THREE LIGHTS OUT. IT IS THE LAST OFFICE ON LEFT (ACROSSED FROM DIRECTOR JIM ROGERS' OFFICE.)	MAG HALL	10/26/2015	REPLACED LAMPS	0.50
1510103717	MAINTENANCE ODW PLUMBING	W'S R/R 700H TOILET #2 CONTINUES TO RUN	W'S R/R 700H	10/26/2015	REPLACED BATTERIES IN FLUSH HEAD.	0.50
1510103716	MAINTENANCE ODW DOOR	RM 903 (D4-024-09) AUTO DOORS WILL NOT CLOSE	RM 903	10/26/2015	PUT LEFT SIDE DOOR BACK ON TRACK	0.50
1510103713	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 CLOGGED	M'S R/R B309	10/26/2015	UNCLOGGED COMMODE	0.50
1510103712	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 TOILET #9 CLOGGED	W'S R/R 1003	10/26/2015	UNCLOGGED COMMODE	0.50
1510103711	MAINTENANCE ODW EXT. LIGHTING	AREA 1 LIGHTS OUT	AREA 1	10/26/2015	REPLACED LAMPS	1.00
1510103709	MAINTENANCE ODW EXT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	10/26/2015	REPLACED LIGHT BULBS. REPLACED LIGHT BALLAST. VACUUMED LIGHT LENSES.	2.00
1510103710	MAINTENANCE ODW EXT. LIGHTING	AREA 3 LAMPS OUT SE OF POLE 5E AND LOOSE LENS COVERS	AREA 3	10/26/2015	REPLACED LAMPS AND REAPPLIED LENS COVERS	1.00
1510103756	MAINTENANCE ODW EXT. LIGHTING	AREA 12 POLE 8EE BALLAST IS BAD	AREA 12 POLE 8EE	10/27/2015	REPLACED WITH NEW	1.00
1510103757	MAINTENANCE ODW EXT. LIGHTING	SATELLITE CANTEEN SKYLIGHT LIGHT NOT WORKING	SATELLITE CANTEEN	10/27/2015	REPLACED LAMPS AND BALLAST	1.00
1510103758	MAINTENANCE ODW EXT. LIGHTING	NE OF POLE 7GG LIGHT FIXTURE NOT WORKING	NE OF POLE 7GG	10/27/2015	REPLACED LAMPS AND BALLAST	1.00
1510103763	MAINTENANCE ODW EXT. LIGHTING	AREA 14 BALLAST IS BAD	AREA 14	10/27/2015	REPLACED WITH NEW	1.00
1510103764	MAINTENANCE ODW STRUCTURAL PROB	NE CORNER OF FENCE BY CONVENTION CENTER NEEDS REPAIRED. PANELS ARE LOOSE AND SCREWS ARE MISSING. SEE ATTACHED MAP FOR EXACT LOCATION.	NE CORNER FENCE	10/27/2015	MADE NECESSARY REPAIRS TO PERIMETER FENCING. SECURED DAMAGED AREAS WITH NEW SCREWS FROM PARKING LOT SIDE, AS WELL AS CONVENTION CENTER SIDE. 11-8-15: REPAIRED BREAK AND REGROUTED AND POURED CONCRETE TO SECURE.	4.00
1510103774	MAINTENANCE ODW PAINTING	Repair drywall in area 3 ramp by Mag Hall. This was damaged a few weeks ago someone put mud on the wall and never finished the repair. Please advise all your employees to put tickets in all repairs as soon as they are discovered. There should be no reason this repair did not have a ticket initiated. I am putting this ticket in as an urgent because I want it addressed ASAP.		10/27/2015	PATCHED AND PAINTED WALL	1.00
1510103784	MAINTENANCE ODW EXT. LIGHTING	THERE IS A LIGHT BY B105 THAT FLICKERS ON/OFF OR JUST STAYS OFF	B105	10/27/2015	REPLACED BALLAST AND LAMPS	0.50
1510103792	MAINTENANCE ODW PAINTING	COLUMNS 7D, 7H, 7J, 7L, 7M, 7N, 7P, 7Q, 7X NEED TO BE PATCHED AND PAINTED. THE CENTER COLUMN ON THE WEST SIDE OF THE COURTYARD NEEDS TO BE PATCHED AND PAINTED.	COLUMN 7D, ETC.	10/27/2015	10-28-15: COMPLETED ALL COLUMNS EXCEPT THE WEST SIDE OF COURTYARD. 10-29-15: SANDED AND PAINTED WEST SIDE OF COURTYARD.	5.00

1510103791	MAINTENANCE ODW PAINTING	COLUMNS 5X, 5W, 5V, 5U, 5R, 5Q, 5P, 5O, 5N, 5M, 5H, 4L AND (THREE SIDES) OF 5L NEED TO BE PATCHED AND PAINTED. POLE NEXT TO COURTYARD DOOR ACROSS FROM 5G NEEDS TO BE PATCHED AND PAINTED.	COLUMN 5X, ETC.	10/27/2015	PATCHED AND PAINTED AFFECTED COLUMNS/AREAS.	2.00
1510103790	MAINTENANCE ODW INT. LIGHTING	M/S R/R B309 CAN LIGHT OUT	M/S R/R B309	10/27/2015	REPLACED LAMPS AND REATTACHED FIXTURE TO CHROME COVER	0.50
1510103816	MAINTENANCE ODW LEAKS	POLE 6GG WET CEILING TILE	POLE 6GG	10/28/2015	10-28-15: PLACED A DRAIN PAN AND BUCKET IN PROBLEM AREA (JW1). 10-30-15: PATCHED SEAM (MM). 10-30-15: REPLACED CEILING TILE (AG).	2.00
1510103829	MAINTENANCE ODW LEAKS	POLE 700J ROOF LEAK	POLE 700J	10/28/2015	PLACED PAN UNDER LEAK. LEAK IS ON SOUTH SIDE OF HEPA FILTER DUCT WORK PENETRATING THE ROOF. CAULKED ELECTRICAL PENETRATION ON HEPA UNIT (MM). REINSTALLED CEILING TILE (AG).	2.00
1510103828	MAINTENANCE ODW DOOR	SECURED EMERGENCY EXIT DOOR RC4 IS HARD TO OPEN	EXIT DOOR RC4	10/28/2015	TRIMMED WEATHER STRIPPING DOOR SWEEP ON BOTTOM OF LEFT DOOR (ENTERING FROM AREA 1). IT WAS TOO LONG AND WAS CAUSING IT TO JAM WITH THE RIGHT SIDE DOOR.	0.50
1510103827	MAINTENANCE ODW LEAKS	AREA 10 SOUTH OF 7U LEAK	AREA 10 SOUTH OF 7U	10/28/2015	10-28-15: PLACED A DRIP TAP AND BUCKET AT THE SITE OF LEAK (MM). 10-30-15: PATCHED SEAM (MM). 10-30-15: REPLACED 3 CEILING TILES (AG).	2.50
1510103826	MAINTENANCE ODW FLOOR TILE	AREA 3 SOUTH OF 4G 3"X3" HOLE IN FLOOR	AREA 3 SOUTH OF 4G	10/28/2015	REPLACED FLOOR TILE WITH SPARE TILE.	1.00
1510103844	MAINTENANCE ODW PLUMBING	W'S R/R 34 TOILET #2 WILL NOT FLUSH	W'S R/R 34 TOILET #2	10/28/2015	REPLACED FLUSH HEAD AND REPLACED VACUUM BREAKER.	1.00
1510103857	MAINTENANCE ODW INT. LIGHTING	ROOM B 200 A CEILING LIGHTS OUT	ROOM B 200 A	10/28/2015	REPLACED LIGHT BULBS	0.50
1510103879	MAINTENANCE ODW INT. LIGHTING	ROOM B 200 B CEILING LIGHTS OUT	ROOM B 200 B	10/28/2015	REPLACED LIGHTS	0.50
1510103865	MAINTENANCE ODW WATER FOUNTAIN	AREA 11, POLE 5X DRINKING FOUNTAIN CLOGGED	AREA 11, POLE 5X	10/29/2015	SNAKED AND PLUNGED. NO SUCCESS. REMOVED CLAY. REMOVED FOUNTAIN, PLUGGED WATER SUPPLY LINE. REPAIRED DRAIN. REMOVED TUB. DISCONNECTED ELECTRICITY AT PANEL. REPLASTERED AND PAINTED. REINSTALLED BASEBOARD AND TOESTRIP INTO PLACE. PARTS: \$43.79.	26.50
1510103878	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET #3 CONSTANTLY FLUSHING	W'S R/R A309	10/29/2015	CHANGED BATTERIES. REPLACED RUBBER WASHER AS THERE WAS A SLIGHT LEAK.	0.50
1510103889	MAINTENANCE ODW PAINTING	CHILD CARE RM 103 PAINT PEELING ON SOUTH WALL	CHILD CARE RM 103	10/29/2015	PATCHED WALL ON 10/28/15. PAINTED WALL ON 10/29/15.	1.00
1510103890	MAINTENANCE ODW ELECTRICAL	CENTRAL PLANT - CONDUIT ON PIT PUMP IS RUSTED	CENTRAL PLANT	10/29/2015	REPLACED CONDUIT WITH SEAL TIGHT. PUMP CSP-1-01 (M3-06-15)	3.00
1510103891	MAINTENANCE ODW ELECTRICAL	CENTRAL PLANT CONDUIT ON PIT PUMP IS RUSTED. PUMP CSP-1-02.	CENTRAL PLANT	10/29/2015	REPLACED CONDUIT WITH SEAL TIGHT. (M3-066-15)	3.00
1510103899	MAINTENANCE ODW DOOR	GATEHOUSE 3 (NORTH DOOR) IS HARD TO OPEN	GATEHOUSE 3	10/29/2015	VACUUMED BOTH SLIDING DOOR TRACKS. NORTH DOOR WAS BINDING IN TRACK. REANCHORED TRACK TO GIVE DOOR MORE ROOM TO SLIDE. (TRACK WAS TOO NARROW.)	0.75
1510103901	MAINTENANCE ODW PA SYSTEM	MAG HALL RM 31 PA SYSTEM NOT WORKING. UNABLE TO HEAR FROM SPEAKER.	MAG HALL RM 31	10/29/2015	TESTED PA SYSTEM. NO ISSUES FOUND.	0.00
1510103912	MAINTENANCE ODW EXT. LIGHTING	AREA 3 LIGHT LENS FELL. BROKEN PIECES ON FLOOR.	AREA 3	10/30/2015	MM: CLEANED UP LENS AND BROUGHT FRAME BACK TO SHOP. AG: CUT AND REPLACED LIGHT LENS.	0.75
1510103911	MAINTENANCE ODW FLOOR TILE	HALLWAY POLES 7R AND 7S - LOOSE FLOOR TILES IN HALLWAY	HALLWAY POLES 7R AND 7S	10/30/2015	CUT AND INSTALLED THREE FLOOR TILES	1.50
1510103910	MAINTENANCE ODW EXT. LIGHTING	AREA 5 SEVERAL LIGHTS OUT	AREA 5	10/30/2015	REPLACED LAMPS	1.00
1510103927	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 TOILET #7 CLOGGED	W'S R/R A404	10/30/2015	REPLACED FLUSH HEAD	0.00
1510103926	MAINTENANCE ODW TEMPERATURE HOT	B313 OLD COMPUTER ROOM/new office space - NORTH END TOO HOT	B313	10/30/2015	SET TEMP DOWN ON NORTH PNEUMATIC THERMOSTAT 2 DEG F. HAND HELD THERMOMETER SAID 72.4 DEG F.	0.50
1511101437	MAINTENANCE ODW PLUMBING	W'S R/R 600 SINK #6 WILL NOT TURN OFF	W'S R/R 600	11/2/2015	REPLACED SOLENOID VALVE AND BATTERIES	1.00
1511101441	MAINTENANCE ODW EXT. LIGHTING	RM 903 OVERHEAD LIGHTS OUT	RM 903	11/2/2015	REPLACED LIGHT BULBS AND BALLAST	1.25
1511101440	MAINTENANCE ODW INT. LIGHTING	AREA 8 "CAGE" OVERHEAD LIGHTS OUT	AREA 8	11/2/2015	REPLACED LIGHT BULBS	0.50
1511101439	MAINTENANCE ODW PAINTING	W'S R/R 309 WALL PAPER SEAMS COMING LOOSE BY ENTRY DOOR	W'S R/R 309	11/2/2015	REGLUED SEAMS AND WALLPAPER BY ENTRY DOOR	1.00
1511101438	MAINTENANCE ODW INT. LIGHTING	W'S R/R 309 LIGHT COVER LENS IS CRACKED	W'S R/R 309	11/2/2015	REPLACED WITH NEW LENS COVER	1.00
1511101436	MAINTENANCE ODW PLUMBING	CHILD CARE RM 130 HAS STANDING WATER ON THE FLOOR IN FRONT OF THE CHILDREN'S SINKS ON SOUTH SIDE OF ROOM	CHILD CARE RM 130	11/2/2015	CUT HOLE IN WALL TO LOCATE LEAK. REPAIRED LEAK AND REMOVED WET INSULATION. PATCHED THE HOLE THAT WAS CUT INTO THE AREA. REPATCHED AND PAINTED AREA WITH TWO COATS OF PAINT. INSTALLED BASEBOARD.	15.00
1511101435	MAINTENANCE ODW INT. LIGHTING	LIGHT OUT IN HALLWAY IN FRONT OF RM 123	CHILD CARE RM 123	11/2/2015	REPLACED BALLAST	1.00
1511101484	MAINTENANCE ODW UTILITY WORK	RECEIPT & CONTROL, EXTRACTION UNIT - NEEDS SIGN HUNG JUST INSIDE THE DOOR ON THE RIGHT	RECEIPT & CONTROL, EXTRACTION UNIT	11/2/2015	HUNG SIGN	0.50
1511101485	MAINTENANCE ODW UTILITY WORK	RECEIPT & CONTROL - NEEDS A SIGN HUNG NEAR THE DOOR MONITOR	RECEIPT & CONTROL	11/2/2015	HUNG SIGN	0.50
1511101486	MAINTENANCE ODW UTILITY WORK	BUILD B, ACCOUNTING - NEEDS A SIGN HUNG NEAR POLE 6DD	BUILD B - ACCOUNTING	11/2/2015	HUNG SIGN	0.50
1511101487	MAINTENANCE ODW UTILITY WORK	DATA CONVERSION - NEEDS A SIGN HUNG NEAR ROOM 406 AND POLE 4Q	DATA CONVERSION	11/2/2015	HUNG SIGN	0.50
1511101493	MAINTENANCE ODW NOISE	SECURITY BREAK ROOM WINDOW A/C UNIT IS MAKING A LOUD NOISE	SECURITY BREAK ROOM	11/2/2015	CHECKED UNIT AND IT WAS RUNNY FINE. COULD NOT HEAR ANY NOISE.	0.50
1511101494	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TWO TOILETS CLOGGED	W'S R/R B211	11/2/2015	SNAKED MAIN DRAIN	1.50

1511101495	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TWO TOILETS CLOGGED	W'S R/R B211	11/2/2015	DUPLICATE TICKET. REFER TO 1511101494.	0.00
1511101549	MAINTENANCE ODW ELECTRICAL	RM 300C - WHEN SHE TURNED HER COMPUTER ON, THE ELECTRIC IN OFFICE WENT OUT	RM 300C	11/3/2015	SOMEONE NAMED "CHRIS" SUPPLIED 300C WITH A NEW POWER STRIP. MIKE ROBINSON SPOKE WITH A WOMAN FROM 300A AND WAS INFORMED THAT THE PROBLEM WAS RECTIFIED.	0.50
1511101562	MAINTENANCE ODW EXT. LIGHTING	W'S R/R A309 TWO CAN LIGHTS OUT	W'S R/R A309	11/3/2015	REPLACED LAMPS	1.00
1511101564	MAINTENANCE ODW PAINTING	W'S R/R A309 COUNTER TOP NEEDS CAULKED	W'S R/R A309	11/3/2015	REMOVED OLD CAULK AND REPLACED WITH NEW. CLEAR CAULK ABOVE SPLASH GUARD AND WHITE BELOW. ALSO CAULKED TWO COUNTERS IN LOUNGE.	1.00
1511101565	MAINTENANCE ODW INT. LIGHTING	SOUTH OF POLE 4H A LIGHT LENS IS BROKEN AND SAGGING	SOUTH OF 4H	11/3/2015	REPLACED LENS	0.50
1511101569	MAINTENANCE ODW UTILITY WORK	MAG HALL BY ROOM 49 - CLOCK NEEDS TO BE STRAIGHTENED	MAG HALL	11/3/2015	STRAIGHTENED UP DOUBLE CLOCK BY ENTRANCE TO ROOM 49	0.50
1511102342	MAINTENANCE ODW ELECTRICAL	POLE 7DD - OUTLET IN THE FLOOR IS NOT WORKING. LOCATION: BETWEEN THE SECOND AND THIRD ROWS RIGHT BY POLE 7DD. (THREE SEATS DOWN ON THE LEFT OF THE THIRD ROW.)	7DD	11/4/2015	NO POWER WHIPS TO FLOOR BOX. BOX IS USED FOR PHONE AND DATA ONLY. NO EXTRA WHIPS UNDER FLOOR.	1.00
1511102393	MAINTENANCE ODW FLOOR TILE	COMPUTER ROOM - FLOOR TILE. BY SECOND PDU. GET A TILE (MAY HAVE ONE ALREADY CUT) AND PLACE WHERE NEEDED. WHEN SERVER IS INSTALLED, IT CAN BE PUT IN PLACE. (SEE ATTACHED.) SPEAK WITH DON FLYNN IF YOU NEED FURTHER CLARIFICATION, EXT. 6034.	COMPUTER ROOM	11/4/2015	REPLACED TILE	0.50
1511102394	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	11/4/2015	UNCLOGGED THE COMMODORE	0.50
1511102429	MAINTENANCE ODW DOOR	DOOR B2 WILL NOT CLOSE COMPLETELY	DOOR B2	11/4/2015	ADJUSTED DOOR CLOSER AND RAISED DOOR HEIGHT	1.00
1511102454	MAINTENANCE ODW INT. LIGHTING	RM 26, DIRECTOR'S OFFICE - LIGHTS OUT	RM 26	11/4/2015	REPLACED LAMPS	0.50
1511102458	MAINTENANCE ODW INT. LIGHTING	AREA 4 SOUTH LIGHTS OUT NEAR ROOM 404	AREA 4 SOUTH	11/5/2015	REPLACED LAMPS	0.50
1511102459	MAINTENANCE ODW INT. LIGHTING	AREA 4 - LIGHT LENS CRACKED SOUTH OF POLE 5M	AREA 4	11/5/2015	REPLACED LENS COVER	0.50
1511102460	MAINTENANCE ODW NOISE	CEILING HALLWAY - REHEAT VALVE IN HALLWAY OF MAG HALL BETWEEN ROOMS 3 AND 4 IS LEAKING	CEILING HALLWAY	11/5/2015	REPACKED REHEAT VALVE	3.00
1511102461	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 HANDICAP SINK IS CLOGGED	W'S R/R B211	11/5/2015	PLUNGED SINK. SNAKED AND AUGERED IT. TOOK TRAP AND TAIL PIECE OUT. ONCE CLOG REMOVED, POURED SEVERAL BUCKETS OF WATER DOWN DRAIN. OK.	2.00
1511102462	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B211 - TOILET SEAT IN TOILET #1 IS CRACKED	W'S R/R B211	11/5/2015	REPLACED TOILET SEAT	0.50
1511102463	MAINTENANCE ODW PLUMBING	W'S R/R 1003 HANDICAP SINK - NO WATER COMING FROM FAUCET	W'S R/R 1003	11/5/2015	REPLACED BATTERIES	0.50
1511102465	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R 1003 TOILET SEAT IN TOILET #4 IS CRACKED	W'S R/R 1003	11/5/2015	REPLACED TOILET SEAT	0.50
1511102467	MAINTENANCE ODW PLUMBING	M'S R/R B309 - SECOND AND THIRD SINKS FROM THE RIGHT DO NOT DISPENSE WATER	M'S R/R B309	11/5/2015	REPLACED BATTERIES IN BOTH SINKS	1.00
1511102468	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A600 - MOVE EXISTING HANDICAP SOAP DISPENSER TO UNDER CABINET	W'S R/R 600	11/5/2015	MOVED SOAP DISPENSER. REMOVED PLASTIC MOUNTING ANCHOR AND PATCHED TILE.	0.75
1511102469	MAINTENANCE ODW ELECTRICAL	W'S R/R A1003 - MOVE THE INSIDE HANDICAP BUTTON TO THE FRONT OF THE FIRST DOOR TO CABINET ON RIGHT	W'S R/R A1003	11/5/2015	MOVED HANDICAP BUTTON TO FRONT OF CABINET DOOR	2.00
1511102530	MAINTENANCE ODW INT. LIGHTING	AREA 3 SOUTH OF POLE 4K - LIGHTS OUT AND LENS COVER CRACKED	AREA 3	11/6/2015	REPLACED LAMPS AND LENS COVER	1.00
1511102531	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	11/6/2015	REPLACED LAMPS	0.50
1511102532	MAINTENANCE ODW INT. LIGHTING	LOCKER ROOM HAS DISCOLORED LAMPS	LOCKER ROOM	11/6/2015	REPLACED LAMPS	1.00
1511102550	MAINTENANCE ODW TEMPERATURE HOT	RM 32 TOO HOT	RM 32	11/6/2015	GLENWOOD HAD TURNED OFF AIR HANDLER TO PERFORM WORK. AHU TURNED BACK ON.	0.50
1511102573	MAINTENANCE ODW INT. LIGHTING	ROOM 200 - LIGHT IN CUBICLE 004 NEEDS TO BE REPLACED. IT IS GLOWING RED.	ROOM 200	11/6/2015	REPLACED LIGHTS	0.50
1511102551	MAINTENANCE ODW PLUMBING	W'S R/R 1003 TOILET CONSTANTLY FLUSHING	W'S R/R 1003	11/6/2015	REPLACED FLUSH HEAD	1.00
1511102552	MAINTENANCE ODW PLUMBING	W'S R/R 700H TOILET NEXT TO SHOWER CONSTANTLY FLUSHING	W'S R/R 700H	11/6/2015	REPLACED FLUSH HEAD	1.00
1511102574	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET CONSTANTLY FLUSHING	W'S R/R A309	11/6/2015	REPLACED FLUSH HEAD	0.00
1511102563	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 IS CLOGGED	W'S R/R 306	11/9/2015	UNCLOGGED THE COMMODORE	0.50
1511102564	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	11/9/2015	REPLACED ONE CRACKED LIGHT LENS, ONE BALLAST AND EIGHT LIGHT BULBS	1.50
1511102565	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 CLOGGED	M'S R/R B309	11/9/2015	UNCLOGGED THE COMMODORE	0.50
1511102567	MAINTENANCE ODW INT. LIGHTING	AREA 6 - 604 LIGHTS OUT	AREA 6 - 604	11/9/2015	REPLACED BALLAST AND LAMPS	1.50
1511102568	MAINTENANCE ODW INT. LIGHTING	M'S R/R 602 LIGHTS OUT	M'S R/R 602	11/9/2015	REPLACED FLOURESCENTS	0.50
1511102569	MAINTENANCE ODW INT. LIGHTING	CHILD CARE RM 130 LIGHTS OUT	CHILD CARE RM 130	11/9/2015	REPLACED LAMPS	0.50
1511102596	MAINTENANCE ODW PAINTING	M'S R/R B309 TOILET #2 CLOGGED	M'S R/R B309	11/10/2015	UNCLOGGED WITH PLUNGER	0.50
1511102597	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 CLOGGED	W'S R/R 306	11/10/2015	UNCLOGGED WITH PLUNGER	0.50
1511102598	MAINTENANCE ODW TEMPERATURE COLD	POLE 4U TOO COLD	POLE 4U	11/10/2015	TEMP READS 72.6 DEG. NO ADJUSTMENT.	0.50

1511102599	MAINTENANCE ODW FLOOR TILE	B313 COMPUTER ROOM - SOME TILES ARE STICKING UP. CHECK ENTIRE ROOM.	B313 COMPUTER ROOM	11/10/2015	RESEATED FOUR FLOOR TILES THAT WERE NOT SEATED FULLY. THERE ARE A FEW TILES THAT HAVE A RAISED EDGE AND WILL NOT SEAT FULLY. CONTRACTOR SHOULD RETURN TO CORRECT.	1.00
1511102649	MAINTENANCE ODW TEMPERATURE COLD	RM 6 TOO COLD	RM 6	11/12/2015	STARTED BOILER @ 0900	0.50
1511102650	MAINTENANCE ODW UTILITY WORK	RM 7 AND 8 - MOVE 3 RETURN CRATES OFF OF DIVIDING WALL OF RM 6	RM 7 AND 8	11/12/2015	MOVED THREE RETURN CRATES IN THE CEILING. USED EXTRA 2'X2' CEILING TILES WITH TWO OF THE RETURN CRATES.	0.75
1511102651	MAINTENANCE ODW FLOOR TILE	RM B313 REMOVE THRESHOLD AND REPALCE TILES THAT HAVE HOLES IN THEM. (NORTH DOOR HALLWAY B2.)	RM B313	11/12/2015	REMOVED THRESHOLD FROM NEW ENTRY DOOR TO B313 (DOOR B2 HALLWAY SIDE). REPLACED TWO FLOOR TILES THAT HAD HOLES IN THEM WITH SOLID/CLEAN TILES. TILES ON THE DOOR JAMB SIDE ARE NOT REMOVABLE WITHOUT REMOVING DOOR FRAME.	1.00
1511102672	MAINTENANCE ODW ELECTRICAL	AREA 3 WFI COVER MISSING SOUTH OF POLE 4H NEAR RAIL	AREA 3	11/12/2015	REPLACED COVER	0.50
1511102673	MAINTENANCE ODW INT. LIGHTING	RM 805 OVERHEAD LIGHTS OUT	RM 805	11/12/2015	REPLACED LIGHT BULBS	0.50
1511102674	MAINTENANCE ODW INT. LIGHTING	RM 803 OVERHEAD LIGHTS OUT	RM 803	11/12/2015	REPLACED LIGHT BULBS	0.50
1511102675	MAINTENANCE ODW INT. LIGHTING	AREA 8 HALLWAY LIGHTS OUT IN FRONT OF ROOM 807	AREA 8 HALLWAY	11/12/2015	REPLACED LIGHT BULBS	0.50
1511102720	MAINTENANCE ODW LEAKS	POLE 10M - LEAK FROM SPRINKLER PIPE. ECKERT (ABCO) HAS BEEN NOTIFIED.	POLE 10M	11/13/2015	TD ACTED AS ESCORT FOR ECKERT. ECKERT REPLACED A LEAKING PIPE. COST: \$1,315.86. REPLACED TWO CEILING TILES.	1.50
1511102721	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT NEAR POLE 4N AND TWO SAGGING COVERS	AREA 3	11/13/2015	REPLACED LAMPS AND REPAIRED COVERS	0.50
1511102733	MAINTENANCE ODW TEMPERATURE COLD	RM 307 TOO COLD	RM 307	11/13/2015	RAISED SPACE TEMP SETPOINT FOR UNIT 2-3 TO 75 DEG F.	0.50
1511102734	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET #3 CONTINUOUSLY FLUSHING	W'S R/R A309	11/13/2015	REPLACED FLUSH HEAD AND DIAPHRAGM	0.75
1511102755	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	11/16/2015	REPLACED 8 LIGHT BULBS AND VACUUMED TWO LIGHT LENSES	0.75
1511102761	MAINTENANCE ODW INT. LIGHTING	AREA 11 OVERHEAD LIGHTS OUT	AREA 11	11/16/2015	REPLACED 20 LIGHT BULBS	0.75
1511102760	MAINTENANCE ODW INT. LIGHTING	COURTYARD KITCHEN AND STORE AREA - LIGHTS OUT	COURTYARD KITCHEN	11/16/2015	REPLACED LAMPS	0.00
1511102759	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT	AREA 3	11/16/2015	REPLACED LAMPS.	0.50
1511102758	MAINTENANCE ODW BLDG/EQUIP. REP	DOCK - COMPACTOR ONLY GOES SO FAR THEN STOPS	DOCK	11/16/2015	DAN REPORTS THAT UNIT STARTED WORKING CORRECTLY AROUND 10 AM. CHECKED HYDRAULIC OIL LEVEL, OK. CYCLED UNIT THREE TIMES. WORKED PERFECTLY EACH TIME. NO ISSUES FOUND.	0.50
1511102806	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT BETWEEN 3W/4W	AREA 11	11/16/2015	REPLACED LIGHTS	1.00
1511102808	MAINTENANCE ODW CEILING TILE	AREA 11 STAINED TILE SOUTH OF 4Y	AREA 11	11/16/2015	REPLACED CEILING TILE	0.50
1511102809	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT BETWEEN POLES 5S/5T	AREA 11	11/16/2015	11-15-15: REPLACED BULB AS WELL AS BULB FIXTURES AND WIRES. DID NOT FIX THE ISSUE. 11-16-15: REPLACED ONE REGULAR BALLAST AND ONE EMERGENCY BALLAST.	4.00
1511102852	MAINTENANCE ODW KITCHEN EQUIP	CHILD CARE - IS EMITTING A FIRE SMELL	CHILD CARE	11/17/2015	RESET DISHWASHER. RAN 2 CYCLES, OK. THEY WILL CALL IF THERE ARE FURTHER PROBLEMS.	2.00
1511102853	MAINTENANCE ODW TEMPERATURE COLD	RMS 46 AND 47 TOO COLD	RMS 46 AND 47	11/17/2015	RAISED UNIT 12-3 SPACE SETPOINT FROM 69 DEG TO 72 DEG	0.50
1511102854	MAINTENANCE ODW PLUMBING CLOG	MAG HALL M'S R/R 35 TOILET CLOGGED	MAG HALL M'S R/R 35	11/17/2015	UNCLOGGED WITH PLUNGER	0.50
1511102855	MAINTENANCE ODW INT. LIGHTING	103F LIGHTS OUT	103F	11/17/2015	REPLACED LAMPS	0.50
1511102892	MAINTENANCE ODW BLDG/EQUIP. REP	RM 102 NOTIFIER PC SCREEN SHOWS "SYSTEM DISK ERROR." HARD DRIVE IS FAILING. C4-001-01	RM 102	11/18/2015	PURCHASED NEW HARD DRIVE FROM MICRO CENTER AND REPLACED OLD DRIVE. RESTORED DATA FROM BACK-UP IMAGE FROM EXTERNAL DRIVE. TESTED SYSTEM, OK. WESTERN "RED" HARD DRIVE COST \$69.99.	2.50
1511102893	MAINTENANCE ODW CLOCKS	MAG HALL LOBBY CLOCK IS ONE HOUR OFF	MAG HALL LOBBY	11/18/2015	RESET CLOCK. 11-20-15: CLOCK DISPLAYING CORRECT TIME. COMPLAINT FROM GUARD WAS THAT HOUR-HAND WAS NOT LINED UP CORRECTLY. MOVED HOUR HAND TO PROPER ALIGNMENT.	0.75
1511102917	MAINTENANCE ODW LEAKS	LOCKER ROOM LEAKING FROM CEILING	LOCKER ROOM	11/19/2015	PLACED CATCH PANS IN LEAK LOCATIONS. REPLACED 16 TILES AND ONE SMOKE HEAD.	8.00
1511102918	MAINTENANCE ODW INT. LIGHTING	AREA 3 LENS COVER SAGGING NEAR POLE 4G	AREA 3	11/19/2015	REPAIRED COVER AND PUT BACK IN TRACK	0.50
1511102919	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 38 LAMP OUT IN HALL OUTSIDE RM 38	MAG HALL RM 38	11/19/2015	REPLACED LAMPS	0.50
1511102920	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	11/19/2015	REPLACED LAMPS	0.50
1511102933	MAINTENANCE ODW LEAKS	SOUTH OF POLE 7P THERE IS A LEAK	SOUTH OF POLE 7P	11/19/2015	REPACKED VALVE	1.00
1511102966	MAINTENANCE ODW INT. LIGHTING	CHILD CARE - TWO LIGHTS OUT IN MIDDLE OF KITCHEN	CHILD CARE	11/20/2015	REPLACED THREE FLOURESCENT TUBES	0.50
1511102967	MAINTENANCE ODW INT. LIGHTING	CHILD CARE LIGHT OUT IN THE CENTER OF DINING ROOM	CHILD CARE	11/20/2015	REPLACED THREE FLOURESCENT TUBES	0.50
1511102968	MAINTENANCE ODW INT. LIGHTING	CHILD CARE RM 130 LIGHTS OUT IN FIXTURE CLOSEST TO COURTYARD	CHILD CARE RM 130	11/20/2015	CHECKED AND ALL LIGHTS ARE OK	0.50
1511102969	MAINTENANCE ODW PLUMBING	CHILD CARE RM 130 ALL FAUCETS HAE LOW WATER PRESSURE AND SINK CLOSEST TO THE COURTYARD IS CLOGGED.	CHILD CARE RM 130	11/20/2015	CLEANED OUT THREE AERATORS AND THE SINK NOW DRAINS FINE	0.75
1511102970	MAINTENANCE ODW INT. LIGHTING	CHILD CARE RM 123 LIGHT OUT	CHILD CARE RM 123	11/20/2015	REPLACED TWO ROUND FLOURESCENT TUBES IN RESTROOM	0.50

1511102971	MAINTENANCE ODW INT. LIGHTING	CHILD CARE RM 110 THREE LIGHTS OUT BY CHILDREN'S SINK	CHILD CARE RM 110	11/20/2015	CHECKED LIGHTS IN RM 110. ALL OK. HOUSEKEEPING SAID WORK ORDER WAS SUPPOSED TO BE FOR RM 109. REPLACED 6 BULBS IN RM 109.	0.50
1511102972	MAINTENANCE ODW UTILITY WORK	CHILD CARE RM 123 LEG ON TABLE HAS FALLEN OFF AND NEEDS TO BE REATTACHED (CHILD CARE HAS THE TABLE LEG)	CHILD CARE RM 123	11/20/2015	CHILD CARE RM 128 - FIXED LIGHTED TABLE. HAD TO DISASSEMBLE TO FIX. OK.	0.75
1511102974	MAINTENANCE ODW CEILING TILE	B CANTEEN - STAINED TILES ABOVE 7-UP MACHINE, COKE MACHINE AND ENERGY MACHINE	B CANTEEN	11/20/2015	REPLACED CEILING TILES WITH NEW	0.50
1511102975	MAINTENANCE ODW CEILING TILE	AREA 12 - 1 STAINED TILE AT 5DD AND 3 STAINED TILES AT 6EE	AREA 12	11/20/2015	REPLACED CEILING TILES WITH NEWE	1.00
1511102976	MAINTENANCE ODW CEILING TILE	AREA 10 - 4P, 2 SAGGING TILES SOUTH OF BRICK WALL; 4O, 2 STAINED TILES SOUTH OF BRICK WALL	AREA 10	11/20/2015	SOUTH HALLWAY NORTH OF POLE 4N - REPLACED ONE SAGGING CEILING TILE. CUT 12" METAL CEILING GRID AND SECURED BOTH TILES IN PLACE. SOUTH HALLWAY NORTH OF POLE 4O - CUT AND REPLACED TWO CEILING TILES THAT WERE STAINED.	1.00
1511102977	MAINTENANCE ODW CEILING TILE	AREA 5 - 4N, T-BAR MISSING ALONG BRICK WALL; 4M, 2 STAINED TILES SOUTH OF BRICK WALL	AREA 5	11/20/2015	JIM EUBANK CHECKED AND THIS AREA HAS BEEN REPAIRED. LOOKS LIKE ODW 1511102976 TOOK CARE OF THE REPAIR.	0.00
1511102979	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	11/20/2015	RAN TOILET AUGER DOWN COMMODE TO UNCLOG.	0.50
1511102980	MAINTENANCE ODW INT. LIGHTING	AREA 3 POLE 5C LIGHTS OUT AND THERE IS A CRACKED LENS	AREA 3	11/20/2015	REPLACED LAMPS AND LENS COVER	0.50
1511102981	MAINTENANCE ODW PLUMBING	W'S R/R B302 TOILET #2 FLUSH HEAD LEAKING WATER	W'S R/R B302	11/20/2015	COULDN'T GET OLD FLUSH HEAD TO SEAL PROPERLY, REPLACED FLUSH HEAD.	0.50
1511102982	MAINTENANCE ODW UTILITY WORK	AREA 5 POLE 6O IS MISSING A CORNER PIECE OF COVE BASE	AREA 5	11/20/2015	11-19-15: MADE A CORNER PIECE. DUE TO PULLING OFF THE CORNER, I STUCK ONE SIDE ON. 11-20-15: STUCK THE OTHER SIDE ON. CHECKED A FEW HOURS LATER AND THE CORNER IS STILL ON POLE. 11/21/15 - REATTACHED COVE BASE AROUND 2330. CHECKED IT AT 0530, STILL ATTACHED.	1.25
1511103014	MAINTENANCE ODW CEILING TILE	RM 604 - EIGHT STAINED TILES (ONE AREA LOOKS WET)	RM 604	11/20/2015	REPLACED STAINED TILES AND SPOT COATED A COUPLE OF TILES. ON 11-24-15 (JW1) SCRUBBED DOWN GRID (IT HAD CAKED ON RUST WATER. IT CAME CLEAN.) (MR) REPLACED TILE AROUND SMOKE HEAD.	2.75
1511103049	MAINTENANCE ODW CEILING TILE	POLE 5GG CEILING TILE IS STAINED	POLE 5GG	11/23/2015	REPLACED WITH NEW	0.50
1511103050	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT SOUTH OF POLE 4O AND 2 SAGGING COVERS	AREA 4	11/23/2015	REPLACED LAMPS. REPAIRED COVERS.	0.50
1511103053	MAINTENANCE ODW PLUMBING	RM 35 FAUCET WILL NOT STOP RUNNING	RM 35	11/23/2015	INSTALLED NEW SOLENOID AND BATTERIES	1.00
1511103061	MAINTENANCE ODW DOOR	SCAMPS SLIDING DOOR REMAINS OPEN ABOUT 3 INCHES	SCAMPS	11/23/2015	CHECKED ALL AREA 7 SLIDING DOORS. ALL OPERATING CORRECTLY.	1.00
1511103064	MAINTENANCE ODW INT. LIGHTING	CHILD CARE OUTSIDE RM 126 LIGHT IN HALLWAY NOT WORKING	CHILD CARE RM 126	11/23/2015	REPLACED EMERGENCY BALLAST	2.50
1511103063	MAINTENANCE ODW LEAKS	RM 604 - ACTIVE LEAK	RM 604	11/23/2015	11-24-15: (JW1 AND SH) PUT PLASTIC IN PALCE ABOVE CEILING TO CONTAIN LEAK. (MS) SEALED ROOF PENETRATION FOR DRY COOLER LINES. 11-25-15: (MM) SEALED ROOF PENETRATION FOR DRY COOLER LINES.	3.00
1511103074	MAINTENANCE ODW ELECTRICAL	A LOT - NO POWER TO FRONT HALF OF GATEHOUSE #1	GATEHOUSE #1	11/23/2015	RESET GFI UNDER TABLE	0.50
1511103078	MAINTENANCE ODW INT. LIGHTING	POLE 4K LIGHTS OUT	POLE 4K	11/24/2015	REPLACED LAMPS	0.50
1511103079	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 TOILET #1 CLOGGED	W'S R/R B302	11/24/2015	UNCLOGGED WITH PLUNGER	0.50
1511103083	MAINTENANCE ODW ELECTRICAL	DOCK DOORBELL IS STUCK IN THE "ON" FUNCTION	DOCK	11/24/2015	REPLACED DOORBELL SWITCH ON OUTSIDE DOCK DOOR	1.00
1511103095	MAINTENANCE ODW TEMPERATURE HOT	RM 7 - OLD CREDIT UNION TOO HOT	RM 7	11/24/2015	ADJUSTED THREE THERMOSTATS TO 70 DEG	0.50
1511103099	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 TOILET #1 CLOGGED	W'S R/R B302	11/24/2015	PLUNGED TOILET NUMEROUS TIMES. OK. NOTIFIED HOUSEKEEPING THAT FLOOR NEEDS MOPPED.	0.50
1511103100	MAINTENANCE ODW FLOOR TILE	CHILD CARE INFANT ROOM BY MAIN DOOR A COUPLE OF FLOOR TILES ARE STICKING LOOSE	CHILD CARE	11/24/2015	REPLACED 2 TILES IN HALLWAY NEAR INFANT ROOM. COULD NOT LOCATE ANY OTHER LOOSE TILES IN INFANT ROOM.	0.50
1511103113	MAINTENANCE ODW WATER FOUNTAIN	CHILD CARE DRINKING FOUNTAIN NEEDS TO BE WINTERIZED	CHILD CARE	11/25/2015	DISCONNECTED POWER, DISCONNECTED DRAIN AND SUPPLY LINES, DRAINED TANK.	1.00
1511103130	MAINTENANCE ODW DOOR	W'S R/R 1003 STALL DOOR #1 IS FALLING OFF HINGE	W'S R/R 1003	11/25/2015	REPLACED WITH PIANO STYLE SPRING HINGE	1.00
1511103131	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	11/25/2015	REPLACED LIGHT BULBS	0.50
1511103163	MAINTENANCE ODW ELECTRICAL	CHILD CARE GARBAGE DISPOSAL IS NOT WORKING	CHILD CARE	11/25/2015	RESET. OVER LOAD.	0.50
1511103191	MAINTENANCE ODW INT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	11/30/2015	REPLACED LIGHT BULBS AND VACUUMED LIGHT FIXTURES	0.50
1511103192	MAINTENANCE ODW INT. LIGHTING	RM 700H OVERHEAD LIGHTS OUT	RM 700H	11/30/2015	REPLACED LIGHT BULBS	0.50
1511103193	MAINTENANCE ODW INT. LIGHTING	RM 903 OVERHEAD LIGHTS OUT	RM 903	11/30/2015	REPLACED LIGHT BULBS	0.50
1511103194	MAINTENANCE ODW INT. LIGHTING	RM 803 OVERHEAD LIGHTS OUT	RM 803	11/30/2015	REPLACED LIGHT BULBS	0.50
1511103195	MAINTENANCE ODW INT. LIGHTING	AREA 6 LAMPS OUT	AREA 6	11/30/2015	REPLACED LAMPS	0.75
1511103196	MAINTENANCE ODW INT. LIGHTING	BOILER RM LIGHTS OUT	BOILER RM	11/30/2015	REPLACED LAMPS	1.00
1511103197	MAINTENANCE ODW INT. LIGHTING	AREA 3 BALLAST AND LIGHTS OUT SOUTH OF POLE 5H	AREA 3	11/30/2015	REPLACED BALLAST AND LAMPS	0.00
1511103198	MAINTENANCE ODW INT. LIGHTING	AREA 12 POLE 8JJ OVERHEAD FLOURESCENT LIGHTS ARE OUT	POLE 8JJ	11/30/2015	REPLACED BALLAST AND LAMPS	0.50

1511103225	MAINTENANCE ODW PLUMBING	COURTYARD CAFE COLD WATER FAUCET (WHERE THEY WASH THEIR HANDS) IS NOT PRODUCING WATER	COURTYARD CAFE	11/30/2015	REPLACED RIGHT-HAND VALVE ON FAUCET. (CRANE DIALESE STEM 2 FOR A COST OF \$18.00.)	0.50
1512102034	MAINTENANCE ODW TEMPERATURE HOT	RM 17 TOO HOT	RM 17	12/1/2015	BOILER AND HEATING WATER SYSTEM JUST OFF-LINE AT TIME OF CALL. SPACE WILL BEGIN TO COOL DOWN IMMEDIATELY. WILL CHECK AGAIN WHEN SYSTEM IS BACK ON-LINE.	0.50
1512102035	MAINTENANCE ODW PLUMBING	W'S R/R 600 SINK #7 WATER WILL NOT SHUT OFF	W'S R/R 600	12/1/2015	REPLACED SOLENOID	0.50
1512102038	MAINTENANCE ODW PLUMBING	W'S R/R 600 TOILET #4 WILL NOT FLUSH	W'S R/R 600	12/1/2015	REPLACED FLUSH HEAD. BATTERIES OK.	0.50
1512102096	MAINTENANCE ODW CEILING TILE	POLE 6HH STAINED TILE	POLE 6HH	12/2/2015	REPLACED TWO STAINED CEILING TILES (ONE ON NORTH SIDE OF POLE 6HH AND ONE ON SOUTH SIDE)	0.50
1512102097	MAINTENANCE ODW LEAKS	SATELLITE CANTEEN - LEAK ABOVE 7-UP MACHINE	SATELLITE CANTEEN	12/2/2015	REPLACED CEILING TILE. STAIN WAS DRY AND COULD NOT FIND AN ACTIVE LEAK.	0.50
1512102098	MAINTENANCE ODW INT. LIGHTING	COMMAND CENTER LIGHTS OUT IN BATHROOM	COMMAND CENTER	12/2/2015	REPLACED LAMPS	0.50
1512102110	MAINTENANCE ODW NOISE	AREA 5 POLE 6P FAULTY CO2 SENSOR	POLE 6P	12/2/2015	REPLACED FAULTY CO2 SENSOR AND CHECKED FOR PROPER OPERATION. OK. JOHNSON CONTROLS CO2 SENSOR, WALL MOUNT \$278.45.	1.00
1512102111	MAINTENANCE ODW INT. LIGHTING	AREA 3 LENS COVER FELL AND BROKE SE CORNER OF POLE 4K	AREA 3	12/2/2015	REPLACED COVER	0.50
1512102116	MAINTENANCE ODW DOOR	AREA 14 - B313 PIECES OF DOOR ARE FALLING OFF AND LANDING ON EMPLOYEES	AREA 14 - B313	12/2/2015	A BOLT AND WASHER FELL OUT OF DOOR CLOSURE LINKAGE (WEST DOOR ON THE NORTH SIDE OF ROOM). REPLACED BOLT AND WASHER.	0.50
1512102322	MAINTENANCE ODW INT. LIGHTING	MAG HALL M'S R/R 4 LIGHTS OUT OVER SINK AND TOILET	MAG HALL M'S R/R 4	12/3/2015	REPLACED LAMPS	0.50
1512102323	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT IN FIXTURES SOUTH OF POLE 5O	AREA 4	12/3/2015	REPLACED LAMPS	0.50
1512102324	MAINTENANCE ODW INT. LIGHTING	AREA 4 POLE 4O KARLA REQUESTS LAMPS BE REMOVED OVER HER CUBICLE	AREA 4 POLE 4O	12/3/2015	REMOVED 6 LAMPS AND MARKED FIXTURES WITH RED DOTS.	0.50
1512102325	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #7 CLOGGED	W'S R/R B211	12/3/2015	UNCLOGGED THE COMMODE	0.50
1512102328	MAINTENANCE ODW GATE/FENCE	GATE #5 ENTRANCE GATE WILL NOT CLOSE	GATE #5	12/3/2015	12-2-15: (AG) MANUALLY CLOSED GATE FOR THE NIGHT. 12-3-15: (JM) HAD SECURITY CYCLE GATE TWICE, OPERATING CORRECTLY. THE CAUSE WAS OPERATOR ERROR ON THE NIGHT SHIFT.	1.00
1512102392	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET #7 WILL NOT FLUSH	W'S R/R A1003	12/4/2015	FLUSHED ALL 23 TOILETS. ALL FUNCTIONING NORMALLY.	0.50
1512102394	MAINTENANCE ODW INT. LIGHTING	RM 1004 OVERHEAD LIGHTS OUT	RM 1004	12/4/2015	REPLACED TWO LIGHT BULBS	0.50
1512102395	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST 3 LENS COVERS SAGGING NEAR POLE 4L	AREA 3 EAST	12/4/2015	REPAIRED LOOSE COVERS	0.50
1512102417	MAINTENANCE ODW WATER FOUNTAIN	CHILD CARE RM 130 - SINK #2 WATER WILL NOT STOP RUNNING	CHILD CARE RM 130	12/4/2015	REPLACED CARTRIDGE. OK. COST: \$38.00.	2.00
1512102439	MAINTENANCE ODW DOOR	RM 201 - RESTROOM DOOR CAN BE LOCKED FROM THE INSIDE, HOWEVER, WHEN YOU LOCK IT FROM THE OUTSIDE WITH A KEY, YOU CANNOT REMOVE THE KEY UNLESS YOU UNLOCK THE DOOR.	RM 201	12/7/2015	REMOVED RETAINER RING AND THREADED LOCK FULLY IN. OK.	0.50
1512102450	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST FIXTURE OUT NW CORNER OF POLE 4H	AREA 3 EAST	12/7/2015	REPLACED BALLAST AND LAMPS.	1.00
1512102465	MAINTENANCE ODW INT. LIGHTING	RM 21 HAS A LIGHT THAT IS FLICKERING	RM 21	12/7/2015	REPLACED BOTH LAMPS	0.50
1512102474	MAINTENANCE ODW ELECTRICAL	RM 200F UNIT 15-2 UV LIGHTS DO NOT WORK	RM 200F	12/7/2015	REPLACED BALLAST AND LAMPS	6.00
1512102477	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #5 CLOGGED	W'S R/R B211	12/7/2015	PLUNGED TOILET, FLUSHED, OK.	0.50
1512102486	MAINTENANCE ODW INT. LIGHTING	POLE 8P RM 603 LIGHTS OUT	POLE 8P RM 603	12/8/2015	REPLACED LIGHTS AND BALLAST	1.00
1512102505	MAINTENANCE ODW INT. LIGHTING	RM 24 DIRECTOR'S OFFICE LIGHT FLICKERING	RM 24 DIRECTOR'S OFFICE	12/8/2015	REPLACED BULB. OK.	1.00
1512102548	MAINTENANCE ODW INT. LIGHTING	AREA 3 WEST LIGHTS OUT NEAR POLE 3C	AREA 3 WEST	12/9/2015	REPLACED LAMPS	0.50
1512102549	MAINTENANCE ODW INT. LIGHTING	AREA 11 LAMPS OUT SOUTH OF POLE 4S	AREA 11	12/9/2015	REPLACED LAMPS	0.50
1512102550	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LIGHTS OUT SOUTH OF POLE 5N	AREA 4 WEST	12/9/2015	REPLACED LAMPS AND BALLAST	0.50
1512102551	MAINTENANCE ODW WATER FOUNTAIN	WATER FOUNTAIN BY ROOM 409 NOT WORKING	RM 49	12/9/2015	FOUND STREAM HEIGHT OUT OF BUBBLER VERY ERRATIC. ADJUSTED REFRIGERATION CYCLE TO WARMER. OK.	0.75
1512102558	MAINTENANCE ODW STRUCTURAL PROB	AHU 15-2 CORROSION CONTROL	AHU 20-2	12/9/2015	SCRAPED RUST AND OLD INSULATION ON FLOOR (FAN SIDE) AND PAINTED.	7.00
1512102590	MAINTENANCE ODW FLOOR TILE	AREA 10 BETWEEN POLES 6T AND 7T RAISED FLOOR TILES	AREA 10	12/10/2015	REGLUED FLOOR TILE AND SWAPPED IT OUT WITH ONE IN A LOW TRAFFIC AREA (UNDER DESK)	0.50
1512102591	MAINTENANCE ODW INT. LIGHTING	MDF LIGHTS OUT	MDF	12/10/2015	REPLACED BALLAST AND LAMPS	1.00
1512102592	MAINTENANCE ODW INT. LIGHTING	B BLDG POLE 7EE LIGHT OUT	B BLDG POLE 7EE	12/10/2015	REPLACED BALLAST	1.00
1512102607	MAINTENANCE ODW PLUMBING	M'S R/R 1005 SINK #1 NOT PRODUCING WATER FROM FAUCET	M'S R/R 1005	12/10/2015	REPLACED BATTERIES	0.50
1512102608	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #13 CLOGGED	W'S R/R B211	12/10/2015	PLUNGED TOILET, OK	0.50
1512102610	MAINTENANCE ODW DOOR	SOUTH DOOR AT DOOR B2 IS NOT CLOSING	DOOR B2	12/10/2015	RAISED DOOR. CLOSES PROPERLY.	1.00
1512102620	MAINTENANCE ODW ELECTRICAL	AREA 5 RAISED FLOOR OUTLET FALLING BELOW RAISED FLOOR IN MIDDLE BETWEEN POLES 6P AND 7P	AREA 5	12/11/2015	REPLACED TILE WITH A PRE-CUT TILE	1.00
1512102621	MAINTENANCE ODW INT. LIGHTING	RM B300 LEFTLIGHT FIXTURE IS OUT	RM B300	12/11/2015	REPLACED LIGHT BULBS	0.50
1512102622	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	12/11/2015	REPLACED BULBS AND VACUUMED FIVE LIGHT LENSES	1.00
1512102623	MAINTENANCE ODW INT. LIGHTING	CHILD CARE RM 110 CIRCULAR LIGHT COVER FALLING OFF IN LEFT BATHROOM	CHILD CARE RM 110	12/11/2015	CORRECTLY REINSTALLED LIGHT COVER	0.50
1512102631	MAINTENANCE ODW INT. LIGHTING	RM 33 CEILING LIGHTS OUT	RM 33	12/11/2015	REPLACED BALLASTS AND LAMPS	2.00
1512102659	MAINTENANCE ODW ELECTRICAL	AREA 13 HAS A SMOKEHEAD IN TROUBLE	AREA 13	12/14/2015	REMOVED AND CLEANED SMOKEHEAD BY POLE 5EE, RESET OK.	0.50

1512102660	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET #18 WILL NOT FLUSH	W'S R/R A1003	12/14/2015	CHECKED BATTERIES. OK. FLUSH HEAD WAS ERRATIC. REPLACED WITH NEW FLUSH HEAD.	0.50
1512102662	MAINTENANCE ODW INT. LIGHTING	AREA 1 LAMPS OUT	AREA 1	12/14/2015	REPLACED LAMPS	1.00
1512102686	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 CLOGGED	M'S R/R B309	12/14/2015	CLEARED CLOG WITH PLUNGER	0.50
1512102687	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R B309 STALL #4 TOILET PAPER DISPENSER BROKEN	M'S R/R B309	12/14/2015	REPLACED TOILET PAPER DISPENSER. COST: \$40.	0.50
1512102688	MAINTENANCE ODW RESTROOM FIXTURE	MAG HALL W'S R/R A34 #3 TOILET DISPENSER WILL NOT STAY LATCHED	W'S R/R A34	12/14/2015	REPLACED TOILET PAPER DISPENSER	1.00
1512102745	MAINTENANCE ODW PLUMBING CLOG	MS' R/R 1005 URINAL AND TOILET #1 CLOGGED	M'S R/R 1005	12/15/2015	UNCLOGGED URINAL AND TOILET	0.50
1512102746	MAINTENANCE ODW ELECTRICAL	DOCK - #1 AIR CURTAIN THERMOMETER IS FALLING APART	DOCK	12/15/2015	12-5-15: THERMOSTAT IS BROKEN. HAD TO ORDER A NEW ONE. 12-21-15: INSTALLED NEW THERMOSTAT. COST \$34.00.	1.00
1512102754	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W'S R/R A34 TOILET #1 CLOGGED	MAG HALL W'S R/R A34	12/16/2015	UNCLOGGED WITH PLUNGER	0.50
1512102755	MAINTENANCE ODW INT. LIGHTING	RM 401 JANITOR'S CLOSET - LIGHT OUT	RM 401	12/16/2015	REPLACED LAMP	0.50
1512102820	MAINTENANCE ODW LEAKS	(NEAR) RM 813 - CEILING LEAK	RM 813	12/18/2015	BOOSTER PUMP ON AHU 18-8 LEAKING AROUND SEALS AND GASKET. ISOLATED PUMP. REMOVED PUMP, DISASSEMBLED PUMP, CLEANED HOUSING AND ORDERED REPAIR SHAFT KIT. REBUILT PUMP AND REINSTALLED. CHECKED FOR LEAKS, PUMP IS OKAY. SHAFT REPAIR KIT (SHAFT, SEALS AND BEARINGS): \$110.00	14.00
1512102822	MAINTENANCE ODW INT. LIGHTING	AREA 3 LOOSE LENS COVER AT POLE 5G	AREA 3	12/18/2015	REPAIRED LENS	0.50
1512102823	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT NEAR POLE 4D	AREA 3	12/18/2015	REPLACED LAMPS	0.50
1512102824	MAINTENANCE ODW INT. LIGHTING	SCAMPS LIGHTS OUT	SCAMPS	12/18/2015	REPLACED LIGHT BULBS	0.50
1512102825	MAINTENANCE ODW INT. LIGHTING	AREA 8 LIGHTS OUT ABOVE MEZZANINE	AREA 8	12/18/2015	REPLACED LIGHT BULBS	0.50
1512102826	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A309 HC BUTTON ON OUTSIDE OF DOOR DOES NOT WORK	W'S R/R A309	12/18/2015	REPLACED BATTERY	0.50
1512102827	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 TOILET #5 CLOGGED	W'S R/R 1003	12/18/2015	UNCLOGGED WITH PLUNGER	0.50
1512102828	MAINTENANCE ODW INT. LIGHTING	OFFICE 300D ENTITY DEPARTMENT NEAR POLE 4F LIGHTS OUT	POLE 4F	12/18/2015	REPLACED LIGHT	0.50
1512102829	MAINTENANCE ODW FLOOR TILE	B313 - INSIDE MANAGER'S OFFICE CUBICLE (CATHY CROSIER) THERE IS A RAISED TILE	B313	12/18/2015	ADJUSTED SUPPORT STANDS TO LEVEL TILE	1.00
1512102831	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP TOILET CLOGGED	W'S R/R A34	12/18/2015	UNCLOGGED WITH PLUNGER	0.00
1512102832	MAINTENANCE ODW INT. LIGHTING	MAG HALL W'S R/R A34 LIGHTS OUT OVER COUNTER (NOT SINK AREA)	MAG HALL W'S R/R A34	12/18/2015	REPLACED LAMPS	0.50
1512102833	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 TOILET CLOGGED	W'S R/R A404	12/18/2015	UNCLOGGED WITH PLUNGER	0.50
1512102852	MAINTENANCE ODW INT. LIGHTING	PER FOH INSPECTION, A CANTEEN NEEDS SHATTER SHIELD Globes INSTALLED on a total of 5 lights in BOTH WALK-IN REFRIGERATORS		12/21/2015	INSTALLED 5 GLASS SHATTER SHIELDS IN 3 WALK-IN BOXES	0.50
1512102853	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 TOILET CLOGGED		12/21/2015	PLUNGED TOILET, FLUSHED, OK.	0.50
1512102863	MAINTENANCE ODW EXT. LIGHTING	RM 309 OVERHEAD LIGHTS OUT		12/21/2015	REPLACED LIGHT BULBS	0.50
1512102862	MAINTENANCE ODW INT. LIGHTING	W'S R/R 1003 LIGHTS FLICKERING		12/21/2015	REPLACED BULB	0.50
1512102861	MAINTENANCE ODW DOOR	RC 3 AUTO DOOR WILL NOT OPEN		12/21/2015	PUSHED BREAK AWAY DOOR BACK ON TRACK	0.50
1512102860	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHT LENSES NEED CLEANED		12/21/2015	VACUUMED ALL LIGHT LENSES	0.00
1512102859	MAINTENANCE ODW INT. LIGHTING	SATELLINE CANTEEN BALLAST OUT IN SKYLIGHT. MISC. LIGHTS BURNED OUT. LIGHT LENS HAS A CRACK IN IT.		12/21/2015	REPLACED BALLAST AND LAMPS. REPLACED LIGHT LENS.	2.50
1512102912	MAINTENANCE ODW INT. LIGHTING	103D LAMPS OUT IN FIXTURE BY TOILET		12/23/2015	REPLACED LAMPS	0.50
1512102920	MAINTENANCE ODW PLUMBING	MAG HALL R/R A5 TOILET #3 CONSTANTING FLUSHING	MAG HALL R/R A5	12/23/2015	REPLACED INSERT WITH VALVE REPAIR KIT	0.50
1512102990	MAINTENANCE ODW KITCHEN EQUIP	AREA 2 (POP) WALK-IN BOX HAS NO A LOW TEMP ALARM		12/23/2015	AG: ADJUSTED THERMOSTAT UP 3 DEG. JM: REPLACED FAULTY THERMOSTAT AND TESTED FOR PROPER OPERATION. OK. REMOTE BULB T-STAT: \$68.00.	2.00
1512102989	MAINTENANCE ODW NOISE	BOILER RM AIR DRYER UNIT CYCLED OFF		12/23/2015	REPLACED FAULTY CONDENSER FAN MOTOR WITH MOTOR FROM OLD WATER COOLER. TESTED FOR PROPER OPERATION. OK.	1.00
1512102988	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT OVER RAIL SOUTH OF POLE 4G. TWO LOOSE LENS COVERS.		12/23/2015	REPLACED LAMPS. REPAIRED LOOSE COVERS.	1.00
1512102987	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 TOILET #1 IS CLOGGED		12/23/2015	UNCLOGGED THE COMMUNE.	0.50
1512102986	MAINTENANCE ODW TEMPERATURE HOT	MAG HALL RM 49 TOO HOT		12/23/2015	SET TEMP FROM 72 DEG TO 70 DEG	0.50
1512103006	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 TOILET #23 CLOGGED		12/28/2015	REMOVED LARGE AMOUNT OF TP AND PLUNGED	0.50
1512103005	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 TOILET #1 CLOGGED		12/28/2015	CHECKED TOILETS AND URINALS. NO CLOGS. CHECKED TOILETS IN 811, NO CLOGS.	0.50
1512103004	MAINTENANCE ODW INT. LIGHTING	AREA 8 LIGHTS OUT IN HALLWAY BY HOUSEKEEPING		12/28/2015	REPLACED LIGHTS	0.75
1512103003	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT BY POLES 4B AND 4D		12/28/2015	REPLACED LAMPS	1.00
1512103008	MAINTENANCE ODW FLOOR TILE	CHILD CARE RM 128 THREE FLOOR TILES ARE LOOSE		12/28/2015	REPAIRED FLOOR TILES IN RM 128	1.00
1512103007	MAINTENANCE ODW INT. LIGHTING	W'S R/R 600 LIGHTS OUT		12/28/2015	REPLACED LAMPS	0.50
1512103012	MAINTENANCE ODW INT. LIGHTING	RM 604 LIGHTS OUT		12/28/2015	REPLACED LAMPS	0.50
1512103011	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT		12/28/2015	REPLACED LAMPS	0.75
1512103010	MAINTENANCE ODW RESTROOM FIXTURE	MAG HALL W'S R/R A5 TOILET SEAT BROKEN		12/28/2015	REPLACED TOILET SEAT	0.50

1512103013	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W'S R/R A5 TOILET SEAT BROKEN		12/28/2015	THIS IS A DUPLICATE TICKET. NO ACTION TAKEN.	0.00
1512103016	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 TOILETS #14 AND #15		12/28/2015	PLUNGED BOTH TOILETS. FLUSHED. OK.	0.50
1512103015	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R B309 HANDICAP STALL NEEDS BATTERIES		12/28/2015	REPLACED BATTERIES	0.50
1512103037	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W'S R/R 34 TOILET #1 CLOGGED		12/29/2015	REMOVED A LARGE AMOUNT OF TOILET PAPER, PLUNGED, FLUSHED, OK.	0.50
1512103036	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 TOILET #9 CLOGGED	W'S R/R B302	12/29/2015	UNCLOGGED WITH PLUNGER	0.50
1512103034	MAINTENANCE ODW INT. LIGHTING	AREA 14 B317 BALLAST IS BAD		12/29/2015	SH: REPLACED BALLAST. JW: REPLACED BALLAST AND REPLACED LAMPS.	2.75
1512103033	MAINTENANCE ODW INT. LIGHTING	BALLAST IS BAD AND LIGHTS ARE OUT		12/29/2015	REPLACED BALLAST AND BULBS	1.00
1512103066	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #7 AND #14 CLOGGED		12/29/2015	UNCLOGGED BOTH TOILETS. OK.	0.50
1512103065	MAINTENANCE ODW LEAKS	RM 30 POSSIBLE ROOF LEAK		12/29/2015	12-28-15: INSTALLED DRIP PAN AND BUCKET. CLEARED ROOF DRAINS. 12-29-15: REPLACED TILE.	2.50
1512103081	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT		12/30/2015	REPLACED BULBS	0.50
1512103080	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 #14 AND #15 CLOGGED		12/30/2015	PLUNGED BOTH TOILETS, FLUSHED, OK	0.50
1512103079	MAINTENANCE ODW DOOR	RM 1003 INSIDE DOOR BUTTON FALLING OFF OF CABINET		12/30/2015	ADJUSTED AND TIGHTENED DOWN SCREWS THAT HOLD DOOR BUTTON INTO PLACE	0.50
1512103082	MAINTENANCE ODW DOOR	RM 1005 DOOR RUBBING AGAINST DOOR FRAME OPPOSITE SIDE FROM TOP HINGE		12/30/2015	TIGHTENED ALL HINGE SCREWS.	0.50
2014123217	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 128 WATER DEFLECTOR AT SECOND CHILD SINK IS BROKEN	CHILDCARE RM 128	12/19/2014	NEED TO ORDER BUBBLER. 1/14/15: REPLACED ADAPTER, ORIFICE ASSEMBLY AND FLEXIGUARD ON BOTH SINKS.	2.00
2015011982	MAINTENANCE ODW ELECTRICAL	POLE 6N ELECTRICAL OUTLET NEEDS CHECKED	POLE 6N	1/5/2015	REPAIRED FLOOR BOX	0.50
2015012013	MAINTENANCE ODW DOOR	DOOR EAST SIDE OF 603 IS NOT SHUTTING	DOOR EAST SIDE OF 603	1/5/2015	LEFT HAND DOOR HAD JUMPED A FEW TEETH ON THE DRIVE BELT. READJUSTED DOOR AND CHECKED FOR PROPER OPERATION. OK.	1.00
2015012014	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET CLOGGED	M'S R/R B309	1/5/2015	CLEARED CLOG WITH PLUNGER	0.50
2015012015	MAINTENANCE ODW TEMPERATURE COLD	BADGE ROOM 200 COLD AIR IS COMING IN AROUND THE WINDOW	BADGE ROOM 200	1/5/2015	CHECKED ALL WINDOWS FOR LEAKAGE. COULD NOT FIND ANY LEAKING COLD AIR.	0.50
2015012048	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A305 TOILET #8 CLOGGED	W'S R/R A306	1/5/2015	PLUNGED THE COMMODORE	0.50
2015012049	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 HAS A BROKEN FLOOR TILE	CHILDCARE RM 128	1/5/2015	CLEANED AREA AND REPLACED FLOOR TILE	0.50
2015012050	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 WEST SIDE GATE WILL NOT CLOSE ALL THE WAY	GATEHOUSE 2	1/5/2015	PULLED CHAIN AND PUSHED GATE LAST FOUR INCHES TO CLOSE	0.50
2015012066	MAINTENANCE ODW INT. LIGHTING	ROOM B 200A FOUR CEILING LIGHTS OUT.	ROOM B 200A	1/6/2015	TWO BALLASTS WERE BAD. REPLACED WITH NEW.	2.00
2015012078	MAINTENANCE ODW DOOR	CANTEEN SWINGING DOOR NEEDS SCREWS TIGHTENED UP	CANTEEN	1/6/2015	TIGHTENED SCREWS ON HINGE	0.50
2015012081	MAINTENANCE ODW PLUMBING	W'S R/R A700H TOILET WILL NOT FLUSH	W'S R/R A700H	1/6/2015	UNLOCKED STALL DOOR. REMOVED LARGE AMOUNT OF SEAT COVERS FROM TOILET. FLUSHED. NO PROBLEM.	0.50
2015012083	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 ALL SINKS BACKED UP	M'S R/R A810	1/6/2015	SNAKED MAIN DRAIN. OK.	1.00
2015012103	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL #2 STOPPED UP	M'S R/R A1005	1/6/2015	ALL TOILETS ARE PROPERLY WORKING.	0.50
2015012139	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP COMMODORE OVERFLOWING	W'S R/R A34	1/7/2015	REPAIRED COMMODORE	0.50
2015012140	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 COMMODORE CLOGGED	M'S R/R A308	1/7/2015	UNCLOGGED THE COMMODORE	0.50
2015012141	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 COMMODORE IS CLOGGED	W'S R/R A5	1/7/2015	UNCLOGGED THE COMMODORE	0.50
2015012142	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 COMMODORE #2 IS CLOGGED	M'S R/R B309	1/7/2015	UNCLOGGED THE COMMODORE	0.50
2015012143	MAINTENANCE ODW GATE/FENCE	GATE 3 WILL NOT OPEN	GATE 3	1/7/2015	PRESSED RESET BUTTON, OPERATED GATE AND WORKING NOW.	0.50
2015012145	MAINTENANCE ODW DOOR	DOOR RC6A CLOSING SLOWLY	DOOR RC6A	1/7/2015	RESET DOOR. WORKING FINE.	0.50
2015012565	MAINTENANCE ODW WATER FOUNTAIN	RM 1005 DRINKING WATER FOUNTAIN DRAIN CLOGGED	RM 1005	1/8/2015	REMOVED SUBSTANCE THAT WAS POURED INTO TOP OF FOUNTAIN AND WAS BLOCKING DRAIN	0.50
2015012566	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 9 CORNER GUARD BROKEN AT CORNER OF DOOR 18 HALLWAY AND LOADING DOCK HALLWAY	AREA 9	1/8/2015	REPLACED CORNER GUARD ON RAILING	0.50
2015012595	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP TOILET CLOGGED	W'S R/R A34	1/8/2015	PLUNGED COMMODORE. FLUSHED. OK.	0.50
2015012596	MAINTENANCE ODW INT. LIGHTING	POLE 4P-5P LIGHT LENS HANGING	POLE 4P-5P	1/8/2015	LATCHED LENS INTO PLACE. OK.	0.50
2015012599	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 5 HEATER IN GUARD SHACK IS NOT WORKING	GATEHOUSE 5	1/8/2015	CHECKED HEATER AND IT WAS RUNNING GOOD. MAY OF HAD TROUBLE DUE TO THE EXTREME COLD WEATHER.	0.50
2015012630	MAINTENANCE ODW PLUMBING CLOG	W'S A5 TOILET CLOGGED AND WATER ON FLOOR	W'S A5	1/8/2015	PLUNGED TOILET. FLUSHED TWICE. OK.	0.50
2015012744	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET CLOGGED	M'S R/R A308	1/9/2015	CLEARED CLOG WITH PLUNGER	0.50
2015012751	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 CLOGGED	W'S R/R A306	1/9/2015	FLUSHED TOILET THREE TIMES. RUNNING FINE.	0.50
2015012755	MAINTENANCE ODW TEMPERATURE COLD	POLE 4M TOO COLD	POLE 4M	1/9/2015	RAISED UNIT SETPOINT FROM 73 TO 74.5. SPACE IS 73.5.	0.50
2015012757	MAINTENANCE ODW ELECTRICAL	AREA 7 POSSIBLE ELECTRICAL OUTLET PROBLEM FOR TINGLE TALBE #26	AREA 7	1/9/2015	CHECKED ALL FOUR ELECTRICAL OUTLETS IN FLOOR ELECTRICAL BOX THAT TINGLE TABLE #26 COULD PLUG INTO. ALL OK.	0.50
2015012782	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 #3 CLOGGED	W'S R/R A404	1/9/2015	PLUNGED TOILET NUMEROUS TIMES. FLUSHED NUMEROUS TIMES. OK.	0.50
2015012795	MAINTENANCE ODW BLDG/EQUIP. REP	B313 PUMP IS IN ALARM	B313	1/9/2015	1-8-15: HIGH WATER ALARM DUE TO PUMP FAILURE. PUMPED DOWN PIT. ORDERED PUMP AND A NEW FLOAT. 1-9-15: REPLACED FLOAT SWITCH AND SUMP PUMP. FILLED PIT AND LET LEAD/LAG CYCLE TWICE.	5.00
2015012806	MAINTENANCE ODW BLDG/EQUIP. REP	NEAR DOOR 21 W'S R/R A309 STALL #3 TOILET PAPER DISPENSER WILL NOT STAY CLOSED	W'S R/R A309	1/12/2015	REPLACED WITH A NEW DISPENSER	0.50
2015012807	MAINTENANCE ODW DOOR	W'S R/R 700H DOOR STUCK OPEN	W'S R/R 700H	1/12/2015	SET DIP SWITCHES ON INTERIOR PUSH BUTTON TO CORRECT POSITION. DOOR OPENER IS NOW OPERATING CORRECTLY.	0.50

2015012808	MAINTENANCE ODW BLDG/EQUIP. REP	M/S R/R 700I TOILET PAPER DISPENSER BROKEN	M/S R/R 700I	1/12/2015	REPLACED BROKEN TOILET PAPER DISPENSER	0.50
2015012809	MAINTENANCE ODW PLUMBING	M/S R/R 308 HAS NO WATER	M/S R/R 308	1/12/2015	URINAL AND CLOSET HAVE WATER. THE SUPPLY TO THE SINK WAS SHUT OFF. TURNED WATER ON AND FOUND A LEAK IN THE SOLENOID. REPLACED SOLENOID. OK.	1.00
2015012810	MAINTENANCE ODW INT. LIGHTING	ACCOUNTING B BLDG LIGHT NEEDS REPLACED	ACCOUNTING B BLDG	1/12/2015	BALLAST IS BAD. REPLACED WITH NEW.	1.00
2015012813	MAINTENANCE ODW ROOF LEAK	CHILDCARE INFANT ROOM CEILING HAS A LEAK	CHILDCARE INFANT ROOM	1/12/2015	MM/MR: TEMPORARILY REPAIRED. JW/SH: PUT CEILING IN. JIM BLACK & SONS: ROOF REPAIRED. COST OF REPAIR UNKNOWN AT THIS TIME. DF/SH/MM/MR/MS: CLEANED UP. DF: PURCHASED ROOF MATERIALS \$64.68 AND \$81.56.	11.00
2015012815	MAINTENANCE ODW BLDG/EQUIP. REP	RM 126 @ 2 FEET OF BASEBOARD IS LOOSE AND NEEDS REATTACHED	RM 126	1/12/2015	REATTACHED COVEBASE WITH SILICONE	0.50
2015012832	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 #2 STOPPED UP	W'S R/R A5	1/12/2015	#2 PLUNGED AND FLUSHED. OK.	0.50
2015012833	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 #4 CLOGGED	W'S R/R A404	1/12/2015	#3 PLUNGED AND FLUSHED. OK.	0.50
2015012834	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #3 CLOGGED; SINK #2 DOESN'T WORK; ANOTHER SINK FURTHER DOWN BARELY WORKS.	W'S R/R A306	1/12/2015	MM: PLUNGED AND FLUSHED. OK. TD: REPLACED SOLENOID AND FOUR CELL BATTERIES AT SINK #2. REPLACED FOUR CELL BATTERIES AT SINK #5.	1.50
2015012835	MAINTENANCE ODW INT. LIGHTING	W'S R/R A306 LIGHTS OUT IN ENTRANCE	W'S R/R A306	1/12/2015	REPLACED THREE LAMPS	0.50
2015012846	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 130 LIGHT OUT	CHILDCARE RM 130	1/12/2015	RERPLACED BULB	0.50
2015012847	MAINTENANCE ODW FLOOR TILE	RESTROOM HALL HAS A LOOSE FLOOR TILE	RESTROOM HALL	1/12/2015	REGLUED FLOOR TILE BACK INTO PLACE	0.50
2015012848	MAINTENANCE ODW BLDG/EQUIP. REP	MECHANIC'S GARAGE ANCHOR BOLTS NEED INSTALLED FOR THE STEEL SHELVES	MECHANIC'S GARAGE	1/12/2015	INSTALLED FOUR ANCHOR BOLTS (THREE ALONG THE BACKSIDE AND ONE IN THE FRONT CENTER).	0.50
2015012849	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST HAS A BROKEN LENS COVER	AREA 3 EAST	1/12/2015	REPLACED BROKEN COVER	0.50
2015012883	MAINTENANCE ODW CEILING TILE	DOOR B1 CEILING TILE HAS A BROWN SPOT AND WHAT APPEARS TO BE A "BUBBLE"	DOOR B1	1/13/2015	1-13-15: REMOVED TLE AND INSTALLED DRIP PAN. 1-16-15: CHECKED ROOF. FOUND SEVERAL (6) SUSPECT SEAMS AND REPAIRED WITH PATCHES. 1-16-15: CUT ANDR EPLACED TWO CEILING TILES.	5.00
2015012905	MAINTENANCE ODW PLUMBING CLOG	M/S R/R B309 TWO TOILETS CLOGGED	M/S R/R B309	1/13/2015	FLUSHED BOTH COMMODES. WORKING PROPERLY.	0.50
2015012915	MAINTENANCE ODW ROOF LEAK	AREA 5 BETWEEN POLES 6P/7P HAS A WET TILE	AREA 5 POLES 6P/7P	1/13/2015	REMOVED DRAIN FLANGE. CLEANED AND RESEALED.	2.00
2015012946	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHT COVER ON SOUTHWEST SIDE OF POLE 8V IS CRACKED	AREA 9	1/14/2015	CUT AND REPLACED LIGHT COVER	1.00
2015012970	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 #2 TOILET CLOGGED	W'S R/R A5	1/14/2015	PLUNGED TOILET AND FLUSHED NUMEROUS TIMES. OK.	0.50
2015013011	MAINTENANCE ODW TEMPERATURE COLD	MSU TOO COLD	MSU	1/15/2015	SPACE TEMP 72.4 DEG. NO ACTION TAKEN.	0.50
2015013012	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHT FIXTURE AND LAMPS OUT	SATELLITE CANTEEN	1/15/2015	REPLACED BALLAST IN FIXTURE AND REPLACED LAMPS	1.25
2015013019	MAINTENANCE ODW DOOR	AREA 7 SWINGING DOORS INTO SCAMPS NEEDS DOORSTOPS TO KEEP DOORS OPEN	AREA 7	1/15/2015	LAI D TWO NEW RUBBER DOORSTOPS BESIDE SWINGING DOORS.PURCHASED DOORSSTOPS FOR A TOTAL OF \$14.97.	0.50
2015013023	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 #2 CLOGGED	W'S R/R A5	1/15/2015	HAD TO PLUNGE NUMEROUS TIMES. FLUSHED SEVERAL TIMES. OK.	0.50
2015013033	MAINTENANCE ODW INT. LIGHTING	B323 IDF ROOM EMERGENCY LIGHT OUT	B323	1/15/2015	CHANGED 2 BULBS. LIGHT WORKING FINE.	0.50
2015013037	MAINTENANCE ODW DOOR	B308 DOOR CLOSER (AT TOP OF DOOR) NEEDS REPAIRED. (IT'S MISSING A SCREW.)	B308	1/15/2015	REPLACED BRACKET ON DOORFRAME. REATTACHED ARM. CLOSER IS NOW WORKING.	0.75
2015013056	MAINTENANCE ODW BUILDING SIGNAGE	VENDOR SIGN AT A LOT BY COOLING TOWER - RESERVED VENDOR SIGN IS COMING LOOSE	FENCE A LOT BY COOLING TOWER	1/16/2015	REPLACED TOP TWO SCREWS ON LOOSE SIGN	0.50
2015013062	MAINTENANCE ODW DOOR	W'S A1003 DOOR HAS A BROKEN HINGE AND PIANO HINGE NEEDS PURCHASED AND INSTALLED	W'S A1003	1/16/2015	REPAIRED TOP HINGE	2.50
2015013064	MAINTENANCE ODW PLUMBING	W'S R/R A306 LAST TOILET WILL NOT FLUSH	W'S R/R A306	1/16/2015	FLUSHED ALL TOILETS 2X EACH. WORKING PROPERLY. NOTICED THIRD TOILET FROM THE END LEAKING AT SPUD GASKET. TIGHTENED. OK.	0.50
2015013114	MAINTENANCE ODW DOOR	#1 DOCK DOOR - SAFETY EDGE WIRE HAS PULLED LOOSE	#1 DOCK DOOR	1/20/2015	REATTACHED WIRE TO BUMP SWITCH AND CHECKED OPERATION. SWITCH IS FUNCTIONING PROPERLY.	0.75
2015013132	MAINTENANCE ODW PLUMBING CLOG	M/S R/R 308 TOILET CLOGGED	M/S R/R 308	1/20/2015	PLJUNGED TOILET. OK.	0.50
2015013154	MAINTENANCE ODW PLUMBING	W'S R/R B211 #9 WILL NOT FLUSH	W'S R/R B211	1/20/2015	REPLACED BATTERIES IN FLUSH HEAD	0.50
2015013155	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS BURNED OUT	AREA 1	1/20/2015	REPLACED LAMPS	0.50
2015013156	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	1/20/2015	REPLACED 24 LIGHT BULBS AND VACUUMED 6 LIGHT COVERS	1.25
2015013157	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 OVERHEAD LIGHTS OUT	W'S R/R A1003	1/20/2015	REPLACED 2 FLUORESCENT LIGHTS AND 2 COMPACT FLUORESCENT LIGHTS	0.50
2015013158	MAINTENANCE ODW INT. LIGHTING	LASER PRINT RM BALLAST IS BAD	LASER PRINT RM	1/20/2015	REPLACED BALLAST WITH NEW AND REPLACED LAMPS	1.00
2015013159	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 TWO FLOOR TILES ARE BROKEN	CHILDCARE RM 128	1/20/2015	REPLACED TWO FLOOR TILES	0.50
2015013160	MAINTENANCE ODW INT. LIGHTING	AREA 14 LAMPS BURNED OUT	AREA 14	1/20/2015	REPLACED WITH NEW	1.00
2015013161	MAINTENANCE ODW BLDG/EQUIP. REP	M/S R/R A1005 INTERIOR HC BUTTON NOT WORKING	M/S R/R A1005	1/20/2015	REPLACED BATTERY	0.50
2015013167	MAINTENANCE ODW PLUMBING	B CANTEEN SINK HAS A LACK OF HOT WATER	B CANTEEN	1/20/2015	FOUND NO HOT WATER IN STAINLESS SINKS (RM 1004). RM 1006 (JANITOR'S CLOSET) HAD BOTH FAUCET VALVES OPEN. REMOVED HW HANDLE AND VALVED OFF PERMANENTLY. HOUSEKEEPING SAID THEY DID NOT NEED HW IN THIS JANITOR'S CLOSET.	1.00
2015013191	MAINTENANCE ODW INT. LIGHTING	W'S R/R A404 LIGHTS OUT	W'S R/R A404	1/21/2015	REPLACED LAMPS	0.50
2015013192	MAINTENANCE ODW INT. LIGHTING	AREA 10 BALLAST IS BAD AND LIGHTS OUT SE OF POLE 7R.	AREA 10	1/21/2015	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2015013193	MAINTENANCE ODW INT. LIGHTING	B317 LIGHTS OUT	B317	1/21/2015	REPLACED LAMPS	0.50
2015013194	MAINTENANCE ODW INT. LIGHTING	AREA 14 BALLAST IS BAD AND SEVERAL LIGHTS OUT	AREA 14	1/21/2015	REPLACED BALLAST. REPLACED 18 LIGHTS.	1.75

2015013212	MAINTENANCE ODW INT. LIGHTING	BADGE ROOM - THERE ARE TWO LIGHTS THAT NEED CHANGED. ONE IS OUT AND THE OTHER IS FLICKERING. CHECK WITH WANDA NEWMAN BEFORE REPLACING.	BADGE ROOM	1/21/2015	REPLACED ONE BULB EACH IN TWO FIXTURES PER WANDA NEWMAN.	0.50
2015013243	MAINTENANCE ODW TEMPERATURE HOT	RESTRICTED AREA 1 LEFT OF MONITOR - TOO HOT	RESTRICTED AREA 1	1/22/2015	LOWERED SPACE TEMP SETPOINT FROM 75 DEG TO 73.5 DEG.	0.50
2015013249	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 5 STALL #2 TOILET CLOGGED	MAG HALL 5	1/22/2015	UNCLOGGED WITH PLUNGER	0.50
2015013250	MAINTENANCE ODW BLDG/EQUIP. REP	MAG HALL RM 4 RESTROOM STALL DOOR BROKEN. TOP HINGE BROKE OFF.	MAG HALL RM 4	1/22/2015	INSTALLED COPPER SLEEVE INTO TOP HINGE.	3.00
2015013251	MAINTENANCE ODW INT. LIGHTING	AREA 14 LAMPS BURNED OUT	AREA 14	1/22/2015	REPLACED WITH NEW	0.50
2015013252	MAINTENANCE ODW INT. LIGHTING	AREA 5 SEVERAL LAMPS OUT	AREA 5	1/22/2015	REPLACED LAMPS	1.00
2015013263	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R B211 HANDICAP STALL HANDRAIL FELL OFF. IT NEEDS TO BE SECURELY REMOUNTED. YOU CAN LOCATE THE HANDRAIL IN B212.	M'S R/R B211	1/22/2015	ACTUALLY M'S R/R B309, HANDRAIL LOCATED IN B312. INSTALLED NEW ANCHORS IN WALL FOR LEFT-HAND SIDE OF HANDRAIL MOUNT AND REINSTALLED HANDRAIL.	1.00
2015013285	MAINTENANCE ODW BLDG/EQUIP. REP	BETWEEN GATE 5 AND S BREEZEWAY THE DRAIN IN THE SIDEWALK IS MAKING A LOUD "GURGLING" SOUND	GATE 5 AND S BREEZEWAY	1/22/2015	CHECKED BOTH DRAINS IN SIDEWALK. NEITHER ONE WAS MAKING A NOISE.	0.50
2015013306	MAINTENANCE ODW INT. LIGHTING	AREA 3 WEST LIGHTS OUT NEAR POLE 5G	AREA 3 WEST	1/23/2015	REPLACED LAMPS	0.50
2015013307	MAINTENANCE ODW INT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	1/23/2015	REPLACED 12 LIGHT BULBS, 2 BALLASTS AND VACUUMED 4 LIGHT FIXTURES	2.00
2015013321	MAINTENANCE ODW BUILDING SIGNAGE	GARAGE DOOR - NEEDS ASBESTOS SIGN PUT UP	GARAGE DOOR	1/23/2015	HUNG SIGN (SCREWED TO WALL) INSIDE GARAGE ACROSS FROM ENTRY DOOR ON LANDING.	0.50
2015013323	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP STALL CLOGGED	W'S R/R A34	1/23/2015	PLUNGED TOILET SEVERAL TIMES. FLUSHED SEVERAL TIMES. OK.	0.50
2015013337	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP STALL CLOGGED AND OVERFLOWING	W'S R/R A34	1/23/2015	PLUNGED. FLUSHED NUMEROUS TIMES. FLUSHED WADS OF TOILET PAPER. WORKING PROPERLY.	0.50
2015013338	MAINTENANCE ODW DOOR	CANTEEN SWINGING DOOR NEEDS REPAIRED	CANTEEN SWINGING DOOR	1/23/2015	INSTALLED NEW ANCHORS IN DOOR JAMB AND REINSTALLED SWINGING DOOR.	1.00
2015013369	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 30 LIGHT KEEPS FLICKERING	MAG HALL RM 30	1/26/2015	REPLACED BOTH LAMPS AT LAST FIXTURE NE CORNER.	0.50
2015013373	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W/S R/R 5 #2 CLOGGED	MAG HALL W'S R/R 5	1/26/2015	PLUNGED THE COMMODORE	0.50
2015013374	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	1/26/2015	REPLACED BULBS	0.50
2015013375	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	1/26/2015	REPLACED LAMPS	0.50
2015013376	MAINTENANCE ODW INT. LIGHTING	CHILLER RM LIGHTS OUT	CHILLER RM	1/26/2015	REPLACED LAMPS	0.50
2015013377	MAINTENANCE ODW INT. LIGHTING	CHILDCARE LIGHTS OUT AT EAST SIDE HALLWAY, WEST SIDE HALLWAY, HALL BATHROOM, RM 109	CHILDCARE	1/26/2015	CHANGED A TOTAL OF 5 BULBS	0.75
2015013378	MAINTENANCE ODW DOOR	RM 123 DOOR TO THE BATHROOM NEEDS A DOOR STOP	RM 123	1/26/2015	INSTALLED A DOOR STOP INTO THE FLOOR. HOMEMADE STOP NEEDS REPLACED. OLD STOP NEEDS TO BE FIXED OR REMOVED. HOLE IN WALL NEEDS FIXED. LT: DOOR STOP HAS BEEN REPLACED. HOLE IN WALL HAS BEEN REPAIRED AND PAINTED.	3.00
2015013379	MAINTENANCE ODW BLDG/EQUIP. REP	CAFETERIA HALL HAS A LOOSE BASEBOARD	CAFETERIA HALL	1/26/2015	CLEANED AND REINSTALLED BASEBOARD	0.50
2015013380	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	1/26/2015	REPLACED 12 BULBS	1.00
2015013381	MAINTENANCE ODW INT. LIGHTING	AREA 3 SE CORNER OF POLE 4H LIGHTS OUT	AREA 3 SE	1/26/2015	REPLACED BALLAST AND LAMPS.	1.00
2015013413	MAINTENANCE ODW PLUMBING	M'S R/R A602 SECOND URINAL WILL NOT FLUSH	M'S R/R A602	1/26/2015	REPLACED 4 AA BATTERIES	0.50
2015013422	MAINTENANCE ODW FLOOR TILE	POLE 7V THERE ARE TWO FLOOR TILES STICKING UP	POLE 7V	1/27/2015	RESET TWO FLOOR TILES.	0.50
2015013428	MAINTENANCE ODW PLUMBING	M'S R/R B309 THIRD SINK FROM THE LEFT IS BARELY FLOWING WATER	M'S R/R B309	1/27/2015	ADJUSTED WATER FLOW	0.50
2015013450	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 TOILET CLOGGED	W'S R/R A306	1/27/2015	UNCLOGGED WITH PLUNGER	0.50
2015013456	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP TOILET CLOGGED	W'S R/R A34	1/27/2015	REMOVED A LARGE AMOUNT OF TOILET PAPER. PLUNGED AND FLUSHED NUMEROUS TIMES. WORKING PROPERLY.	0.50
2015013476	MAINTENANCE ODW DOOR	903 AUTO DOOR KNOCKED OFF TRACK	903	1/28/2015	PUT DOOR BACK ON TRACK	0.50
2015013477	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	1/28/2015	REPLACED 20 LIGHT BULBS AND CLEANED 3 LIGHT LENSES	1.00
2015013478	MAINTENANCE ODW INT. LIGHTING	AREA 4 TWO LIGHTS OUT NORTH OF POLE 4M	AREA 4	1/28/2015	REPLACED LOOSE LENSES AND REPLACED LAMP	0.50
2015013479	MAINTENANCE ODW PLUMBING	HEALTH UNIT A41 TOILET FLUSHES BY ITSELF	HEALTH UNIT A41	1/28/2015	ADJUSTED RANGE SENSOR 1/4 TURN LOWER	0.50
2015013488	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A602 URINAL OVERFLOWING	M'S R/R A602	1/28/2015	REPLACED FLUSH HEAD. REPLACED VACUUM BREAKER (URINAL WAS OVERFLOWING DUE TO FLUSH HEAD MALFUCTION).	0.50
2015013490	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 #2 CLOGGED	W'S R/R A5	1/28/2015	PLUNGED COMMODORE. FLUSHED NUMEROUS TIMES. OK.	0.50
2015013491	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP STALL CLOGGED	W'S R/R A34	1/28/2015	WITHDREW A LARGE AMOUNT OF TOILET PAPER. PLUNGED. FLUSHED NUMEROUS TIMES. OK.	0.50
2015013499	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 CLOGGED	W'S R/R A306	1/28/2015	PLUNGED COMMODORE. FLUSHED NUMEROUS TIMES. OK. TIGHTENED SEAT BOLTS TO #'S 4, 5, 6 AND 8.	0.50
2015013501	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 HANDICAP STALL CLOGGED	W'S R/R A404	1/28/2015	PLUNGED TOILET. REPLACED FLUSH HEAD AND VACUUM BREAKER. OK.	1.50
2015013505	MAINTENANCE ODW INT. LIGHTING	CHILDCARE HALLWAY R/R LIGHT OUT	CHILDCARE HALLWAY R/R	1/28/2015	LIGHTS WERE WORKING FINE WHEN I CHECKED.	0.50
2015013506	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 126 LIGHT OUT	CHILDCARE RM 126	1/28/2015	AG: REPLACED 4 LIGHT FLUORESCENT BULBS (2 8" CIRCULAR AND 2 12" CIRCULAR). MR: REPLACED DIMMING BALLAST.	1.50
2015013507	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 126 FLOOR TILE TO THE LEFT OF FRONT DOOR IS LOOSE AND HAS A CHIP IN CORNER	CHILDCARE RM 126	1/28/2015	TILE HAS BEEN REPAIRED	0.50
2015013508	MAINTENANCE ODW CEILING TILE	CHILDCARE FOYER TWO CEILING TILES MISSING AND BUCKET NEEDS REMOVED FROM CORNER OF ROOM	CHILDCARE FOYER	1/28/2015	REMOVED BUCKETS. CUT AND REPLACED TWO CEILING TILES.	0.75

2015013512	MAINTENANCE ODW GATE/FENCE	B LOT JOHNSON ST. FIRE GATE FOURTH PANEL DOWN, TOP PART IS NOT ATTACHED.	B LOT	1/28/2015	REPAIRED AND REATTACHED PANEL TO POST. PAINTED AND REPAIRED.	1.00
2015013523	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE TEACHER'S R/R TOILET CLOGGED	CHILDCARE TEACHER'S R/R	1/29/2015	PLUNGED THE COMMODE	0.50
2015013525	MAINTENANCE ODW PLUMBING CLOG	MAG HALL R/R 5 TOILET #2 CLOGGED	MAG HALL R/R 5	1/29/2015	UNCLOGGED THE COMMODE	0.50
2015013602	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W'S R/R 5 STALL NEXT TO HANDICAP CLOGGED	MAG HALL W'S R/R 5	1/29/2015	TOILET CLOGGED TO RIM. FECES FOUND ON FLOOR. (TOILET DID NOT OVERFLOW AS FLOOR AND SEAT COVERS WERE DRY.) PLUNGED, FLUSHED, NOTIFIED HOUSEKEEPING (C. PUTTHOFF).	0.50
2015013639	MAINTENANCE ODW INT. LIGHTING	RM 903 LIGHTS OUT	RM 903	1/30/2015	REPLACED 8 LIGHTS	0.50
2015013640	MAINTENANCE ODW INT. LIGHTING	LIGHTS OUT AT POLE 5M	POLE 5M	1/30/2015	REPLACED LAMPS	0.50
2015013641	MAINTENANCE ODW TEMPERATURE COLD	AREA 1 TOO COLD	AREA 1	1/30/2015	TOOK READINGS OF AREA: 74.2, 73.4 AND 73.1 AND READING FROM METASYS WAS 72.9. WITHIN CONTRACT. MADE NO ADJUSTMENTS.	0.50
2015013642	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 308 TOILET STOPPED UP	M'S R/R 308	1/30/2015	CLEARED CLOG WITH PLUNGER. OK.	0.50
2015013643	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 309 #2 SINK STOPPED UP	W'S R/R 309	1/30/2015	CLEARED CLOG WITH PLUNGER	0.50
2015013653	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 STALL #8 CLOGGED	W'S R/R 306	1/30/2015	PLUNGED COMMODE. FLUSHED. OK.	0.50
2015013677	MAINTENANCE ODW DOOR	CHILDCARE RM 123 FINGER GUARDS NEEDS REPLACED ON DOOR	CHILDCARE RM 123	1/30/2015	REPLACED FINGER GUARDS WITH NEW	0.50
2015020369	MAINTENANCE ODW BLDG/EQUIP. REP	LASER PRINT RM HAS AN ODOR	LASER PRINT RM	2/2/2015	TICKET SAID THAT THE ODOR COULD BE COMING FROM THE AC UNIT. CHECKED ALL UNITS. ODOR ACTUALLY COMING FROM SOUR DIRT IN A COFFEE CUP.	1.50
2015020371	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W'S R/R A5 #2 CLOGGED	MAG HALL R/R A5	2/2/2015	SNAKED COMMODE	0.50
2015020372	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT OVER CUBICLE GDI-A3-027. CRACKED LENS AND LIGHTS OUT IN HALL OUTSIDE 303.	AREA 3	2/2/2015	REPLACED LAMPS. REPLACED LAMP AND LENS COVER.	1.00
2015020373	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LIGHTS OUT	AREA 4 WEST	2/2/2015	REPLACED LAMPS.	0.50
2015021900	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A700 SINK CLOGGED. WATER HAS BEEN TURNED OFF AND AN "OUT OF ORDER" SIGN HAS BEEN PLACED ON SINK. NEEDS TO BE SNAKED.	W'S R/R A700	2/2/2015	SNAKED DRAIN.	1.00
2015021997	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LIGHTS OUT	AREA 4 WEST	2/3/2015	REPLACED LAMPS	1.00
2015021998	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #2 CLOGGED	M'S R/R B309	2/3/2015	UNCLOGGED WITH PLUNGER	0.50
2015021999	MAINTENANCE ODW PLUMBING	M'S R/R A308 TOILET NOT FLUSHING PROPERLY	M'S R/R A308	2/3/2015	ADJUSTED WATER SUPPLY TO STRENGTHEN FLUSH	0.50
2015022401	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 CLOGGED	W'S R/R 306	2/4/2015	UNCLOGGED COMMODE	0.50
2015022402	MAINTENANCE ODW FLOOR TILE	POLE 5X FLOOR TILES NEED REPLACED	POLE 5X	2/4/2015	REPLACED BOTH FLOOR TILES	0.75
2015022403	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHT LENS COVER MISSING BY POLE 8V	AREA 9	2/4/2015	CUT AND REPLACED LENS ON LIGHT FIXTURE	0.75
2015022454	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET #8 FLUSING CONTINUOUSLY. TOILET #2 CLOGGED.	W'S R/R A1003	2/4/2015	#8: CHANGED BATTERIES ON FLUSH HEAD. #2: PLUNGED. FLUSHED NUMEROUS TIMES. OK.	1.00
2015022457	MAINTENANCE ODW ELECTRICAL	RM 31, CUBICLE GDIA0033 POWER IS OUT	RM 31	2/4/2015	RESET BREAKER	0.50
2015022462	MAINTENANCE ODW BLDG/EQUIP. REP	CENTRAL PLANT WATER HEATER IS LEAKING	CENTRAL PLANT	2/4/2015	VALVED OFF WATER HEATER AND REMOVED. REPLACED WITH NEW UNIT.	4.00
2015022485	MAINTENANCE ODW INT. LIGHTING	MAG HALL 3 AND 3A LIGHTS OUT	MAG HALL 3 AND 3A	2/5/2015	REPLACED LAMPS IN 3A. PUT RED DOTS ON TWO FIXTURES IN 3A AND 10 IN RM 3.	0.50
2015022486	PREVENTIVE MAINT	116A SUMP PUMP	116A	2/5/2015	CLEANED, INSPECTED AND OPERATED. WORKING PROPERLY.	0.50
2015022487	MAINTENANCE ODW INT. LIGHTING	MAINTENANCE SHOP LIGHTS OUT	MAINTENANCE SHOP	2/5/2015	REPLACED WITH NEW	0.50
2015022488	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILETS #2 AND #3 CLOGGED	M'S R/R B309	2/5/2015	PLUNGED BOTH. FLUSHED. OK.	0.50
2015022489	MAINTENANCE ODW PLUMBING	CHILDCARE RM 126 TOILET LEAKING	CHILDCARE RM 126	2/5/2015	REPLACED "O" RING	0.50
2015022526	MAINTENANCE ODW BLDG/EQUIP. REP	R/R 103D TOILET SEAT SCREW IS MISSING	R/R 103D	2/5/2015	REPLACED TOILET SEAT SCREW WITH NEW	0.50
2015022527	MAINTENANCE ODW RESTROOM FIXTURE	CSPC GUARD RESTROOM SINK HANDLE NEEDS ADJUSTED TO SHUT OFF WATER	GUARD RESTROOM	2/5/2015	2-5-15: CHECKED FAUCET. NEED TO ORDER A REPLACEMENT. 2-6-15: REPLACED FAUCET. COST: \$36.00.	1.50
2015022550	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 30 CEILING LIGHT IS FLICKERING	MAG HALL RM 30	2/5/2015	REPLACED LAMPS.	0.50
2015022571	MAINTENANCE ODW PLUMBING	M'S R/R B309 TOILET #1 PIPES LEAKING	M'S R/R B309	2/6/2015	ADJUSTED WATER SUPPLY VALVE. LEAK STOPPED.	0.50
2015022594	MAINTENANCE ODW BLDG/EQUIP. REP	AIR HOSE ON BACK WALL NEEDS MOVED HIGHER ON WALL	MSU	2/6/2015	MOVED AIR HOSE	1.50
2015022638	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 SINKS 1 AND 2 CLOGGED	W'S R/R A1003	2/9/2015	SNAKED DRAIN. HAD TO REMOVE PAPER TOWEL DISPENSER.	1.25
2015022640	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 HAS A LOOSE TILE	CHILDCARE RM 128	2/9/2015	CLEANED AREA. REINSTALLED TILE.	1.00
2015022641	MAINTENANCE ODW BUILDING SIGNAGE	CHILDCARE DROP OFF SIGN NEEDS INSTALLED	CHILDCARE	2/9/2015	INSTALLED SIGN ON WEST SIDE OF BUILDING.	0.50
2015022642	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 130 LIGHTS OUT	CHILDCARE RM 130	2/9/2015	REPLACED BULBS	0.50
2015022644	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 126 BALLAST IS BAD	CHILDCARE RM 126	2/9/2015	REPLACED BALLAST	1.00
2015022645	MAINTENANCE ODW KITCHEN EQUIP	CHILDCARE OVEN AND EXHAUST FAN NOT OPERATING	CHILDCARE	2/9/2015	RESET SHUNT BREAKER FOR OVEN AND EXHAUST FAN.	0.50
2015022646	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	2/9/2015	PLUNGED TOILET NUMEROUS TIMES. FLUSHED NUMEROUS TIMES. OK.	0.50
2015022692	MAINTENANCE ODW CLOCKS	MAG HALL RM 32C WALL CLOCK MAKING NOISE	MAG HALL RM 32C	2/10/2015	REPLACED CLOCK WITH NEW DIGITAL CLOCK	1.00
2015022696	MAINTENANCE ODW PLUMBING CLOG	MAG HALL W'S R/R 34 TOILET #1 CLOGGED	MAG HALL W'S R/R 34	2/10/2015	TOILET OK, NOT CLOGGED. CHECKED OTHER TOILETS AS WELL. ALL OK.	0.50
2015022702	MAINTENANCE ODW FLOOR TILE	AREA 10 SOUTH OF POLE 7W FLOOR TILE NEEDS REPLACED	AREA 10	2/10/2015	REPLACED TILE	0.50
2015022714	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309: URINAL #1 OVERFLOWS WHEN FLUSHED. STALLS #3 AND #4 CLOGGED.	M'S R/R B309	2/10/2015	PLUNGED 3 AND 4 TO UNCLOG. PLUNGED URINAL, REPLACED LEAKING STOP VALVE, REPLACED DIAPHRAGM.	1.00
2015022746	MAINTENANCE ODW PLUMBING	W'S R/R A600 HANDICAP TOILET WILL NOT FLUSH	W'S R/R A600	2/11/2015	REPLACED BATTERIES IN FLUSH HEAD	0.50

2015022747	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 STALL #8 CLOGGED	W'S R/R A306	2/11/2015	PLUNGED SEVERAL TIMES. FLUSHED SEVERAL TIMES. OK.	0.50
2015022748	MAINTENANCE ODW NOISE	POLE 8H VENT ABOVE DESK MAKING NOISE	POLE 8H	2/11/2015	CHECKED AREA. CHECKED AHU. SOUNDED NORMAL.	0.50
2015022749	MAINTENANCE ODW INT. LIGHTING	POLE 4F IN FRONT OF OFFICE 300A LIGHT COVER IS LOOSE	POLE 4F	2/11/2015	ADJUSTED LIGHT LENS. OK.	0.50
2015022773	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 ALL SINKS ARE CLOGGED	W'S R/R B302	2/11/2015	SNAKED OUT DRAIN LINE	4.50
2015022869	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 CLOGGED	W'S R/R A306	2/13/2015	UNCLOGGED THE COMMUNE	0.50
2015022870	MAINTENANCE ODW INT. LIGHTING	AREA 5 OVERHEAD LIGHTS OUT	AREA 5	2/13/2015	REPLACED 24 LIGHT BULBS	1.00
2015022889	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 103 (ALL LIGHTS OUT IN ONE FIXTURE) AND 109 (ALL LIGHTS OUT IN THREE FIXTURES)	CHILDCARE RM'S 103 AND 109	2/13/2015	REPLACED ALL LIGHT BULBS. 2-23-15: RM 103, REBUILT LIGHT FIXTURE WITH NEW BALLAST, 6 NEW SOCKETS AND METAL PART THAT HOLDS THE SOCKETS.	4.50
2015022911	MAINTENANCE ODW INT. LIGHTING	POLE 8JJ LIGHT LENS IS HANGING	POLE 8JJ	2/17/2015	SECURED LIGHT LENS. OK.	0.50
2015022930	MAINTENANCE ODW TEMPERATURE COLD	B317 TOO COLD	B317	2/17/2015	MEASURED 68.5 DEG. TURNED NO LIEBERT UNIT AND SET FOR 71 DEG F.	0.50
2015022959	MAINTENANCE ODW SNOW REMOVAL	ACROSS DOOR B1 - EAST/WEST DRIVE LANE IS BLOCKED WITH A SMALL PILE OF SNOW	ACROSS DOOR B1	2/17/2015	SHOVELED SNOW FROM DRIVE. NO LONGER BLOCKED.	0.50
2015022974	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 STALL #8 CLOGGED	W'S R/R A306	2/18/2015	PLUNGED COMMUNE. FLUSHED. OK. FLUSHED ALL TOILETS. OK.	0.50
2015023017	MAINTENANCE ODW PLUMBING	W'S R/R 700H FIRST TOILET WILL NOT FLUSH	W'S R/R 700H	2/18/2015	REPLACED FLUSH HEAD WITH REBUILT	1.00
2015023032	MAINTENANCE ODW PLUMBING	W'S R/R 700H LAST TOILET WILL NOT FLUSH.	W'S R/R 700H	2/19/2015	FLUSHED ALL MANUAL AND AUTO TOILETS. ALL FUNCTIONING NORMALLY.	0.50
2015023038	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	2/19/2015	REPLACED 12 LIGHT BULBS AND VACUUMED FOUR LIGHT FIXTURES	1.00
2015023039	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS OUT	AREA 1	2/19/2015	REPLACED 12 LIGHT BULBS	0.50
2015023040	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 TOILET #1 CLOGGED	M'S R/R 810	2/19/2015	UNCLOGGED COMMUNE	0.50
2015023041	MAINTENANCE ODW DOOR	RM 203 DOOR KNOB FELL OFF	RM 203	2/19/2015	REPAIRED. OK.	1.00
2015023088	MAINTENANCE ODW PLUMBING	W'S R/R A600 STALL #13 TOILET WILL NOT FLUSH	W'S R/R A600	2/20/2015	REPLACED FLUSH HEAD WITH REBUILT	1.00
2015023089	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 STALL #8 CLOGGED	W'S R/R A306	2/20/2015	PLUNGED COMMUNE. FLUSHED SEVERAL TIMES. OK.	0.50
2015023109	MAINTENANCE ODW BLDG/EQUIP. REP	SCAMPS HVAC UNIT IS BEEPING	SCAMPS	2/20/2015	LOW TEMP ALARM. RESET ALARM, NO ALARMS CURRENTLY PRESENT. UNIT FUNCTIONING CORRECTLY.	0.50
2015023133	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE STAFF REFRIGERATOR NOT COOLING	CHILDCARE	2/23/2015	CHECKED FRIG. SOMEONE TURNED COOLING OPTION TO OFF POSITION. SET COOLING TEMP TO SUGGESTED TEMP. WAITED TO BE SURE IT BAGAN TO COOL. OK.	0.75
2015023136	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 CLOGGED	M'S R/R B309	2/23/2015	UNCLOGGED THE COMMUNE	0.50
2015023137	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 TOILET #11 CLOGGED	W'S R/R B302	2/23/2015	UNCLOGGED THE COMMUNE	0.50
2015023138	MAINTENANCE ODW PLUMBING	SECURITY R/R COMMUNE CONSTANTLY RUNS WATER	SECURITY R/R	2/23/2015	REPLACED BATTERIES AND FLUSH DIAPHRAGM	0.75
2015023143	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #3 CLOGGED	W'S R/R B211	2/23/2015	UNFORTUNATELY, SOMEONE OPENED UP THE TOILET PAPER DISPENSER AND TOOK THE ENTIRE ROLL OF TOILET PAPER AND THREW IT IN THE TOILET.	0.50
2015023150	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #15 CLOGGED AND OVERFLOWING ONTO FLOOR	W'S R/R A600	2/23/2015	FLUSHED TOILET NUMEROUS TIMES WHILE PLUNGING. OK.	0.50
2015023166	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 TWO SINKS ARE CLOGGED	W'S R/R B302	2/23/2015	2-23-15: SNAKED THROUGH DRAIN. SNAKE WILL NOT MAKE TURN INTO TEE. REASSEMBLED DRAIN. VALVED OFF SINKS. MEASURED DISTANCE TO TEE. 2-24-25: REMOVED BLOCK TO ACCESS TEE. SNAKED MAIN THROUGH TEE. COVERED HOLE IN TEE. COVERED HOLE IN BLOCK WALL IN JANITOR'S CLOSET BY DOOR B4.	5.00
2015023201	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 CLOGGED	M'S R/R B309	2/24/2015	CLEARED PAPER TOWELS FROM CLOGGED COMMUNE.	1.00
2015023234	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET CLOGGED	M'S R/R A1005	2/24/2015	CLEARED CLOGGED COMMUNE	0.50
2015023235	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #3 CLOGGED	W'S R/R B211	2/24/2015	CLEARED CLOGGED COMMUNE	1.00
2015023236	MAINTENANCE ODW GATE/FENCE	GATE 3 NORTH DOOR ON GUARD SHACK IS STICKING	GATE 3	2/24/2015	LUBED ROLLERS AT TOP OF DOOR, VACUUMED OUT DOOR TRACK AND CUT AWAY RUBBER FLOORING THAT WAS HANGING OVER INTO DOOR TRACKS.	0.75
2015023237	MAINTENANCE ODW BLDG/EQUIP. REP	CSPC DOCK BAY LIFT NOT WORKING PROPERLY	CSPC DOCK BAY	2/24/2015	CYCLED LIFT FULLY THREE TIMES. LIFT IS OPERATING CORRECTLY. MOVES SLOWLY DUE TO COLD WEATHER.	0.50
2015023252	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	2/24/2015	UNCLOGGED COMMUNE	0.50
2015023275	MAINTENANCE ODW SNOW REMOVAL	SIDEWALK OUTSIDE GATE 1 HAS ICE AND A PATH NEEDS SHOVELED.	SIDEWALK OUTSIDE GATE 1	2/25/2015	USED BOBCAT TO BREAK UP ICE. SHOVELED AREA. SCATTERED SALT.	3.00
2015023276	MAINTENANCE ODW BLDG/EQUIP. REP	DOCK DOOR - TOP STEP IS BROKEN AND THE METAL GUARD PLATE IS OFF	DOCK DOOR	2/25/2015	REINSTALLED TREAD	1.00
2015023287	MAINTENANCE ODW INT. LIGHTING	AREA 3 POLE 5G BROKEN LENS COVER	AREA 3	2/25/2015	REPLACED BROKEN LENS AT 5G, 4G AND 4H.	3.00
2015023288	MAINTENANCE ODW INT. LIGHTING	RM 903 LIGHT FIXTURE OUT	RM 903	2/25/2015	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2015023315	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	2/25/2015	PLUNGED, FLUSHED, OK	0.50
2015023319	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #3 CLOGGED	W'S R/R B211	2/25/2015	PLUNGED, FLUSHED, OK	0.50
2015023364	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #4 IS CLOGGED	W'S R/R A600	2/26/2015	PLUNGED. FLUSHED. OK.	0.50
2015023365	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET #3 SPRAYING WATER	W'S R/R A309	2/26/2015	ADJUSTED WATER FLOW	0.50
2015023366	MAINTENANCE ODW LEAKS	CHILDCARE RM 123 WATER LEAK AT THE CHILDREN'S SINKS	CHILDCARE RM 123	2/26/2015	NO LEAK ON SUPPLY OR DRAIN. THERE IS AN ODOR. WAS NOT CLEANED OUT SO COULD NOT WIPE DOWN WITH CLOROX.	1.50
2015023369	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A306 TOILET SEAT BROKEN AT STALL #9	W'S R/R A306	2/26/2015	REPLACED TOILET SEAT	0.50

2015023372	MAINTENANCE ODW RESTROOM FIXTURE	M/S R/R A602 AUTO DOOR INTERIOR BUTTON NOT WORKING	M/S R/R A602	2/26/2015	REPLACED BATTERY	0.50
2015023373	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #8 CLOGGED	W'S R/R A306	2/26/2015	UNCLOGGED WITH PLUNGER	0.50
2015023374	MAINTENANCE ODW PLUMBING	MAG HALL TOILETS #1-#5 NOT FLUSHING PROPERLY	MAG HALL 5	2/26/2015	FLUSHED ALL TOILETS. FUNCTIONING NORMALLY.	0.50
2015023375	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 35 TOILET #1 CLOGGED	MAG HALL 35	2/26/2015	UNCLOGGED COMMODOE. TOILET FUNCTIONING PROPERLY.	0.50
2015023381	MAINTENANCE ODW PLUMBING CLOG	M/S R/R A35 TOILET STOPPED UP	M/S R/R A35	2/26/2015	PLUNGED. FLUSHED. OK.	0.50
2015023385	MAINTENANCE ODW PLUMBING CLOG	R/R A403 TOILET CLOGGED	R/R A403	2/26/2015	PLUNGED. FLUSHED. OK.	0.50
2015023386	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #4 CLOGGED	W'S R/R A600	2/26/2015	PLUNGED. FLUSHED. OK.	0.50
2015023387	MAINTENANCE ODW SNOW REMOVAL	GATEHOUSE 1 AND B2 TO CHILDCARE HAS BLACK ICE AND NEEDS SALTED	GATEHOUSE 1	2/26/2015	SALTED AFFECTED AREAS	0.50
2015023389	MAINTENANCE ODW LEAKS	ROOF LEAK AT 6DD	ROOF LEAK AT 6DD	2/26/2015	NO ACTIVE LEAK. REMOVED DRIP PAN.	1.00
2015031348	MAINTENANCE ODW PLUMBING	M/S R/R A810 HANDICAP STALL TOILET RUNNING	M/S R/R A810	3/2/2015	CHECKED STALL. FUNCTIONING NORMALLY.	0.50
2015031358	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET #7 CONSTANTLY RUNNING	W'S R/R A1003	3/2/2015	REPLACED FLUSH HEAD, STOP VALVE, VACUUMED BREAKER AND SPUD GASKET	1.50
2015031483	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600, FIRST STALL ON RIGHT IS CLOGGED	W'S R/R 600	3/2/2015	PLUNGED TOILET. FLUSHED. OK.	0.50
2015031484	MAINTENANCE ODW LEAKS	B313 ROOF DRAIN LEAK	B313	3/2/2015	THERE WAS SNOW BUILD-UP AND THE LEAK STOPPED ONCE THE SNOW WAS CLEARED AWAY FROM THE DRAIN	0.00
2015031485	MAINTENANCE ODW INT. LIGHTING	POLES 4L AND 4N CEILING LIGHT TILES ARE BUCKLING	POLES 4L AND 4N	3/2/2015	REPLACED 2 LOOSE LENS COVERS	0.50
2015031486	MAINTENANCE ODW TEMPERATURE COLD	HEALTH UNIT TOO COLD	HEALTH UNIT	3/2/2015	TEMP AT HEALTH UNIT 71.5, 72.0. RAISED T-STAT 1 DEG.	0.50
2015031489	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 5/DPO BETWEEN POLES 7L AND 7N CEILING LIGHT COVERS BUCKLING	AREA 5/DPO	3/2/2015	REPAIRED LIGHT COVER	0.50
2015031490	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 4/DCO BETWEEN POLES 4P AND 4M CEILING LIGHT COVERS ARE BUCKLING	AREA 4/DCO	3/2/2015	REPAIRED 5 LOOSE LENS COVERS	1.00
2015031491	MAINTENANCE ODW PLUMBING CLOG	M/S R/R B309 #2 CLOGGED	M/S R/R B309	3/2/2015	UNCLOGGED THE COMMODOE	0.50
2015031492	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 #3 CLOGGED	W'S R/R A404	3/2/2015	UNCLOGGED THE COMMODOE	0.50
2015031493	MAINTENANCE ODW INT. LIGHTING	AREA 10 SEVERAL OVERHEAD LIGHTS OUT	AREA 10	3/2/2015	RERPLACED 32 LIGHT BULBS AND 2 LIGHT BALLASTS	2.50
2015032083	MAINTENANCE ODW INT. LIGHTING	AREA 6 - LIGHTS OUT AT SLIDING GLASS DOORS AT RECEIPT AND CONTROL	AREA 6	3/3/2015	REPLACED LAMPS	0.50
2015032089	MAINTENANCE ODW PLUMBING	CHILDCARE STAFF LOUNGE TOILET IS LEAKING	CHILDCARE STAFF LOUNGE	3/3/2015	THE TOILET IS FINE. THE WATER ON THE FLOOR WAS FROM A LEAKING WATER HEATER. VALVED OFF WATER HEATER AND DRAINED UNIT. REMOVED WATER HEATER. PURCHASED NEW HEATER AND FITTINGS. SET NEW HEATER, REPIPED WATER LINES, GAS LINE AND ADDED FLUE PIPE. TOILET AND DISHWASHER ARE WORKING PROPERLY. COST: CORKEN \$11.28; FERGUSON \$92.31; FERGUSON \$3.784.37.	27.00
2015032091	MAINTENANCE ODW PLUMBING	M/S R/R 1005 HANDICAP TOILET IS OVERFLOWING	M/S R/R 1005	3/3/2015	CLEARED 3 COMMODOES AND MIDDLE COMMODOE TWICE	1.00
2015032096	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #14 CLOGGED	W'S R/R B211	3/3/2015	UNCLOGGED WITH PLUNGER	0.50
2015032097	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #1 CLOGGED, #12 TOILET SEAT IS LOOSE	W'S R/R B211	3/3/2015	UNCLOGGED TOILET WITH PLUNGER. TIGHTENED SEAT MOUNTS ON #12.	0.50
2015032107	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 STOPPED UP.	W'S R/R 306	3/3/2015	REMOVED SEAT COVERS AND FLUSHED. OK.	0.50
2015032120	MAINTENANCE ODW BLDG/EQUIP. REP	JOHNSON ST. LOT - VEHICLE LEAKING FLUID	JOHNSON ST. LOT	3/3/2015	APPLIED OIL DRY	1.00
2015032183	MAINTENANCE ODW INT. LIGHTING	AREA 4 POLES 4P, 4M, 4O - LIGHTS OUT, LENSES LOOSE	AREA 4	3/4/2015	REPLACED 2 LOOSE LENS COVERS. REPLACED 4 LAMPS.	0.50
2015032184	MAINTENANCE ODW INT. LIGHTING	AREA 3 POLES 4B, 4C, 3B, 4F, 4K - LIGHTS OUT AND LENSES LOOSE	AREA 3	3/4/2015	REPLACED 3 LOOSE LENSES. REPLACED 5 LAMPS.	1.00
2015032185	MAINTENANCE ODW INT. LIGHTING	AREA 9 POLE 8W - LIGHTS OUT AND LENSES LOOSE	AREA 9	3/4/2015	REPAIRED TWO SAGGING LIGHT LENSES. REPLACED FOUR LIGHT BULBS.	0.50
2015032186	MAINTENANCE ODW INT. LIGHTING	AREA 14 POLES 2EE, 2FF - LIGHTS OUT AND LENSES LOOSE	AREA 14	3/4/2015	REPLACED BULBS AND ADJUSTED LENSES.	0.50
2015032187	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 1 POLE 8E A SPARK CAME FROM OUTLET WHILE CUSTODIAN WAS SWEEPING FLOOR	AREA 1	3/4/2015	CLEANED OTU STAPES AND PAPER CLIPS. PUT COVER BACK ON.	1.00
2015032188	MAINTENANCE ODW INT. LIGHTING	AREA 8 "CAGE" OVERHEAD LIGHTS OUT	AREA 8	3/4/2015	REPLACED 4 LIGHT BULBS	0.50
2015032189	MAINTENANCE ODW INT. LIGHTING	MSU LIGHTS OUT	MSU	3/4/2015	REPLACED 4 LIGHT BULBS	0.50
2015032553	MAINTENANCE ODW WATER FOUNTAIN	POLE 5X - WATER FOUNTAIN NOT DRAINING	POLE 5X	3/4/2015	SNAKED OUT DRAIN.	1.00
2015032555	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 6 TOILETS CLOGGED	W'S R/R B302	3/4/2015	PLUNGED EACH TOILET NUMEROUS TIMES. FLUSHED EACH TOILET NUMEROUS TIMES. ALL WORKING PROPERLY.	0.50
2015032638	MAINTENANCE ODW LEAKS	POLE 7EE CEILING LEAK	POLE 7EE	3/4/2015	NO LEAK. CEILING TILE WAS PAINTED MAKING IT LOOK WET.	1.00
2015032661	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE DISHWASHER NOT WORKING	CHILDCARE	3/4/2015	DISHWASHER WORKING NORMALLY. WATER HEATER WAS BEING REPLACED, THEREFORE, NO HOT WATER.	1.50
2015032662	MAINTENANCE ODW LEAKS	N. BREEZEWAY HAS TWO LEAKS	N. BREEZEWAY	3/4/2015	UPON INSPECTION, NO LEAKS FOUND. REPLACED 3 CEILING TILES. 3-17-15: REPLACED CEILING TILE.	1.00
2015032701	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 TOILET CLOGGED	W'S R/R 306	3/5/2015	PLUNGED TOILET, FLUSHED, OK	0.50
2015032705	MAINTENANCE ODW INT. LIGHTING	RM 804 HOUSEKEEPING OFFICE HAS LIGHTS OUT	RM 804	3/5/2015	REPLACED FOUR LIGHT BULBS	0.50
2015032721	MAINTENANCE ODW SNOW REMOVAL	2ND STREET SIDEWALK NEEDS CLEANED	2ND STREET	3/5/2015	SHOVELED SIDEWALK FROM GATEHOUSE 1 BUS STOP TO CONVENTION CENTER.	2.00
2015032728	MAINTENANCE ODW WATER FOUNTAIN	WATER FOUNTAIN OUTSIDE M/S R/R 1005 NOT PRODUCING WATER	WATER FOUNTAIN	3/5/2015	REPLACED LEVER. OK. PART COST \$10.00.	1.00
2015032734	MAINTENANCE ODW INT. LIGHTING	POLE 5B NEAR SKYLIGHT CANTEEN - CEILING LIGHTS OUT	POLE 5B	3/6/2015	REPLACED 8 LIGHTS AND ONE LIGHT LENS.	1.00
2015032735	MAINTENANCE ODW INT. LIGHTING	AREA 1 OVERHEAD LIGHTS OUT	AREA 1	3/6/2015	REPLACED 30 LIGHT BULBS	1.00

2015032752	MAINTENANCE ODW LEAKS	RM 30 - CAN "HEAR" WATER DRIPPING AND THE CEILING TILE APPEARS WET	RM 30	3/6/2015	PLACED LEAK DIVERTER IN CEILING AGAINST BACK WALL WITH BUCKET BELOW. JIM BLACK & SONS REPAIRED. REPLACED TILE AND REMOVED DRIP PAN.	2.50
2015032791	MAINTENANCE ODW INT. LIGHTING	POLE 5FF LIGHT LENS IS HANGING	POLE 5FF	3/9/2015	PUT LENS BACK IN PLACE	0.50
2015032794	MAINTENANCE ODW INT. LIGHTING	POLE 5DD ALL FOUR LIGHTS OUT	POLE 5DD	3/9/2015	LOST A PHASE IN LIGHTING PANEL 313. REPLACED 100 AMP FUSE.	0.50
2015032808	MAINTENANCE ODW BLDG/EQUIP. REP	COURTYARD CAFE OVEN DOOR BROKEN	COURTYARD CAFE	3/9/2015	REPLACED SPRING AND ELECTRICAL CONNECTION	1.50
2015032809	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 4 TOILET CLOGGED	M'S R/R 4	3/9/2015	PLUNGED TOILET. NOW CLEAR.	0.50
2015032844	MAINTENANCE ODW INT. LIGHTING	AREA 11 POLE 5X LIGHT LENS CRACKED	AREA 11	3/9/2015	CUT AND REPLACED LIGHT LENS	1.00
2015032845	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 110 FLOOR TILE COMING LOOSE BY WATER FOUNTAIN	CHILDCARE RM 110	3/9/2015	REGLUED TILE BACK INTO PLACE	0.50
2015032846	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	3/9/2015	REPLACED 18 BULBS	1.50
2015032847	MAINTENANCE ODW INT. LIGHTING	CHILDCARE CAFETERIA LIGHTS OUT	CHILDCARE CAFETERIA	3/9/2015	REPLACED BURNED OUT BULB	0.50
2015032848	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT AT POLE 4E	AREA 3	3/9/2015	REPLACED BALLAST AND LAMPS	0.50
2015032849	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT AT POLE 4N	AREA 4	3/9/2015	REPLACED BALLAST, LAMPS AND LENS COVER	1.00
2015032852	MAINTENANCE ODW LEAKS	LOADING DOCK ROOF LEAK	LOADING DOCK	3/9/2015	HIGH SNOW LEVEL. NO ACTIVE LEAK.	1.50
2015032853	MAINTENANCE ODW LEAKS	AREA 14 LEAK BETWEEN B323B AND B323C	AREA 14	3/9/2015	REMOVED DRIP PANS AND REPLACED TILES	1.50
2015032854	MAINTENANCE ODW LEAKS	POLE 6HH WATER LEAK	POLE 6HH	3/9/2015	HIGH SNOW LEVEL. NO ACTIVE LEAK. REMOVED DRIP PAN.	1.00
2015032855	MAINTENANCE ODW LEAKS	OUTSIDE MDF WATER LEAK IN CEILING	MDF	3/9/2015	COULD NOT FIND ACTIVE LEAK. REMOVED DRIP PAN AND BUCKET. CEILING TILE HAS BEEN REPLACED.	1.00
2015032857	MAINTENANCE ODW PLUMBING CLOG	CUSTODIAL CLOSET B303 DRAIN CLOGGED	RM B303	3/9/2015	ATTEMPTED SEVERAL DAYS TO CLEAR CLOG WITH SNAKE. HAD TO CALL ROTO ROOTER TO JET ENTIRE LINE TO THE STREET. ART'S RENTAL \$50; ROTO ROOTER \$1,000.	30.00
2015032858	MAINTENANCE ODW BLDG/EQUIP. REP	B304 DOOR KNOB FELL OFF FROM INSIDE. NEEDS SPANNER WRENCH TO TIGHTEN IT UP.	B304	3/9/2015	TIGHTENED UP DOOR KNOB	0.50
2015032885	MAINTENANCE ODW PLUMBING	M'S R/R A1005 LEAK AT TOP OF TOILET BOWL	M'S R/R A1005	3/10/2015	TIGHTENED NUT TO STOP LEAK	0.50
2015032886	MAINTENANCE ODW LEAKS	POLE 7DD LEAK AT CEILING	POLE 7DD	3/10/2015	NO ACTIVE LEAK. REMOVED DRIP PAN. REPLACED CEILING TILE.	1.00
2015032913	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 CLOGGED	W'S R/R 306	3/10/2015	PLUNGED TOILET NUMEROUS TIMES, FLUSHED, WORKING PROPERLY.	0.50
2015032966	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 CLOGGED	W'S R/R A306	3/11/2015	PLUNGED COMMODO, FLUSHED, OK.	0.50
2015032968	MAINTENANCE ODW PLUMBING	M'S R/R A1005 SINK #3 WATER RUNNING CONTINUOUSLY	M'S R/R A1005	3/11/2015	VALVED OFF WATER. REPLACED BATTERIES AND REPAIRED DRIPPING COMPRESSION CONNECTION.	2.00
2015032969	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 #1 CLOGGED	W'S R/R A600	3/11/2015	UNCLOGGED COMMODO	0.50
2015032970	MAINTENANCE ODW INT. LIGHTING	POLES 3B AND 4C HAVE SAGGING/BUCKLING CEILING LIGHT COVERS	POLES 3B AND 4C	3/11/2015	REPAIRED LOOSE LENSES	0.50
2015032971	MAINTENANCE ODW INT. LIGHTING	POLE 6P HAS A SAGGING/BUCKLING CEILING LIGHT COVER	POLE 6P	3/11/2015	LIGHT COVER HAS BEEN FIXED	0.50
2015032973	MAINTENANCE ODW INT. LIGHTING	AREA 3: POLES 4F, 5G HAVE SAGGING/BUCKLING CEILING LIGHT COVERS	AREA 3	3/11/2015	REPAIRED LENSES	0.50
2015032974	MAINTENANCE ODW INT. LIGHTING	AREA 3: DESK 065, 066, 068, 032, 033, 018, 002 AND 001 HAVE SAGGING/BUCKLING CEILING LIGHT COVERS	AREA 3	3/11/2015	REPAIRED LENSES	0.50
2015032975	MAINTENANCE ODW INT. LIGHTING	AREA 4 RM 21 HAS A SAGGING/BUCKLING CEILING LIGHT COVER	AREA 4	3/11/2015	REPAIRED LOOSE LENS	0.50
2015032997	MAINTENANCE ODW INT. LIGHTING	AREA 4 POLES 4M AND 4P HAVE SAGGING/BUCKLING CEILING LIGHT COVERS	AREA 4	3/11/2015	REPAIRED LOOSE LENSES. LENS SOUTH OF POLE 4M BUCKLED. TRIMMED TO FIT SECURELY AND REINSTALLED.	1.00
2015032998	MAINTENANCE ODW INT. LIGHTING	AREA 3 (2 LIGHT PANELS FROM POLE 5J) LIGHT COVER LOOSE	AREA 3	3/11/2015	REPAIRED LENS COVER	0.05
2015033051	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 6 SUMP PUMP ALARM SOUNDED.	AREA 6	3/12/2015	CYCLED EACH PUMP THREE TIMES. BOTH PUMPS ARE PUMPING AND ALTERNATING CORRECTLY. FLOATS ARE WORKING CORRECTLY. SOMEONE BUMPED SWITCH?	0.50
2015033065	MAINTENANCE ODW BLDG/EQUIP. REP	CSPC RM 201 DOOR KNOB ON BREAK ROOM HAS COME OFF	CSPC RM 201	3/13/2015	REINSTALLED DOOR KNOB	0.50
2015033067	MAINTENANCE ODW BLDG/EQUIP. REP	A PLANT COOLING TOWER ENCLOSURE SHEET METAL AT BOTTOM OF SCREENING IS LOOSE	A PLANT COOLING TOWER	3/13/2015	MADE SURE THE SHEET METAL IS SECURE ALL AROUND COOLING TOWER. SCREWS WERE ADDED AS NEEDED TO SECURE.	1.00
2015033070	MAINTENANCE ODW GATE/FENCE	GATE 5 ENTRANCE GATE WILL NOT OPEN/CLOSE	GATE 5	3/13/2015	GATE OPERATORS ARE WORKING CORRECTLY. FOUND "OPEN" COMMAND RELAY ENERGIZED, INDICATING SIGNAL FROM SECURITY PANEL WAS BEING SENT TO ENTRANCE GATE TO KEEP IT OPEN. SECURITY RELEASED COMMAND. NOW GATE FUNCTIONS NORMALLY.	1.00
2015033094	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R 35 TOILET SEAT IS BROKEN	M'S R/R 35	3/13/2015	REPLACED BROKEN TOILET SEAT	0.50
2015033105	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 3 RAMP - HAS TORN RUBBER	AREA 3 RAMP	3/13/2015	REMOVED LOOSE PIECE OF RUBBER. REPLACED WITH NEW.	1.50
2015033124	MAINTENANCE ODW INT. LIGHTING	RM 31 BETWEEN PODS 36 AND 37 LIGHT FLICKERING	RM 31	3/16/2015	REPLACED BALLAST AND LAMPS	0.50
2015033126	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 126 BROKEN FLOOR TILE	CHILDCARE RM 126	3/16/2015	REPLACED FLOOR TILE	0.50
2015033145	MAINTENANCE ODW TEMPERATURE COLD	RM 39 TOO COLD	RM 39	3/16/2015	BOILERS NOT ON DUE TO OUTDOOR AIR TEMP (71 DEG). REHEAT NOT AVAILABLE. SPACE TEMP IS 71.7 DEG.	0.50
2015033147	MAINTENANCE ODW CEILING TILE	AREA 1 RM 600 BEHIND GLASS SECURITY DOORS CEILING TILES HAVE WATER STAINS	AREA 1 RM 600	3/16/2015	REPLACED TILES	0.50

2015033155	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 SINK STOPPED UP	W'S R/R 600	3/16/2015	LAST SINK WAS CLOGGED. PLUNGED NUMEROUS TIMES. RAN WATER CONTINUOUSLY. CLEARED CLOG.	0.50
2015033189	MAINTENANCE ODW KITCHEN EQUIP	COURTYARD CANTEEN LIGHTS OUT UNDER HOOD	COURTYARD CANTEEN	3/17/2015	REPLACED BULBS	0.50
2015033190	MAINTENANCE ODW TEMPERATURE HOT	EXTRACTING AREA 7 TOO HOT	EXTRACTING AREA 7	3/17/2015	LOWERED SPACE SETPOINT FROM 72.5 DEG TO 71 DEG	0.50
2015033191	MAINTENANCE ODW CEILING TILE	AREA 1 POLE 8K CEILING TILES NEED REPLACED RIGHT BEFORE ENTERING MAILROOM	AREA 1 POLE 8K	3/17/2015	REPLACED THREE TILES. ONE SOUTH OF 8K AND TWO NORTH OF 8K. PATCHED HOLE IN ROOF.	1.50
2015033194	MAINTENANCE ODW PLUMBING	W'S A309 LAST SINK - PIPE DRIPPING	W'S A309	3/17/2015	TIGHTENED COMPRESSION FITTINGS TO STOP LEAK	0.50
2015033208	MAINTENANCE ODW CEILING TILE	POLES 6V AND 7V CEILING TILES APPEAR TO BE WET	POLES 6V AND 7V	3/17/2015	INSTALLED DRIP PAN. FOUND AND PATCHED 2 HOLES IN ROOF. REPLACED CEILING TILE.	3.00
2015033227	MAINTENANCE ODW BLDG/EQUIP. REP	DOOR 21 CANOPY SUPPORT LEG BENT	DOOR 21 CANOPY	3/17/2015	REPAIRED AND INSTALLED CANOPY LEG. ELSMERE IRONWORKS: \$166.00	3.00
2015033233	MAINTENANCE ODW INT. LIGHTING	ROOM B200A POLE 5BB CEILING LIGHTS OUT. BALLASTER MADE A "NOISE" AND ALL FOUR LIGHT BULBS IN ONE FIXTURE WENT OUT.	B200A	3/18/2015	REPLACED BALLAST AND FOUR LAMPS	0.75
2015033234	MAINTENANCE ODW GATE/FENCE	GATE 5 WILL NOT OPEN/CLOSE	GATE 5	3/18/2015	INVESTIGATED INOPERABLE GATE. PROBLEM WITH SECURITY SYSTEM.	1.00
2015033248	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #5 TOILET CLOGGED	W'S R/R 306	3/18/2015	UNCLOGGED WITH PLUNGER	0.50
2015033249	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #4 TOILET CLOGGED	W'S R/R B211	3/18/2015	UNCLOGGED WITH PLUNGER	0.50
2015033250	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 #14 TOILET CLOGGED	W'S R/R 1003	3/18/2015	UNCLOGGED WITH PLUNGER	0.50
2015033251	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 126 NORNER OF GREEN TILE (LOCATED UNDER SMALL TABLE NEAR ENTRY DOOR) IS MISSING	CHILDCARE RM 126	3/18/2015	REMOVED OLD BROKEN TILE AND REPLACED WITH NEW.	1.00
2015033259	MAINTENANCE ODW BLDG/EQUIP. REP	DOCK DOOR A BLDG - BUMP SWITCH CABLE IS BAD	DOCK DOOR A BLDG	3/18/2015	REPLACED BUMP SWITCH CABLE	1.00
2015033279	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	3/19/2015	REPLACED 12 LIGHT BUBLS AND VACUUMED 4 LIGHT FIXTURES	1.00
2015033280	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	3/19/2015	REPLACED BULBS	0.50
2015033290	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #1 CLOGED	M'S R/R B309	3/19/2015	CLEARED CLOG WITH PLUNGER	0.50
2015033333	MAINTENANCE ODW WATER FOUNTAIN	AREA 11 POLE 5X WATER FOUNTAIN DRAIN CLOGGED	AREA 11	3/20/2015	SOMEONE Poured AN UNKNOWN SUBSTANCE INTO WATER FOUNTAIN DRAIN CAUSING A CLOG. VACUUMED OUT DRAIN WITH SHOP VAC. (W10-021-11)	1.00
2015033360	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 FIRST STALL IS CLOGGED	M'S R/R B309	3/20/2015	PLUNGED TOILET. OK.	0.50
2015033373	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	3/23/2015	REPLACED 16 LIGHTS	0.75
2015033374	MAINTENANCE ODW INT. LIGHTING	RM 815 LIGHTS OUT	RM 815	3/23/2015	REPLACED FOUR LIGHT BULBS	0.50
2015033375	MAINTENANCE ODW INT. LIGHTING	NORTH SWITCH GEAR OVERHEAD LIGHTS OUT	NORTH SWITCH GEAR	3/23/2015	REPLACED TWO LIGHT BULBS	0.50
2015033376	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 LIGHTS OUT	W'S R/R A1003	3/23/2015	REPLACED SIX LIGHTS	0.50
2015033377	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	3/23/2015	REPLACED FIVE LIGHTS	0.50
2015033378	MAINTENANCE ODW PLUMBING CLOG	SECURITY RM 201 SINK CLOGGED	SECURITY RM 201	3/23/2015	SNAKED DRAIN	0.50
2015033379	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHT OUT IN HALLWAY GOING TO THE HANDICAP RAMP	MAG HALL	3/23/2015	REPLACED LAMP AND CLEANED FIXTURE	0.50
2015033404	MAINTENANCE ODW INT. LIGHTING	CLOSET 601 LIGHT OUT	CLOSET 601	3/23/2015	REPLACED THE CFL	0.50
2015033405	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 #4 TOILET STOPPED UP	M'S R/R A1005	3/23/2015	PLUNGED TOILET. OK.	0.50
2015033417	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 TOILET CLOGGED	W'S R/R B211	3/23/2015	PLUNGED TOILET. FLUSHED. OK.	0.50
2015033475	MAINTENANCE ODW PLUMBING CLOG	MAG HALL #1 TOILET CLOGGED	MAG HALL 34	3/24/2015	UNCLOGGED WITH PLUNGER	0.50
2015033479	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 CLOGGED	W'S R/R 306	3/24/2015	PLUNGED TOILET. FLUSHED. OK.	0.50
2015033519	MAINTENANCE ODW FLOOR TILE	AREA 1 NORTH OF 8K FLOOR TILE LOOSE	AREA 1	3/24/2015	READJUSTED FLOOR TILE STAND	0.50
2015033533	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP TOILET CLOGGED	W'S R/R 34	3/25/2015	PLUNGED TOILET. FLUSHED. OK.	0.50
2015033535	MAINTENANCE ODW INT. LIGHTING	MAG HALL LOBBY - LIGHTS OUT	MAG HALL	3/25/2015	REPLACED MINE LITE BULBS IN LOBBY AREA	0.75
2015033537	MAINTENANCE ODW CEILING TILE	RM 815 - CRACKED CEILING TILE	RM 815	3/25/2015	REPLACED WITH NEW	0.50
2015033538	MAINTENANCE ODW INT. LIGHTING	RM 815 - LIGHT LENS COVER CRACKED	RM 815	3/25/2015	REPLACED WITH NEW LENS	0.50
2015033539	MAINTENANCE ODW BLDG/EQUIP. REP	RM 700J - DUSTY IN COMPRESSOR RM	RM 700J	3/25/2015	VACUUMED ALL AROUND ROOM AND REPLACED EXHAUST FAN FILTER	0.75
2015033540	MAINTENANCE ODW CEILING TILE	AREA 7 - TWO CEILING TILES NEED REPLACED	AREA 7	3/25/2015	REPLACED 2 CEILING TILES	0.50
2015033542	MAINTENANCE ODW SAFETY ISSUE	Clean Maintenance shop. Old Child Care ceiling tile has been on the bench for over a month. Salt spreaders need to be put away. The entilre area needs to be cleaned and maintained at all times as per the contract requirments.		3/25/2015	CLEANED UP MAINTENANCE SHOP	0.25
2015033543	MAINTENANCE ODW SAFETY ISSUE	Shovel has been sitting in the middle of the sidewalk next to the salt bin for sometime. Put shovel away before someone gets hurt.	salt bin	3/25/2015	DONE.	0.25
2015033563	MAINTENANCE ODW BLDG/EQUIP. REP	COURTYARD NEAR LOCKER ROOM - SPILL	COURTYARD	3/25/2015	MOPPED UP LIQUID	0.50
2015033567	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET CLOGGED	M'S R/R A308	3/25/2015	PLUNGED. FLUSHED. OK.	0.50
2015033569	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #3 AND #4 CLOGGED	M'S R/R B309	3/25/2015	FLUSHED #3 IT IS OK. PLUNGED #4 OK.	0.50
2015033571	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 LAST TOILET CLOGGED	M'S R/R 1005	3/25/2015	PLUNGED TOILET. OK.	0.50
2015033595	MAINTENANCE ODW PLUMBING CLOG	# 8 COMMODOE CLOGGED	W'S RR A306	3/26/2015	UNCLOGGED COMMODOE #8	0.50
2015033603	MAINTENANCE ODW DOOR	EAST LOBBY DOOR WILL NOT CLOSE COMPLETELY	MAG HALL LOBBY	3/26/2015	RAISED DOOR	0.50
2015033604	MAINTENANCE ODW INT. LIGHTING	LITE OUT IN RESTROOM	M'S R/R 35	3/26/2015	REPLACED TWO LIGHT BULBS	0.50
2015033622	MAINTENANCE ODW LEAKS	RM 17 SR OPERATIONS MANAGER'S OFFICE - WATER IS DRIPPING AROUND THE WINDOW	RM 17	3/26/2015	3-26-15: CHECKED AREA. NO STAINED CEILING TILE. WATER MARK ON DESK AND PAPERS HAD BEEN WET. NOT WET NOW.L 3-28-15: CHECKED AREA AGAIN. NOT WET.	1.00
2015033634	MAINTENANCE ODW CLOCKS	CONTROL CENTER DIGITAL CEILING MOUNTED CLOCK NOT OPERATING CORRECTLY	CONTROL CENTER	3/26/2015	REPLACED CLOCK WITH NEW UNIT FROM STOCK	1.00

2015033649	MAINTENANCE ODW INDOOR AIR QUAL	POLES 8D THROUGH 8H - HUMIDITY LEVEL IS MAKING CHECKS STICK TOGETHER	POLES 8D THRU 8H	3/26/2015	RAINING TODAY AND ON OUTSIDE AIR. CANNOT REDUCE HUMIDITY WITHOUT RAISING DRY BULB TEMP, WHICH WILL CAUSE MORE COMPLAINTS	0.50
2015033650	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #2 CLOGGED	M'S R/R B309	3/26/2015	PLUNGED TOILET	0.50
2015033651	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A1003 DOOR OFF OF CABINET	W'S R/R A1003	3/26/2015	REATTACHED DOOR. OK.	0.50
2015033654	MAINTENANCE ODW UTILITY WORK	DOCK'S TORNADO BLUE STROBE LIGHT NEEDS LOWERED	DOCK	3/26/2015	LOWERED BLUE STROBE 24"	2.00
2015033664	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 10 LIGHTS OUT	MAG HALL RM 10	3/27/2015	REPLACED LAMPS AND CLEANED LENS COVER	0.50
2015033688	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 6 8P ALARM IS SOUNDING	AREA 6	3/27/2015	WHEN I CHECKED PUMP CONTROLS, I SAW THAT PUMP #1 WAS TURNED OFF. THE LAG PUMP WAS TURNED ON BUT THE ALARM SOUNDED. TURNED PUMP #1 ON AND CYCLED LEAD AND LAG TWICE. BOTH PUMPS ARE WORKING.	0.50
2015033693	MAINTENANCE ODW FLOOR TILE	N BREEZEWAY, WEST SIDE - FLOOR TILE HAS POPPED UP	N BREEZEWAY	3/27/2015	3-27-15: PLACED CONE ON TILE. 3-28-15: REPLACED FLOOR TILE WITH NEW.	1.50
2015033701	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 HANDICAP TOILET CLOGGED	W'S R/R A309	3/27/2015	UNCLOGGED THE COMMODOE	0.50
2015033713	MAINTENANCE ODW PLUMBING	M'S R/R A403 URINAL WILL NOT FLUSH	M'S R/R A403	3/30/2015	REPLACED FLUSH HEAD	0.50
2015033714	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	3/30/2015	REPLACED 8 LIGHT BULBS AND VACUUMED 2 LIGHT LENSES	0.75
2015033715	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	3/30/2015	REPLACED 4 LIGHT BULBS	0.50
2015033716	MAINTENANCE ODW DOOR	MAG HALL AUTO DOOR EXTERIOR BUTTON NOT OPENING DOOR	MAG HALL 34	3/30/2015	REPLACED BATTERY	0.50
2015033717	MAINTENANCE ODW PLUMBING	W'S R/R 34 FAUCET WILL NOT STOP RUNNING	W'S R/R 34	3/30/2015	REPLACED SOLENOID AND BATTERIES	1.00
2015033721	MAINTENANCE ODW ELECTRICAL	RM 33 SECOND LIGHT SWITCH ON THE LEFT IS NOT WORKING PROPERLY.	RM 33	3/30/2015	REPLACED THREE WAY LIGHT SWITCH	1.00
2015033723	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET CLOGGED	M'S R/R B309	3/30/2015	CLEARED CLOGGED COMMODOE	1.00
2015033739	MAINTENANCE ODW INT. LIGHTING	POLE 6GG HAS A LOOSE LIGHT LENS	POLE 6GG	3/30/2015	PUT LIGHT LENS BACK IN PLACE	0.50
2015033740	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 TOILET CLOGGED	W'S R/R 306	3/30/2015	PLUNGED, FLUSHED, OK.	0.50
2015033749	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 CLOGGED	W'S R/R B211	3/30/2015	PLUNGED, FLUSHED, OK	0.50
2015033774	MAINTENANCE ODW INT. LIGHTING	AREA 3 WEST LIGHT OUT OVER CUBICLE 18	AREA 3 WEST	3/31/2015	REPLACED LAMPS	0.50
2015033776	MAINTENANCE ODW INT. LIGHTING	AREA 4 NEAR POLE 4Q LOOSE LIGHT COVER	AREA 4	3/31/2015	REPAIRED LENS COVERS	0.50
2015033777	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 130 SINK #2 CLOGGED	CHILDCARE RM 130	3/31/2015	SNAKED DRAIN	0.50
2015033783	MAINTENANCE ODW WATER FOUNTAIN	CHILDCARE PK RM WATER CONSTANTLY RUNNING FROM FOUNTAIN	CHILDCARE PK RM	3/31/2015	REPLACED CARTRIDGE	0.75
2015033784	MAINTENANCE ODW TEMPERATURE HOT	TRAINING RM 50 TOO HOT	RM 50	3/31/2015	ADJUSTED TEMP	0.50
2015033791	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 35 TOILET STOPPED UP	M'S R/R 35	3/31/2015	PLUNGED, FLUSHED, OK.	0.50
2015040506	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 35 TOILET CLOGGED	MAG HALL 35	4/1/2015	UNCLOGGED WITH PLUNGER	0.50
2015042282	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R 1003 CABINET DOOR OFF OF HINGE	W'S R/R 1003	4/2/2015	PUT DOOR HINGE BACK ON TRACK	0.50
2015042315	MAINTENANCE ODW INT. LIGHTING	RM B211 (BACK SIDE) OF ROOM LIGHT OUT	RM B211	4/2/2015	REPLACED LAMPS IN RECESSED FIXTURES	0.50
2015042345	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #3 CLOGGED	M'S R/R B309	4/2/2015	PLUNGED, FLUSHED, OK.	0.50
2015042346	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 #12 TOILET SEAT BROKEN	W'S R/R B211	4/2/2015	REPLACED BROKEN TOILET SEAT WITH NEW TOILET SEAT	0.50
2015042367	MAINTENANCE ODW INT. LIGHTING	M'S R/R 602 LIGHTS OUT IN ENTRANCE	M'S R/R 602	4/3/2015	REPLACED 2 LIGHT BULBS IN CAN LIGHT	0.50
2015042371	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 126 - FLOOR TILE NEEDS REPLACED. THERE'S A HOLE IN IT FROM THE EXTERMINATOR.	CHILDCARE RM 126	4/3/2015	REPLACED WITH NEW FLOOR TILE	0.75
2015042809	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 4 TOILET READY TO OVERFLOW	MAG HALL 4	4/3/2015	UNCLOGGED WITH PLUNGER.	0.50
2015042811	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT BETWEEN POLES 6W AND 7W	AREA 10	4/3/2015	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2015042812	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 CLOGGED	M'S R/R B309	4/3/2015	UNCLOGGED WITH PLUNGER	0.50
2015042813	MAINTENANCE ODW DOOR	DOOR LEADING INTO AREA 7 IS "HITTING A LITTLE HARD"	AREA 7	4/3/2015	RUBBER BUMPS AT TOP OF DOORFRAME THAT KEEPS DOOR FROM HITTING METAL TO METAL WAS MISSING. INSTALLED NEW RUBBER BUMPER. 4-7-15: REMOVED BUMPER AND ADJUSTED DOOR TO CLOSE PROPERLY.	1.00
2015042815	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #1 AND #2 CLOGGED	M'S R/R B309	4/3/2015	CLEARED TWO CLOGGED COMMODOES	1.00
2015042816	MAINTENANCE ODW INT. LIGHTING	HALLWAY 18 WHERE CARPET MEETS TILE - OVERHEAD LIGHTS FLICKERING	HALLWAY 18	4/3/2015	REPLACED 4 LIGHT BULBS AND DUSTED OFF LIGHT LENS	0.50
2015042885	MAINTENANCE ODW DOOR	ACCORDIAN HINGE PROTECTOR UNATTACHED AT BOTTOM HALF OF DOOR	CHILDCARE RM 103	4/6/2015	PUT HINGE PROTECTOR BACK TOGETHER	0.50
2015042886	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 109 LIGHTS OUT	CHILDCARE RM 109	4/6/2015	REPLACED 6 BULBS	0.50
2015042887	MAINTENANCE ODW INT. LIGHTING	CHILDCARE HALL BATHROOM LIGHTS OUT	CHILDCARE HALL BATHROOM	4/6/2015	REPLACED LIGHT	0.50
2015042917	MAINTENANCE ODW INT. LIGHTING	POLE 4U - LIGHTS ARE OUT ON RAISED FLOORING (NEAR 4U)	POLE 4U	4/6/2015	REPLACED BALLAST AND LAMPS	0.50
2015042919	MAINTENANCE ODW CEILING TILE	POLE 4M (SIX TILES FROM THE LEFT) HAS STAINED OR BROKEN TILES; 40 HAS THREE STAINED TILES	POLES 4M AND 40	4/6/2015	REPLACED TILES	1.00
2015042920	MAINTENANCE ODW CEILING TILE	SKYLIGHT CANTEEN - STAINED TILES ABOVE THE 7-UP MACHINE AND TO THE RIGHT OF THE SKYLIGHT CANTEEN	SKYLIGHT CANTEEN	4/6/2015	REPLACED 3 TILES	0.50
2015042934	MAINTENANCE ODW DOOR	M'S R/R 308 BATHROOM DOOR NOT OPENING/CLOSING PROPERLY	M'S R/R 308	4/7/2015	OPERATED DOOR. WORKING PROPERLY.	0.50
2015042962	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 #1 CLOGGED	W'S R/R 600	4/7/2015	PLUNGED, FLUSHED, OK.	0.50
2015042964	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #1 CLOGGED	M'S R/R B309	4/7/2015	PLUNGED, FLUSHED, OK.	0.50
2015042966	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 #1 CLOGGED	M'S R/R 810	4/7/2015	PLUNGED, FLUSHED, OK.	0.50
2015042993	MAINTENANCE ODW EXT. LIGHTING	LOBBY - OUTSIDE CAN LIGHTS ARE OUT	LOBBY - OUTSIDE	4/8/2015	REPLACED LAMPS.	0.50

2015042994	MAINTENANCE ODW RESTROOM FIXTURE	M/S R/R A602 HANDICAP STALL TOILET PAPER DISPENSER BROKEN	M/S R/R A602	4/8/2015	REPLACED DISPENSER	0.50
2015042995	MAINTENANCE ODW TEMPERATURE HOT	POLES 8D-8J TOO WARM	POLES 8D-8J	4/8/2015	TEMPS ARE NORMAL AT 73-74 DEG. HUMIDITY IS HIGH DUE TO HIGHER THAN NORMAL OUTDOOR HUMIDITY. WILL DROP WHEN CHILLER STARTS LATER TODAY.	0.50
2015043044	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #4 CLOGGED	W'S R/R 306	4/8/2015	UNCLOGGED COMMODORE	0.50
2015043045	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 CLOGGED	W'S R/R 306	4/8/2015	UNCLOGGED COMMODORE	0.50
2015043051	MAINTENANCE ODW PLUMBING CLOG	M/S R/R A308 TOILET ABOUT TO OVERFLOW	M/S R/R A308	4/8/2015	UNCLOGGED WITH PLUNGER	0.50
2015043071	MAINTENANCE ODW TEMPERATURE HOT	604 TOO HOT	604	4/9/2015	4-9-15 AND 4-10-15: FOUND LIEBERT 40 LOW CHARGE. ADJUSTED. OK.	2.00
2015043072	MAINTENANCE ODW PLUMBING	W'S R/R 1003 - TOILET CONTINUOUSLY FLUSHING	W'S R/R 1003	4/9/2015	CHANGED FLUSH HEAD. OK.	0.50
2015043078	MAINTENANCE ODW GATE/FENCE	CHILDCARE PLAYGROUND - REPAIR RUBBER HINGE BOOT ON METAL GATE (NEAR THE BUILDING)	CHILDCARE PLAYGROUND GATE	4/9/2015	REPLACED FINGER GUARD MEMBRANE	1.00
2015043080	MAINTENANCE ODW INT. LIGHTING	AREA 7 SEVERAL OVERHEAD LIGHTS OUT	AREA 7	4/9/2015	REPLACED 12 LIGHT BULBS AND VACUUMED FOUR LIGHT FIXTURES	1.00
2015043081	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A404 #3 TOILET SEAT BROKEN	W'S R/R A404	4/9/2015	REPLACED SEAT	0.50
2015043083	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE SWINGING EQUIPMENT - RUBBER BOOTS OVER THE UNIVERSAL JOINT ON THE SWINGING EQUIPMENT NEEDS REPLACED	CHILDCARE SWINGING EQUIPMENT	4/9/2015	REPLACED TORN RUBBER BOOT. SWINGSETMALL.COM \$24.95	1.00
2015043124	MAINTENANCE ODW PLUMBING	CHILDCARE RM 107 TEACHER SINK FAUCET IS DRIPPING	CHILDCARE RM 107	4/10/2015	REPLACED FAUCET. HOME DEPOT (MOEN): \$129.90.	1.00
2015043126	MAINTENANCE ODW PLUMBING	CHILDCARE RM 110 TEACHER'S SINK AND CHILDCREN'S SINK FAUCETS ARE DRIPPING	CHILDCARE RM 110	4/10/2015	REPLACED "O" RINGS IN GOOSE NECK ON BOTH SIDES	1.00
2015043127	MAINTENANCE ODW PAINTING	CHILDCARE RM 110 PAINT IS CHIPPING OFF WALL BEHIND BLUE COUCH. (THERE'S A POSTER OVER THE CHIPPING PAINT.)	CHILDCARE RM 110	4/10/2015	PATCHED WALL AFTER SCRAPING LOOSE PAINT. TWO COATS OF PAINT ON WALL.	1.50
2015043128	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 126 LIGHT OUT BY PICTURE WINDOW	CHILDCARE RM 126	4/10/2015	REPLACED SIX LIGHT BULBS IN TWO LIGHT FIXTURES	0.50
2015043129	MAINTENANCE ODW WATER FOUNTAIN	CHILDCARE RM 128 WATER FOUNTAIN ON KID'S SINK BY BACK DOOR IS LEAKING	CHILDCARE RM 128	4/10/2015	CHILDCARE ROOM 129: VALVE ON FOUNTAIN IS HOLDING AND IS NOT LEAKING. THE WATER ONLY RUNS DOWN THE FOUNTAIN WHEN THE VALVE IS NOT FULLY DEPRESSED.	0.50
2015043130	MAINTENANCE ODW DOOR	CHILDCARE RM 128 ACCORDIAN FINGER-GUARD ON FRONT CLASS DOOR IS TORN	CHILDCARE RM 128	4/10/2015	REMOVED OLD FINGER-GUARD AND REPLACED	0.50
2015043131	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 130 BASEBOARD BY FRONT CLASSROOM DOOR IS COMING OFF AND BASEBOARD BY MIDDLE OF SPACE POSTER IS COMING OFF	CHILDCARE RM 130	4/10/2015	COMPLETED. REATTACHED.	1.00
2015043132	MAINTENANCE ODW DOOR	CHILDCARE RM 130 ACCORDIAN FINGER-GUARD ON BATHROOM DOOR BY FIRE DOOR IS TORN	CHILDCARE RM 130	4/10/2015	REMOVED OLD FINGER-GUARD AND REPLACED	0.50
2015043133	MAINTENANCE ODW PLUMBING CLOG	M/S R/R 35 TOILET ABOUT TO OVERFLOW	M/S R/R 35	4/10/2015	PLUNGED TOILET. OK.	0.50
2015043138	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 CLOGGED	W'S R/R 306	4/10/2015	UNCLOGGED THE COMMODORE	0.50
2015043143	MAINTENANCE ODW LEAKS	AREA 5 ROOF LEAK	AREA 5	4/10/2015	PATCHED ROOF. DRIP PAN STILL IN PLACE. (WILL REMOVE AFTER ANOTHER RAIN TO ENSURE ROOF REPAIR WAS SUCCESSFUL.)	1.50
2015043173	MAINTENANCE ODW DOOR	AREA 6 DOOR 1 WILL NOT CLOSE	AREA 6	4/13/2015	DOOR OFF-TRACK. PUT DOOR BACK ON TRACK AND CHECKED FOR PROPER OPERATION. OK.	0.50
2015043175	MAINTENANCE ODW BLDG/EQUIP. REP	JOHNSON ST. - SINKHOLE NEEDS FIXED	JOHNSON ST.	4/13/2015	FILLED HOLE. MATERIAL: 3 BAGS COST \$50.37	2.00
2015043178	MAINTENANCE ODW POWER OUTAGE	POLE 10M WHOLE ROW WITHOUT POWER	POLE 10M	4/13/2015	RESET BREAKER	0.50
2015043197	MAINTENANCE ODW INT. LIGHTING	RM 903 OVERHEAD LIGHTS OUT	RM 903	4/13/2015	REPLACED ONE LIGHT BALLAST AND EIGHT LIGHT BULBS	1.00
2015043198	MAINTENANCE ODW PLUMBING CLOG	M/S R/R 309 TOILET OVERFLOWING	W'S R/R 309	4/13/2015	W'S R/R A309 - REPLACED BATTERIES IN FLUSH HEAD FOR TOILET #3 AND CHECKED FOR PROPER OPERATION. OK.	0.50
2015043201	MAINTENANCE ODW INT. LIGHTING	M/S R/R 602 LIGHT LENS FALLING OFF	M/S R/R 602	4/13/2015	PUT COVER BACK ON TRACK AND REPLACED TWO LAMPS	0.50
2015043273	MAINTENANCE ODW ELECTRICAL	A7 - 011, 012, 013 DOES NOT HAVE POWER	A7 - 011, 012, 013	4/14/2015	RECONNECTED POWER	1.00
2015043276	MAINTENANCE ODW INT. LIGHTING	308 - BURNED OUT LAMP	308	4/14/2015	REPLACED LAMP	0.50
2015043277	MAINTENANCE ODW INT. LIGHTING	W'S R/R B302 LIGHT OUT IN FOYER	W'S R/R B302	4/14/2015	REPLACED BOTH LAMPS	0.50
2015043282	MAINTENANCE ODW EXT. LIGHTING	DOOR 21 ALCOVE LIGHTS OUT	DOOR 21 ALCOVE	4/14/2015	REPLACED LAMP	1.00
2015043283	MAINTENANCE ODW EXT. LIGHTING	S. BREEZEWAY & A4 BUILDING MOUNTED LIGHTS OUT	S. BREEZEWAY & A4	4/14/2015	REPLACED LAMPS. 4-21-15: CLEANED AND REPLACED 400 WATT LAMPS	3.00
2015043284	MAINTENANCE ODW EXT. LIGHTING	DOOR B3 BUILDING MOUNTED LIGHT OUT	DOOR B3	4/14/2015	REPLACED LAMP	0.50
2015043285	MAINTENANCE ODW EXT. LIGHTING	DOOR B1 BUILDING MOUNTED LIGHT OUT	DOOR B1	4/14/2015	REPLACED LAMP	0.50
2015043286	MAINTENANCE ODW EXT. LIGHTING	SWITCHGEAR ROLL-UP DOOR BUILDING MOUNTED LIGHT OUT	SWITCHGEAR ROLL-UP DOOR	4/14/2015	REPLACED LAMP	0.50
2015043287	MAINTENANCE ODW EXT. LIGHTING	GARDENER'S ROLL-UP DOOR BUILDING MOUNTED LIGHT OUT	GARDENER'S ROLL-UP DOOR	4/14/2015	INSTALLED NEW LAMP AND PHOTO CELL. 4-21-15: LIGHT IS WORKING OK.	2.00
2015043290	MAINTENANCE ODW PLUMBING CLOG	M/S R/R A4 TOILET CLOGGED	M/S R/R A4	4/14/2015	PLUNGED, FLUSHED, OK.	0.50
2015043292	MAINTENANCE ODW DOOR	RM B211 - ELECTRIC PEDESTRIAN DOOR BUTTON OUTSIDE ROOM NOT WORKING	RM B211	4/14/2015	REPLACED BATTERY AND ADJUSTED SWITCH SCREWS (WHICH WERE LOOSE). CHECKED FOR PROPER OPERATION. OK.	0.50
2015043293	MAINTENANCE ODW BLDG/EQUIP. REP	RM B314 - PDU HAS AUDIO ALARM	RM B314	4/14/2015		0.00
2015043313	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 34 TOILET #1 OVERFLOWING	MAG HALL 34	4/15/2015	UNCLOGGED WITH PLUNGER.	0.50
2015043315	MAINTENANCE ODW GATE/FENCE	DOOR 14, WALK NORTH TO THE FENCE. TOP TWO RAILS OF A SECTION OF FENCE HAS POPPED OUT.	DOOR 14 NORTH	4/15/2015	PUT FENCE RAILS BACK TOGETHER	0.50

2015043366	MAINTENANCE ODW TEMPERATURE COLD	RM 21 TOO COLD	RM 21	4/16/2015	TOO WARM OUTSIDE FOR BOILERS (60 DEG), SO NO REHEAT AVAILABLE. RAISING THE SETPOINT FOR THIS UNIT (13-3-4) WILL OVER-HEAT ALL OTHER SPACES IN MAG HALL. NO ACTION TAKEN.	0.50
2015043383	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #4 TOILET CLOGGED	M'S R/R B309	4/16/2015	UNCLOGGED THE COMMUNE	0.50
2015043397	MAINTENANCE ODW BLDG/EQUIP. REP	THREE PARKING SPACES WEST OF 4TH ST LOBBY PARKING LOT F - CONCRETE PARKING STOP BUMPER IS DAMAGED AND NEEDS REPLACED. (THIS IS AN RA SPOT.)	4TH ST LOBBY PARKING LOT F	4/16/2015	REPLACED STOP BUMPER WITH USED STOCK. 4/18/15: REPLACED PLASTIC BUMPER WITH CONCRETE.	2.00
2015043421	MAINTENANCE ODW BLDG/EQUIP. REP	B313 COMPUTER ROOM - LIEBERT 26 #1 COMPRESSOR CIRCUIT NEEDS CHARGED	B313	4/17/2015	CHARGED L-26 #1 CIRCUIT TO 18 DEG SUPER HEAT, CLEAR SIGHT GLASS.	4.00
2015043426	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A4 TOILET ABOUT TO OVER-FLOW	M'S R/R A4	4/17/2015	PLUNGED, FLUSHED, OK	0.50
2015043441	MAINTENANCE ODW DOOR	RC 6A DOCK AREA DOOR IS HARD TO CLOSE	RC 6A DOCK AREA	4/17/2015	RESET POWER TO DRIVE MOTOR. FUNCTIONING NORMALLY.	0.50
2015043466	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 POLES 8-D-8J TOO HOT	AREA 1	4/20/2015	SPACE TEMPS ARE BETWEEN 72.5 AND 73.5 DEG F. WITHIN CONTRACT REQUIREMENTS. NO CHANGE MADE.	0.50
2015043467	MAINTENANCE ODW TEMPERATURE HOT	AREA 7 EXTRACTING TOO HOT	AREA 7	4/20/2015	SPACE TEMP IS 71 DEG F. WITHIN CONTRACT REQUIREMENTS. NO CHANGE MADE.	0.50
2015043469	MAINTENANCE ODW INT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	4/20/2015	REPLACED 12 LIGHT BULBS	0.50
2015043471	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 #6 TOILET CLOGGED	W'S R/R A600	4/20/2015	UNCLOGGED THE COMMUNE	0.50
2015043526	MAINTENANCE ODW INT. LIGHTING	POLES 4E AND 4F BY OFFICE 300A SCREEN OVER LIGHT IS HANGING	POLES 4E AND 4F	4/21/2015	PUT BACK ON TRACK. SECURED.	0.50
2015043528	MAINTENANCE ODW INT. LIGHTING	POLE 10X LIGHTS OUT	POLE 10X	4/21/2015	REPLACED LIGHT BALLAST AND FOUR BULBS	1.00
2015043529	MAINTENANCE ODW INT. LIGHTING	COMPACTOR ROOM LIGHTS OUT	COMPACTOR RM	4/21/2015	REPLACED LIGHT BALLAST AND TWO BULBS	1.00
2015043534	MAINTENANCE ODW INT. LIGHTING	RAMP AT G3 AND G4 BY ROOM 305 - LIGHT OUT	RAMP AT G3 AND G4	4/21/2015	REPLACED BALLAST AND LAMPS	1.00
2015043536	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 TOILET STOPPED UP	W'S R/R 306	4/21/2015	PLUNGED, FLUSHED, OK	0.50
2015043554	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE SWINGING EQUIPMENT PROTECTIVE RUBBER BOOT COVERING UNIVERSAL JOINT IS RIPPED	CHILDCARE SWINGING EQUIPMENT	4/21/2015	REPLACED PROTECTIVE RUBBER BOOT. SWINGSETMALL.COM \$24.95	1.00
2015043555	MAINTENANCE ODW INT. LIGHTING	W'S R/R 404 LIGHTS OUT ABOVE SINKS	W'S R/R 404	4/21/2015	REPLACED LAMPS	0.50
2015043556	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 TOILET CLOGGED	W'S R/R 306	4/21/2015	UNCLOGGED TOILET	0.50
2015043558	MAINTENANCE ODW BLDG/EQUIP. REP	LIEBERT 26 BELT NEEDS TIGHTENED	LIEBERT 26	4/21/2015	TIGHTENED BELTS	0.50
2015043568	MAINTENANCE ODW INT. LIGHTING	POLE 4J LIGHT LENS HANGING	POLE 4J	4/21/2015	PUT BACK ON TRACK. SECURED. 4-27-25: REPLACED COVER.	1.00
2015043593	MAINTENANCE ODW PLUMBING	M'S R/R 1005 TOILET WILL NOT STOP FLUSHING	M'S R/R 1005	4/22/2015	TOILET #2: REPLACED 4 "A" BATTERIES IN FLUSH VALVE. TOILET #4: WAS CLOGGED AND CLEARED.	0.50
2015043594	MAINTENANCE ODW INT. LIGHTING	CHILDCARE R/R 109 LIGHT OUT	CHILDCARE R/R 109	4/22/2015	REPLACED COMPLETE LIGHT FIXTURE	0.75
2015043595	MAINTENANCE ODW DOOR	W'S R/R B211 DOOR WILL NOT CLOSE	W'S R/R B211	4/22/2015	REMOVED WIRE CAUGHT IN DOOR SWITCH FROM OUTSIDE DOOR BUTTON	0.50
2015043604	MAINTENANCE ODW ROOF LEAK	Flashing on elevated roof of Canteen A needs re-attached.		4/22/2015	4-27-15: CALLED IMBUS. NO RETURN CALL. 4-28-15: CALLED IMBUS AGAIN. DID CALL RETURN CALL. 4-29-15: MANUFACTURER'S REP, TOM CARTER, CAME TO ASSESS THE ISSUE. 5-1-15: PER (JASON EUBANK) APPLIED PEEL N' STICK ROOFING TO REMAINING NORTH-FACING RUN OF OPEN FLASHING UNTIL FUNDFS CAN BE PROCURED TO FIX ROOF.	7.00
2015043613	MAINTENANCE ODW INT. LIGHTING	LOBBY AT DOOR 18 A LIGHT IS OUT	LOBBY - DOOR 18	4/22/2015	REPLACED LAMPS	0.50
2015043614	MAINTENANCE ODW CEILING TILE	LOBBY AT DOOR 18 CEILING TILE IS FALLING	LOBBY AT DOOR 18	4/22/2015	PUT CEILING TILE BACK IN PLACE	0.50
2015043615	MAINTENANCE ODW PLUMBING	RM B101 DRAIN NEEDS SNAKED	RM B101	4/22/2015	4-22-15: TRIED TO SNAKE. THERE IS A SOLID OBSTRUCTION. SNAKE COULD ONLY GO 16" TO 24". 4-28-15: PER JAY WITHROW, NO FURTHER ACTION REQUIRED.	2.00
2015043654	MAINTENANCE ODW PLUMBING	W'S R/R 600 SINKS 2, 7 AND 9 - FAUCETS NOT PRODUCING WATER	W'S R/R 600	4/23/2015	TIGHTENED SEAT BOLTS IN STALLS 7, 10, 13 AND 15. REPLACED TOILET SEAT IN 8. REPLACED SEAT MOUNTING HARDWARE IN 9. REPLACED 4 "C" BATTERIES IN 3 SINKS (12 TOTAL).	1.50
2015043655	MAINTENANCE ODW PLUMBING	M'S R/R 602 LAST SINK - FAUCET NOT PRODUCING WATER	M'S R/R 602	4/23/2015	REPLACED 4 "C" BATTERIES	0.50
2015043663	MAINTENANCE ODW SAFETY ISSUE	The Material left over from the Print Room IDIQ project is blocking the path to the North Switch Gear and is a safety issue. The Material from this project should have been neatly stored in your space upon the completion of the Computer Room Project.		4/23/2015	REMOVED CART FROM RM 815 AND PUT IN OUR SHOP SPACE	0.50
2015043675	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R 600 COVE BASE IS PEELING OFF THE WALL AT BATHROOM ENTRANCE	W'S R/R 600	4/23/2015	COMPLETED. REATTACHED WITH POWER GRAB.	0.50
2015043691	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1002 #4 TOILET STOPPED UP	W'S R/R 1002	4/23/2015	CHECKED EACH STALL. NO CLOGGED TOILET. FLUSHED ALL TOILETS. NOTHING WAS STOPPED UP.	0.50
2015043701	MAINTENANCE ODW PLUMBING	W'S R/R A309 LAST TWO SINKS - FAUCETS NOT EXTRACTING WATER	W'S R/R A309	4/24/2015	REPLACED FOUR "C" BATTERIES IN BOTH SINKS.	1.00
2015043719	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #4 TOILET CLOGGED	M'S R/R 1005	4/24/2015	UNCLOGGED THE COMMUNE	0.50
2015043722	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 309 TOILET OVERFLOWING	W'S R/R 309	4/24/2015	REPLACED FOUR BATTERIES IN FLUSH VALVE AND ADJUSTED FLOW	0.50
2015043753	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B302 SMOKE HEAD	W'S R/R B302	4/27/2015	REPLACED SMOKE HEAD	1.00
2015043754	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS OUT	AREA 1	4/27/2015	REPLACED LAMPS	1.00
2015043755	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	4/27/2015	REPLACED LAMPS	1.00
2015043756	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST LIGHTS OUT	AREA 3 EAST	4/27/2015	REPLACED LAMPS	0.50

2015043764	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 MIDDLE STALL CLOGGED WITH PAPER TOWELS	W'S R/R 34	4/27/2015	CLEARED CLOGGED COMMUNE	0.50
2015043787	MAINTENANCE ODW PLUMBING	W'S R/R 306 #8 TOILET WILL NOT FLUSH	W'S R/R 306	4/27/2015	TOILET FLUSHES. NEEDED TO BE PLUNGED. FUNCTIONING NORMALLY.	0.50
2015043802	MAINTENANCE ODW	Clean maintenace shop. Parking stops should not be stored in maintenace shop. Upon completion of each project clean up all tools material and debris from the work areas and shop area.		4/28/2015	COMPLETE	0.25
2015043806	MAINTENANCE ODW INT. LIGHTING	W'S R/R A600 CANISTER LIGHTS - 1 IS OUT, 1 IS FLICKERING	W'S R/R A600	4/28/2015	REPLACED LAMPS	0.50
2015043833	MAINTENANCE ODW DOOR	DOOR 18 BY CONTROL CENTER IS MAKING NOISE	DOOR 18	4/28/2015	SCREW LOOSE HOLDING BOTTOM HINGE ON DOOR. REATTACHED AND TIGHTENED SCREWS. CHECKED DOOR FOR PROPER OPERATION. OK.	1.00
2015043836	MAINTENANCE ODW INT. LIGHTING	AREA 3 NEAR POLE 4G LIGHTS OUT	AREA 3	4/28/2015	REPLACED LAMPS	0.50
2015043837	MAINTENANCE ODW INT. LIGHTING	AREA 4 NEAR POLES 5Q AND 5R LIGHT COVER IS LOOSE	AREA 4	4/28/2015	SECURED COVER AND REPAIRED CLIP	0.50
2015043838	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 34 LIGHTS OUT	MAG HALL RM 34	4/28/2015	REPLACED LAMPS	0.50
2015043888	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 30 CEILING LIGHT IS OUT BUT SOMETIMES FLASHES AND BLINKS	MAG HALL RM 30	4/29/2015	REPLACED LAMPS	0.50
2015043889	MAINTENANCE ODW DOOR	W'S R/R A309 DOOR WILL NOT CLOSE ALL THE WAY	W'S R/R A309	4/29/2015	ADJUSTED LOOSE SCREWS ON HINGES.	0.50
2015043917	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 #12 TOILET CLOGGED	W'S R/R A600	4/29/2015	PLUNGED, FLUSHED, OK	0.50
2015043931	MAINTENANCE ODW INT. LIGHTING	POLE 6HH LIGHT COVER IS HANGING	POLE 6HH	4/30/2015	SECURED LIGHT COVER INTO PLACE	0.50
2015043932	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 109 RESTROOM LIGHT IS OUT	CHILDCARE	4/30/2015	TURNT LIGHT SWITCH ON. LIGHT IN RESTROOM IS OK. TURNT ON OTHER LIGHT SWITCH TO TURNT LIGHT ON IN ADJACENT CLOSET. ALL LIGHTS WERE IN WORKING CONDITION.	0.50
2015043934	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 110 ADULT SINK IS CLOGGED	CHILDCARE	4/30/2015	MM: PLUNGED. NEEDS SNAKED. VALVED OFF WATER. TD: SNAKED DRAIN. CLEANED AND FLUSHED.	1.00
2015043935	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE WINDOW/SILL ON RED WALL IN GYM IS CRUMBLING	CHILDCARE	4/30/2015	PATCHED WALL. PAINTED THREE COATS RED PAINT.	1.00
2015043936	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE STEPPING STONES IN COURTYARD BY RM 130 ARE CRUMBLING	CHILDCARE	4/30/2015	REMOVED OLD STEPPING STONE. CUT ASTROTURF TO FIT NEW. PLACED NEW DOWN. FILLED IN WITH ASTROTURF. THERE ARE 2 STONES REMAINING. UNABLE TO PURCHASE ADDITIONAL (IDENTICAL) STEPPING STONES AS THEY ARE NO LONGER AVAILABLE.	1.00
2015043937	MAINTENANCE ODW WATER FOUNTAIN	CHILDCARE DRINKING FOUNTAIN ON PLAYGROUND NEEDS REPAIRED	CHILDCARE	4/30/2015	REPLACED FOUNTAIN (\$690.00)	2.50
2015043990	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 35 TOILET CLOGGED	M'S R/R 35	4/30/2015	PLUNGED, FLUSHED, OK.	0.50
2015050580	MAINTENANCE ODW RESTROOM FIXTURE	CHILDCARE - TOILET SEAT COVER DISPENSER LOOSE IN THE TEACHER LOUNGE	CHILDCARE	5/1/2015	REPLACED MISSING WALL ANCHOR	0.50
2015050582	MAINTENANCE ODW TEMPERATURE COLD	AREA 1 POLE 8K TOO COLD	AREA 1 POLE 8K	5/1/2015	METASYS TEMP 72.9. TOOK THREE AREA TEMPS, 73, 73 AND 73. WITHIN RANGE. MADE NO ADJUSTMENTS.	0.50
2015050597	MAINTENANCE ODW BLDG/EQUIP. REP	Childcare grass padding on outside play ground has become a tripping hazard. In a few locations next to the swing set; the padding needs lifted and the tree roots cut out.		5/1/2015	LIFTED PAD. CUT THREE SECTIONS OF ROOT OUT.	2.00
2015050599	MAINTENANCE ODW BLDG/EQUIP. REP	Childcare outside play area grass padding under tire swing is worn and needs cut out and repaired.		5/1/2015	CUT, TRIMMED, GLUED DOWN ASTROTURF. PATCHED UNDER BOTH TIRE SWINGS.	20.00
2015051452	MAINTENANCE ODW BLDG/EQUIP. REP	Sink hole in Johnson lot needs repaired		5/1/2015	FILLED IN HOLE. USED THREE BAGS OF CONCRETE.	2.00
2015051453	MAINTENANCE ODW BLDG/EQUIP. REP	Sink hole in Lobby Lot west of the lobby next to catch basin		5/1/2015	PATCHED HOLE	1.00
2015051535	MAINTENANCE ODW WATER FOUNTAIN	POLE 8JJ WATER FOUNTAIN IS LEAKING	POLE 8JJ	5/1/2015	REPLACED DRAIN FITTING	1.00
2015052414	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	5/4/2015	REPLACED 12 LIGHT BULBS AND ONE LIGHT BALLAST	1.25
2015052415	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT BETWEEN POLES 4J AND 5J	AREA 3	5/4/2015	REPLACED LAMPS.	0.50
2015052416	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS OUT OUTSIDE RM 31	MAG HALL	5/4/2015	REPLACED BALLAST AND LAMPS	0.50
2015052417	MAINTENANCE ODW BLDG/EQUIP. REP	H LOT MULCH FIRE ON 4TH ST	H LOT	5/4/2015	EXTINGUISHED FIRE WITH 2, 5 GALLON BUCKETS OF WATER	0.50
2015052418	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 38 LIGHT OUT IN CONFERENCE ROOM	MAG HALL	5/4/2015	REPLACED BALLAST AND LAMPS	0.50
2015052427	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B302 #3 TOILET SEAT BROKEN	W'S R/R B302	5/4/2015	REPLACED BROKEN TOILET SEAT WITH NEW. USED LAST ONE. PUTTING IN AN ORDER FOR MORE TOILET SEATS.	0.50
2015052437	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 308 TOILET CLOGGED	M'S R/R 308	5/4/2015	UNCLOGGED WITH PLUNGER	0.50
2015052438	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE PLAYGROUND - GREEN SURFACE HAS COME LOOSE BY THE PLAYHOUSE ON LARGE PLAYGROUND AREA	CHILDCARE PLAYGROUND	5/4/2015	5-5-15: HAS TO BE WORKED ON OVER WEEKEND. (WE DO HAVE THE MATERIAL.) 5-9-15: CLEANED AND REPAIRED HOLE IN SURFACE.	4.00
2015052509	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 TOILET CLOGGED	M'S R/R 810	5/5/2015	UNCLOGGED WITH PLUNGER	0.50
2015052596	MAINTENANCE ODW INT. LIGHTING	LOBBY - SPOT LIGHT OUT	LOBBY	5/5/2015	REPLACED LAMP	0.50
2015053071	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #2 TOILET CLOGGED	M'S R/R B309	5/7/2015	UNCLOGGED THE COMMUNE. OK.	0.50
2015053075	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 38 LIGHT OUT	MAG HALL 38	5/7/2015	REPLACED LAMPS	0.50
2015053076	MAINTENANCE ODW DOOR	GATEHOUSE 3 DOOR NOT SHUTTING PROPERLY	GATEHOUSE 3	5/7/2015	SOUTH DOOR WORKING NORMALLY. ADJUSTED TOP GLIDE. OK.	0.50
2015053077	MAINTENANCE ODW INT. LIGHTING	SCAMPS LIGHTS OUT	SCAMPS	5/7/2015	RERPLACED FOUR LIGHT BULBS	0.50
2015053078	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	5/7/2015	REPLACED 12 LIGHT BULBS AND VACUUMED FOUR LIGHT FIXTURES	1.00

2015053079	MAINTENANCE ODW INT. LIGHTING	MAINTENANCE SHOP LIGHTS OUT	MAINTENANCE SHOP	5/7/2015	REPLACED LAMPS	0.50
2015053080	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE BASKETBALL GOAL PROTECTIVE COVER NEEDS SECURED	CHILDCARE	5/7/2015	SECURED THE COVER ON POLE WITH 3 ZIP TIES	0.50
2015053081	MAINTENANCE ODW BLDG/EQUIP. REP	SATELITTE CANTEEN SMOKE HEAD	SATELITTE CANTEEN	5/7/2015	CLEANED UP SMOKE HEAD WITH COMPRESSED AIR. OK.	0.50
2015053082	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE PLAYHOUSE PLASTIC SIDE WALL IS POPPING OUT AT BOTTOM	CHILDCARE PLAYHOUSE	5/7/2015	REMOVED PANEL, CLANED OUT DIRT AND REMOUNTED PANEL	3.00
2015053083	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 600 #14 CLOGGED	W'S R/R 600	5/7/2015	REMOVED A LARGE AMOUNT OF TOILET PAPER. FLUSHED. OK.	0.50
2015053096	MAINTENANCE ODW TEMPERATURE HOT	POLE 4Y TO HOT	POLE 4Y	5/7/2015	CHECKED UNIT, WORKING OK. LOWERED SET POINT 1 DEG. FROM 74 TO 73.	0.50
2015053121	MAINTENANCE ODW PLUMBING	W'S R/R A309 A TOILET WILL NOT FLUSH	W'S R/R A309	5/7/2015	THERE WAS NOTHING WRONG WITH TOILET. SOMEONE EMPTIED COFFEE AND CREAM IN BOWL. FLUSHED. OK.	0.50
2015053127	MAINTENANCE ODW PA SYSTEM	POLE 10X SPEAKER FOR PA SYSTEM CRACKLES	POLE 10X	5/7/2015	HAD SECURITY MAKE AN ANNOUNCEMENT AND CHECKED SPEAKER. WAS WORKING FINE.	0.50
2015053148	MAINTENANCE ODW INT. LIGHTING	AREA 3 WEST LIGHTS OUT NORTH OF POLE 4B	AREA 3 WEST	5/8/2015	REPLACED LAMPS	0.50
2015053150	MAINTENANCE ODW INT. LIGHTING	MSU LIGHT FLASHING	MSU	5/8/2015	REPLACED ONE BAD LIGHT BULB	0.50
2015053151	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 TOILET CLOGGED	W'S R/R B211	5/8/2015	UNCLOGGED THE COMMODOE	0.50
2015053184	MAINTENANCE ODW PLUMBING CLOG	B308 - FLOOR DRAIN BACKING UP WHEN URINAL AND SINKS IN B309 ARE USED	B308	5/8/2015	5-6-15: SNAKED DRAIN TO 4" TO CLEAR OBSTRUCTION. 5-7-15/5-8-15: CHECKED BOTH DAYS TO MAKE SURE DRAIN REMAINING CLEAR.	4.00
2015053185	MAINTENANCE ODW BLDG/EQUIP. REP	DOGHOUSE - SCREWS ARE MISSING FROM PAD LOCK	DOGHOUSE	5/8/2015	REPLACED MISSING SCREWS	0.50
2015053203	MAINTENANCE ODW TEMPERATURE HOT	RM 32 TOO HOT	RM 32	5/11/2015	CHECKED SPACE TEMP. 72.6 AND 73.1 DEG. NO ACTION TAKEN.	0.50
2015053212	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 TOILET CLOGGED	W'S R/R B211	5/11/2015	CHECKED TOILET #14. NO CLOG. CHECKED FAUCETS. FAUCET #7 NOT PRODUCING WATER. CHANGED FOUR C BATTERIES. OK.	0.50
2015053218	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 1003 #10 TOILET CLOGGED	W'S R/R 1003	5/11/2015	UNCLOGGED THE COMMODOE	0.50
2015053237	MAINTENANCE ODW UTILITY WORK	Replace sign at Gate 5. E-mail sent to Dave with the details		5/11/2015	COMPLETED PER JASON. A NEW WORK ORDER IS BEING ISSUED.	0.00
2015053248	MAINTENANCE ODW PLUMBING	M'S R/R 602 WATER CONTINUOUSLY RUNNING FROM FAUCET	M'S R/R 602	5/12/2015	REPLACED BATTERIES AND SOLENOID. OK.	1.00
2015053255	MAINTENANCE ODW PLUMBING	W'S R/R B211 TOILET WILL NOT FLUSH	W'S R/R B211	5/12/2015	PLUNGED TOILET. OK. NOTIFIED HOUSEKEEPING OF WATER ON FLOOR. FLUSHED ALL OTHER TOILETS. OK.	0.50
2015053258	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 700I TOILET STOPPED UP	M'S R/R 700I	5/12/2015	PLUNGED TOILET	0.50
2015053278	MAINTENANCE ODW PLUMBING	W'S R/R B302 TOILET #2 CONSTANTLY FLUSHING	W'S R/R B302	5/12/2015	REPLACED BATTERIES	0.50
2015053291	MAINTENANCE ODW BLDG/EQUIP. REP	B101 CARD READER IS HANGING FROM WALL	B101	5/12/2015	5-12-15: PER JAY WITHROW, CANCEL THIS TICKET.	0.00
2015053296	MAINTENANCE ODW INT. LIGHTING	AREA 4 R/R 403 LIGHT IS FLICKERING	R/R 403	5/12/2015	REPLACED CANISTER LIGHT LAMP	0.50
2015053353	MAINTENANCE ODW TEMPERATURE HOT	POLE 8F TOO HOT	POLE 8F	5/13/2015	LOWERED SPACE SET POINT TO 73 DEG	0.50
2015053390	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 #8 TOILET CLOGGED	W'S R/R 306	5/14/2015	UNCLOGGED THE COMMODOE	0.50
2015053395	MAINTENANCE ODW NOISE	RM 46-47 A THUMPING NOISE CAN BE HEARD FROM THE CEILING	RM 46-47	5/14/2015	CONTRACTORS WORKING IN MECHANICAL ROOM HANGING CONDUIT. (DID NOT HEAR ANY NOISE.)	0.50
2015053416	MAINTENANCE ODW INT. LIGHTING	RM 302 LIGHTS OUT AND LENS IS HANGING	RM 302	5/14/2015	REPLACED LENS AND REPLACED LAMPS	0.50
2015053417	MAINTENANCE ODW INT. LIGHTING	HALLWAY TO THE WEST OF RM 302 LIGHTS OUT LEADING UP TO MAG HALL	HALLWAY TO THE WEST OF RM 302	5/14/2015	REPLACED LAMPS	0.50
2015053426	MAINTENANCE ODW DOOR	AREA 7 DOOR 6A WILL NOT OPEN	AREA 7	5/15/2015	REMOVED POWER TO DOOR. RESET. OK.	0.50
2015053427	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 602 URINAL #1 OVERFLOWING	M'S R/R 602	5/15/2015	REPAIRED LEAKING FLUSH HEAD.	0.50
2015053428	MAINTENANCE ODW TEMPERATURE COLD	POLE 8K TOO COLD	POLE 8K	5/15/2015	TOOK THREE TEMPS OF AREA - 73.8, 73.6 AND 73.5. WITHIN RANGE, MADE NO ADJUSTMENTS.	0.00
2015053430	MAINTENANCE ODW WATER FOUNTAIN	MAG HALL DRINKING FOUNTAIN (EAST SIDE OF LOBBY DOORS) LEAKING COMPRESSOR OIL	MAG HALL	5/15/2015	REPLACED WATER COOLER. \$689.79	4.00
2015053440	MAINTENANCE ODW WATER FOUNTAIN	MAG HALL BY RM 5 - WATER FOUNTAIN NOT WORKING	MAG HALL	5/15/2015	5-15-15: CHECKED SUPPLY. POSSIBLE BLOCKAGE BETWEEN REGULATOR AND BUBBLER. VALVED OFF AND REASSEMBLED. 5-16-15: REMOVED REGULATOR AND FOUND BLOCKAGE. REPLACED SPRING REGULATOR. (PN# 102539 KULLY SUPPLY)	1.50
2015053451	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 123 (BEHIND CLASSROOM DOOR) PAINT IS MISSING/PEELING.	CHILDCARE RM 123	5/15/2015	5/24-5/25: INSTALLED DRYWALL, VAPOR BARRIER, PAINTED. 5/25: REPLACED RECEPTACLE, HUNG WATER FOUNTAIN. 5/23: CLEANED FLOOR AND MOPPED AROUND CONSTRUCTION AREA.	36.00
2015053495	MAINTENANCE ODW LEAKS	CHILDCARE RM 103 ROOF LEAK	CHILDCARE RM 103	5/18/2015	5-18-15: JIM BLACK & SONS CAME OUT TO INSPECT. REPAIRED PREVIOUS REPAIR. 5-17-15: REPLACED TILE. 5-15-15: PUT BUCKET UNDER LEAK.	1.50
2015053496	MAINTENANCE ODW DOOR	GATEHOUSE 2 THUMB WHEEL ON WEST SIDE DOOR WILL NOT LATCH THE LOCK	GATEHOUSE 2	5/18/2015	INSTALLED THUMB WHEEL BARREL BACK INTO DOOR	1.00
2015053497	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 IS CLOGGED	M'S R/R B309	5/18/2015	UNCLOGGED COMMODOE	0.50
2015053498	MAINTENANCE ODW INT. LIGHTING	M'S R/R 602 LIGHTS OUT	M'S R/R 602	5/18/2015	REPLACED LAMPS	0.50
2015053499	MAINTENANCE ODW INT. LIGHTING	W'S R/R 600 LIGHTS OUT	W'S R/R 600	5/18/2015	REPALCED LAMPS	0.50
2015053500	MAINTENANCE ODW BLDG/EQUIP. REP	TERRY'S CANTEEN "THANK YOU" DOOR ON TWO TRASH CANS DO NOT CLOSE.	TERRY'S CANTEEN	5/18/2015	REPLACED SHORT SCREWS WITH LONGER SCREWS	0.50
2015053501	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	5/18/2015	REPLACED 8 LIGHT BULBS AND VACUUMED 2 LIGHT LENSES	0.50

2015053502	MAINTENANCE ODW INT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	5/18/2015	REPLACED 11 LIGHT BULBS AND VACUUMED 3 LIGHT FIXTURES	1.00
2015053533	MAINTENANCE ODW UTILITY WORK	RM 604 NEEDS TWO SIGNS HUNG ON THE DOOR ON THE INSIDE OF ROOM: DO NOT EXIT (FIRST) AND EMERGENCY EXIT (SECOND)	RM 604	5/18/2015	HUNG SIGNS ON WEST DOOR FACTING AREA 1	0.50
2015053536	MAINTENANCE ODW BLDG/EQUIP. REP	DATA CONVERSION OFFICE 406, NEAR POLE 4R - HAS WHAT APPEARS TO BE MOLD IN OFFICE	OFFICE 406, NEAR POLE 4R	5/18/2015	TALKED TO MANAGER AND SHE SHOWED ME WHERE THE FLOOR HAD NOT BEEN CLEANED BEHIND AND UNDER FURNITURE (AFTER THE FLOOD LAST YEAR). NOTIFIED CATHY PUTTHOFF AND SHOWED HER THE DIRT UNDER THE FURNITURE.	0.50
2015053551	MAINTENANCE ODW BUILDING SIGNAGE	REPLACE SIGN AT GATE 5.	GATE 5	5/18/2015	REMOVED 8 SIGNS AND HUNG SIGN AT GATE 5	1.50
2015053566	MAINTENANCE ODW TEMPERATURE HOT	AREA 6 POLES P0, Q, R, S TOO HOT	AREA 6	5/19/2015	CHECKED TEMPS IN AERA 6. RESET TEMPS. LIEBERT L-5. FOUND 74 DEG. ADJUSTED TO 72 DEG.	1.00
2015053627	MAINTENANCE ODW INT. LIGHTING	RM 118 - NUMEROUS LIGHTS OUT	RM 118	5/20/2015	REPLACED 16 LAMPS	1.00
2015053631	MAINTENANCE ODW INT. LIGHTING	AREA 14 POLE 2JJ LIGHTS OUT	AREA 14	5/20/2015	REPLACED BALLAST AND FOUR LAMPS	1.25
2015053648	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 URINAL CLOGGED	M'S R/R B309	5/20/2015	PLUNGED URINAL. OK.	0.50
2015053658	MAINTENANCE ODW INT. LIGHTING	RM 813 OVERHEAD LIGHTS OUT	RM 813	5/21/2015	REPLACED 2 LIGHT BULBS AND CLEANED OFF LIGHT LENS	0.50
2015053659	MAINTENANCE ODW INT. LIGHTING	W'S R/R B811 OVERHEAD LIGHTS OUT	W'S R/R B811	5/21/2015	REPLACED TWO LIGHT BULBS	0.50
2015053665	MAINTENANCE ODW TEMPERATURE COLD	POLE 4Y TOOL COLD	POLE 4Y	5/21/2015	THIS IS IN AREA 11. THEY ARE TAKING THE UNIT DOWN. UNABLE TO MAKE AN ADJUSTMENT.	0.00
2015053666	MAINTENANCE ODW INT. LIGHTING	RM 80A OVERHEAD LIGTHS OUT IN HOUSEKEEPING OFFICE	RM 80A	5/21/2015	REPLACED 2 LIGHT BULBS	0.50
2015053667	MAINTENANCE ODW INT. LIGHTING	RM 803 LIGHTS OUT IN TRUCKER'S OFFICE	RM 803	5/21/2015	REPLACED FOUR LIGHT BULBS	0.50
2015053678	MAINTENANCE ODW BUILDING SIGNAGE	OUTSIDE MAG HALL WHERE THE PICNIC TABLES ARE NEEDS A "NO SMOKING" SIGN HUNG	OUTSIDE MAG HALL	5/21/2015	INSTALLED NEW SIGN	0.50
2015053686	MAINTENANCE ODW INT. LIGHTING	LIGHTS OUT BETWEEN B307 AND B308 IN HALLWAY	BETWEEN B307A ND B308	5/21/2015	REPLACED 12 LIGHT BULBS AND ONE LIGHT BALLAST	1.25
2015053687	MAINTENANCE ODW INT. LIGHTING	B3 LIGHTS OUT	B3	5/21/2015	3 LIGHT FIXTURES JUST INSIDE DOOR B3 ARE ON OLD LAZER PRINT'S LIGHTS. THEY WORK FINE IF OLD LAZER PRINT'S LIGHTS ARE ON.	0.50
2015053688	MAINTENANCE ODW INT. LIGHTING	LIGHTS OUT IN FRONT OF B314	B314	5/21/2015	REPLACED 8 LIGHT BULBS	0.50
2015053689	MAINTENANCE ODW INT. LIGHTING	LIGHTS OUT AT B2	B2	5/21/2015	REPLACED 8 LIGHT BULBS AND 1 LIGHT BALLAST	1.00
2015053690	MAINTENANCE ODW CEILING TILE	BROKEN CEILING TILE AT B2	B2	5/21/2015	PUT ONE CEILING TILE BACK INTO PLACE AND REPLACED ANOTHER	0.50
2015053691	MAINTENANCE ODW CEILING TILE	STAINED CEILING TILE SOUTH OF 7DD	7DD	5/21/2015	CHECKED ROOF, FOUND SMALL HOLE IN PATCH NEXT TO SUPPORT OR I-BEAM. CAULKED HOLE AND SURROUNDING AREA.	1.50
2015053706	MAINTENANCE ODW TEMPERATURE COLD	POLE 8K TOO COLD	POLE 8K	5/22/2015	CHECKED TEMP WITH HANDHELD THERMOMETER AT 72.2 DEG. SETPOINT IN COMPUTER AT 75 DEG. WITHIN LIMITS. NO ACTION TAKEN.	0.50
2015053707	MAINTENANCE ODW LEAKS	GATEHOUSE 3 ROOF LEAK	GATEHOUSE 3	5/22/2015	REPAIRED SEAMS AND BOLTS WITH MASTIC	4.50
2015053708	MAINTENANCE ODW LEAKS	GATEHOUSE 4 ROOF LEAK	GATEHOUSE 4	5/22/2015	REPAIRED ALL SEAMS AND BOLTS STICKING OUT OF ROOF MEMBRANE, APPLIED MASTIC. 5-28-15: ROOF LEAKING AROUND PERIMETER. USED ROOF TAR PATCH AND SEALED ENTIRE ROOF PERIMETER UP TO THE TOP OF THE FLASHING.	4.50
2015053709	MAINTENANCE ODW LEAKS	GATEHOUSE 5 ROOF LEAK	GATEHOUSE 5	5/22/2015	REPAIRED ALL SEAMS AND BOLTS STICKING OUT OF ROOF MEMBRANE, APPLIED MASTIC	1.50
2015053730	MAINTENANCE ODW INT. LIGHTING	POLE 4O THERE IS A BLINKING LIGHT ABOVE WORK STATIONS TWS 078 AND TWS 079	POLE 4O	5/22/2015	REPLACED FOUR LIGHT BULBS IN FIXTURE	0.50
2015053761	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 308 TOILET STOPPED UP	M'S R/R 308	5/26/2015	FLUSHED TOILET 3 TIMES. WORKS PROPERLY.	0.50
2015053762	MAINTENANCE ODW TEMPERATURE HOT	AREA 7 POLES L, M, N TOO HOT	AREA 7	5/26/2015	SPACE IS AT SETPOINT AT 71 DEG F, WHICH IS LOWER THAN CONTRACT REQUIREMENT OF 74 +/- F. NO CHANGE MADE.	0.50
2015053763	MAINTENANCE ODW TEMPERATURE HOT	RM 200 TOO HOT	RM 200	5/26/2015	LOWERED SPACE TEMP SETPOINT FROM 74.5 TO 72.5	0.50
2015053764	MAINTENANCE ODW PLUMBING CLOG	R/R 403 TOILET STOPPED UP	R/R 403	5/26/2015	REPLACED FLUSH HEAD WITH REBUILT. FLUSHES OK.	1.00
2015053774	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 TOILET #5 CLOGGED	W'S R/R A309	5/26/2015	UNCLOGGED THE COMMODE	0.50
2015053775	MAINTENANCE ODW INT. LIGHTING	AREA 8 OVERHEAD LIGHTS OUT	AREA 8	5/26/2015	REPLACED SIX LIGHT BULBS	0.50
2015053776	MAINTENANCE ODW INT. LIGHTING	AREA 11 POLE 5V LIGHT FIXTURE OUT	AREA 11	5/26/2015	REPLACED BALLAST, TWO SOCKETS AND FOUR LIGHT BULBS	1.25
2015053777	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS OUT	AREA 1	5/26/2015	REPLACED LAMPS	0.75
2015053778	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	5/26/2015	REPLACED LAMPS	1.50
2015053779	MAINTENANCE ODW FLOOR TILE	CHILDCARE TWO BROKEN FLOOR TILES	CHILDCARE	5/26/2015	REPLACED TILES	1.00
2015053814	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 SINK CLOGGED	W'S R/R A306	5/27/2015	TIGHTENED SEATBOLTS ON ALL 8 TOILETS. CLEARED CLOG IN #2. SNAKED DRAIN IN #1. REPLACED 4 "C" BATTERIES IN SINK #3.	1.50
2015053815	MAINTENANCE ODW FLOOR TILE	POLE 6U RAISED FLOOR TILE AND IS BENT	POLE 6U	5/27/2015	5-27-15: RESPONDED TO AREA, ASKED WHERE TILE WAS AND WAS TOLD THAT BATCHING CARTS HAD BEEN STAGED OVER IT. 6-1-15: REPLACED FLOOR TILE.	1.00
2015053816	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 #5 TOILET CLOGGED	W'S R/R A309	5/27/2015	UNCLOGGED THE COMMODE	0.50
2015053866	MAINTENANCE ODW INT. LIGHTING	AREA 6 RECEIPT AND CONTROL CEILING LIGHT OUT	AREA 6	5/28/2015	REPLACED 6 LIGHT BULBS AND 1 LIGHT BALLAST	1.00
2015053870	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 TOILET #1 CLOGGED	W'S R/R 34	5/28/2015	UNCLOGGED COMMODE	0.50
2015053871	MAINTENANCE ODW INT. LIGHTING	AREA 9 SEVERAL OVERHEAD LIGHTS OUT	AREA 9	5/28/2015	REPLACED 20 LIGHT BULBS AND VACUUMED FOUR LIGHT LENSES	1.00
2015053873	MAINTENANCE ODW BLDG/EQUIP. REP	Repair damaged drywall just above the base in the hallway next to room 200A	200A	5/28/2015	PATCHED AND PAINTED SPOT WITH 2 COATS OF PAINT	1.00

2015053877	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET #14 CLOGGED	W'S R/R B211	5/28/2015	UNCLOGGED COMMODE	0.50
2015053900	MAINTENANCE ODW LEAKS	We have 2 roof leaks in training room 111.	111	5/28/2015	REPLACED 4 CEILING PADS	2.00
2015053939	MAINTENANCE ODW TEMPERATURE HOT	CHILDCARE (WEST SIDE) TOO HOT	CHILDCARE	5/29/2015	RTU-1 HAD OVER-COOLED AND ENTERED HEATING MODE BRIEFLY. MONITORED UNIT OPERATION FOR ONE HOUR. UNIT IS COOLING AND OPERATING NORMALLY.	1.50
2015053940	MAINTENANCE ODW TEMPERATURE HOT	AREA 6 POLE 8P TOO HOT	AREA 6	5/29/2015	ADJUSTED LIEBERT 1 DEG LOWER. FOUND 72.5 DEG. END 71.5 DEG.	0.50
2015053941	MAINTENANCE ODW TEMPERATURE HOT	MDF 201C AREA 13 TOO HOT	MDF 201C	5/29/2015	FOUND RM COOL. ADJUSTED TEMP 2 DEG UP. FOUND 68 DEG. END 70 DEG.	0.50
2015053950	MAINTENANCE ODW INT. LIGHTING	SCAMPS SEVERAL LIGHTS OUT	SCAMPS	5/29/2015	REPLACED 12 LIGHT BULBS	0.50
2015053951	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 TOILET #2 CLOGGED	M'S R/R 1005	5/29/2015	UNCLOGGED THE COMMODE	0.50
2015053952	MAINTENANCE ODW INT. LIGHTING	W'S R/R 1003 OVERHEAD LIGHTS OUT	W'S R/R 1003	5/29/2015	REPLACED 5 LIGHT BULBS	0.50
2015053953	MAINTENANCE ODW INT. LIGHTING	W'S R/R A600 LIGHT LENS COVER NEEDS TO BE REINSTALLED	W'S R/R A600	5/29/2015	REINSTALLED LIGHT LENS COVER BACK INTO PLACE	0.50
2015060004	MAINTENANCE ODW DOOR	DOORS BETWEEN CAMPS AND SHIPPING AREA 7 ARE COMING OFF OF HINGE. REQUEST CHAINS TO BE PLACED ON DOORS INSTEAD OF PLASTIC DOOR STOPS.	SCAMPS	6/1/2015	INSTALLED ANCHOR BOLTS IN DOORS AND WALL.	1.00
2015061047	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	6/1/2015	REPLACED 8 LIGHT BULBS AND VACUUMED 2 LIGHT LENSES	0.50
2015061048	MAINTENANCE ODW INT. LIGHTING	W'S R/R 306 LIGHTS OUT	W'S R/R 306	6/1/2015	REPLACED 15 LAMPS	1.00
2015061243	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 HANDICAP TOILET CLOGGED	W'S R/R A309	6/1/2015	PLUNGED TOILET. FLUSHED. OK.	0.50
2015062564	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 12 THRESHOLD PLATE AT THE TOP OF RAMP GOING FROM NORTH BREEZEWAY IS WORN OUT AND STICKING UP	AREA 12	6/2/2015	INSTALLED NEW THRESHOLD	2.00
2015062565	MAINTENANCE ODW DOOR	ROOM 402 DOOR CLOSER IS SLAMMING SHUT (LEAKING OIL?)	ROOM 402	6/2/2015	DOOR CLOSER LEAKING OIL AND NOT WORKING PROPERLY. REPLACED CLOSER WITH NEW UNIT AND CHECKED FOR PROPER OPERATION. OK. (\$64.97)	2.00
2015062571	MAINTENANCE ODW PLUMBING CLOG	MAG HALL R/R 35 TOILET CLOGGED	MAG HALL R/R 35	6/2/2015	UNCLOGGED WITH PLUNGER	0.50
2015062572	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET OVERFLOWING	W'S R/R A309	6/2/2015	REPAIRED FLUSH HEAD	0.50
2015062573	MAINTENANCE ODW PLUMBING	M'S R/R A602 URINAL WILL NOT FLUSH	M'S R/R A602	6/2/2015	FOUND WATER TURNED OFF. ADJUSTED FLOW SO IT WILL NOT OVERFLOW.	0.50
2015062574	MAINTENANCE ODW EXT. LIGHTING	NO LIGHTING OUTSIDE OF DOOR 18	DOOR 18	6/2/2015	REPLACED LAMPS	0.50
2015062607	MAINTENANCE ODW ELECTRICAL	CUBICLE (POD) BY POLE 5G NO ELECTRIC ON LEFT SIDE	POLE 5G	6/2/2015	EMPLOYEE WAS TRYING TO PLUG INTO SYSTEM'S FURNITURE (CUBICLE WALL RECEPTACLE). NONE OF THESE CUBICLES HAVE BEEN WIRED FOR POWER. CONNECTED ANOTHER POWER STRIP TO THE PRIMARY POWER STRIP TO GIVE EMPLOYEE POWER.	0.50
2015062755	MAINTENANCE ODW PLUMBING CLOG	CLOGGED TOILET #5	W'S R/R A309	6/4/2015	UNCLOGGED TOILET	0.50
2015062861	MAINTENANCE ODW INT. LIGHTING	AREA 3 BETWEEN POLES 4K AND 4H (ENTITY DEPT.) LIGHT COVER IS HANGING	AREA 3	6/4/2015	SECURED LOOSE LATCH.	0.50
2015062862	MAINTENANCE ODW INT. LIGHTING	AREA 14 BY POLES 2JJ AND 2HH LIGHTS OUT	AREA 14	6/4/2015	REPLACED (8) LAMPS	1.00
2015062866	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 TOILET #3 CLOGGED	W'S R/R A309	6/4/2015	UNCOGGED COMMODE	0.50
2015062887	MAINTENANCE ODW DOOR	INSIDE DOOR BUTTON DOES NOT WORK.	W'S R/R A309	6/5/2015	REPLACED BATTERY	0.50
2015062888	MAINTENANCE ODW RESTROOM FIXTURE	COMMUNE SEAT IS BROKEN	W'S R/R A5	6/5/2015	REPLACED SEAT	0.50
2015062889	MAINTENANCE ODW INT. LIGHTING	LIGHTS OUT OVER CUBICLE A3080		6/5/2015	REPLACED LAMPS OVER CUBICLE A3080	0.50
2015062891	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET IN A308	M'S R/R A308	6/5/2015	CHECKED TOILET NO CLOG	0.50
2015062938	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET	M'S R/R A309	6/8/2015	PLUNGED TOILET UNCLOG	0.50
2015062939	MAINTENANCE ODW PLUMBING	SEWER ODOR	W'S R/R A600	6/8/2015	PUT TRAP OIL INTO DRAINS ORANGE SCENTED	0.50
2015062940	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET #1 STALL	M'S R/R A810	6/8/2015	UNCLOGGED TOILET	0.50
2015062941	MAINTENANCE ODW INT. LIGHTING	LIGHT FIXTURE OUT	AREA 5	6/8/2015	REPLACED BALLAST IN FIXTURE	1.00
2015062943	MAINTENANCE ODW ROOF LEAK	STAFF REPORTED IN AREA THAT THEY HEAR WATER DRIPPING ON CEILING TILE'	POLE 7DD	6/8/2015	RAISED CEILING TILE BUT COULD NOT FIND ANY LEAKS AND NO WET OR STAINED TILES	1.00
2015062944	MAINTENANCE ODW INT. LIGHTING	LIGHT BLINKING	ROOM A 21	6/8/2015	WATCHED LIGHTS FOR 10 MIN. TURNED LIGHTS OFF AND ON SEVERAL TIMES BUT DID NOT SEE ANY BLINKING.	0.50
2015062945	MAINTENANCE ODW INT. LIGHTING	LIGHT LENS IS ABOUT TO FALL.	ROOM A 21	6/8/2015	RESET LIGHT LENS	0.50
2015063026	MAINTENANCE ODW INT. LIGHTING	LIGHT OUT IN AREA 6	AREA 6	6/9/2015	REPLACED BALLAST	1.00
2015063047	MAINTENANCE ODW PLUMBING CLOG	FOUR SINKS STOP- UP	W'S R/R B 211	6/9/2015	UNCLOG (3) SINKS CHECKED ALL SINKS DRAINING OK.	2.00
2015063086	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET STALL #5	W'S R/R A309	6/10/2015	UNCLOG TOILET	0.50
2015063087	MAINTENANCE ODW INT. LIGHTING	SEVERAL LIGHTS OUT IN A309	W'S R/R A309	6/10/2015	REPLACED (18) LAMPS	1.00
2015063088	MAINTENANCE ODW INT. LIGHTING	LIGHTS OUT OVER DESK	A34	6/10/2015	REPLACED (2) LAMPS	0.50
2015063112	MAINTENANCE ODW PLUMBING CLOG	STALL (14) STOP UP STALL (16) WONT FLUSH	W'S R/R A1003	6/10/2015	UNCLOG TOILET IN STALL (14) REPLACED BATTERIES IN FLUSH HEAD STALL (16)	0.50
2015063118	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET	M'S R/R A700I	6/10/2015	UNCLOG TOILET	0.50
2015063135	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET STALL #5		6/11/2015	UNCLOG TOILET	0.50
2015063152	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET STALL #3	W'S R/R A404	6/11/2015	UNCLOG TOILET STALL #3	0.50
2015063154	MAINTENANCE ODW DOOR	S-HOOK ON OUR DOOR HAS TURNED AND THE CHAIN WILL NOT STAY HOOKED	ROOM A 700K	6/11/2015	INSTALLED EYE BOLTS IN PLACE OF S- HOOKS	0.50
2015063168	MAINTENANCE ODW TEMPERATURE HOT	TO HOT AT POLE 8P	POLE 8P	6/11/2015	LOWERED STEPOINT ON LIEBERT #5	0.50
2015063174	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET STALL #1	W'S R/R B 211	6/11/2015	UNCLOG TOILET AND CHECKED ALL TOILETS	0.50
2015063184	MAINTENANCE ODW PLUMBING CLOG	CLOG TOILET STALL #1	W'S R/R B 211	6/12/2015	UNCLOG TOILET STALL #1	0.50

2015063185	MAINTENANCE ODW INT. LIGHTING	SEVERAL LIGHTS OUT IN W'S R/R B 211	W'S R/R B 211	6/12/2015	REPLACED LAMPS ABOVE SINKS TOTAL OF (6)	1.00
2015063187	MAINTENANCE ODW INT. LIGHTING	(3) LIGHT BLUBS OUT IN AREA 6	AREA 6	6/12/2015	REPLACED LIGHTS IN AREA 6 CHECKED ALL OF THE AREA	0.50
2015063225	MAINTENANCE ODW PLUMBING CLOG	HANDICAP STALL TOILET CLOG.	W'S R/R A309	6/12/2015	UNCLOG TOILET	0.50
2015063251	MAINTENANCE ODW PLUMBING	W'S R/R B211 POSSIBLE LEAK IN WALL	W'S R/R B211	6/15/2015	DRAIN LEAKING ON SINK #2. REPLACED P-TRAP AND ALL DRAIN PIPE TO STACK. DRAIN ALSO CLOGGED. SNAKED DRAIN. CHECKED REPAIRS FOR LEAKS, OK. CHECKED ALL OTHER SINK DRAINS. OK.	9.00
2015063257	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 109 LIGHT OUT	CHILDCARE RM 109	6/15/2015	REPLACED LAMPS. REPLACED FIXTURE.	1.00
2015063258	MAINTENANCE ODW INT. LIGHTING	CHILDCARE R/R 130 LIGHT OUT	CHILDCARE R/R 130	6/15/2015	REPLACED LAMPS	0.50
2015063271	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET #16 LEAKING	W'S R/R A1003	6/15/2015	REPLACED O RING AND ADJUSTED WATER SUPPLY	0.50
2015063272	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE PLAYGROUND STUMP NEEDS CUT DOWN	CHILDCARE PLAYGROUND	6/15/2015	CUT STUMP. CLEANED UP MULCH FROM SW CORNER OF PLAYGROUND.	2.00
2015063273	MAINTENANCE ODW DOOR	SCAMPS HOOK ON DOOR IS HOOKING THE CARTS	SCAMPS	6/15/2015	INSTALLED I-BOLT INTO WOODEN PORTION OF DOOR.	0.50
2015063284	MAINTENANCE ODW ELECTRICAL	POLE 8F DOES NOT HAVE POWER	POLE 8F	6/15/2015	RESET BREAKER #53. PANEL PC 9G2.	0.50
2015063322	MAINTENANCE ODW DOOR	MAG HALL OFFICE 6B LOCK ON DOOR IS HARD TO OPEN	MAG HALL	6/16/2015	LUBRICATED LOCK PARTS TO FREE UP ACTION. LUBED HINGES TO ELIMINATE NOISE.	0.50
2015063346	MAINTENANCE ODW INT. LIGHTING	POLE 4C CEILING LIGHT IS FLICKERING	POLE 4C	6/16/2015	REPLACED LAMPS	0.50
2015063347	MAINTENANCE ODW TEMPERATURE COLD	RM 817 TOO COLD	RM 817	6/16/2015	CHECKED TEMP. ADJUSTED TEMP.	0.50
2015063356	MAINTENANCE ODW CEILING TILE	AREA 7, RM 700G, CANDLING RM, CEILING TILE IS HANGING	AREA 7	6/16/2015	CEILING TILE REPLACED. REPLACED TEE IN ROOF DRAIN.	4.00
2015063376	MAINTENANCE ODW PLUMBING	W'S R/R B211 SINK #1 WILL NOT STOP RUNNING	W'S R/R B211	6/16/2015	REPLACED SOLENOID	0.50
2015063378	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 #5 CLOGGED	W'S R/R A309	6/16/2015	UNCLOGGED WITH PLUNGER	0.50
2015063379	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHT FIXTURE AND SEVERAL LGIHTS OUT	AREA 5	6/16/2015	REPLACED BALLAST IN FIXTURE AND REPLACED LAMPS	2.50
2015063380	MAINTENANCE ODW BLDG/EQUIP. REP	DOCK - NEW BAY #1 LIFT NOT WORKING	DOCK	6/16/2015	FOUND BROKEN LIMIT SWITCH CAM ON DOCK DOOR OPERATOR PREVENTING LIFT OPERATION. REPAIRED LIMIT SWITCH CAM AND ADJUSTED FOR PROPER LIFT OPERATION WITH DOOR OPEN ONLY.	2.00
2015063395	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 HANDICAP STALL CLOGGED	W'S R/R A309	6/17/2015	CLEARED CLOGGED COMMODO. CHECKED OTHERS. CLEAR.	0.50
2015063404	MAINTENANCE ODW DOOR	MSU WEST DOOR AUTO DOOR SENSOR WILL NOT OPEN FROM HALLWAY INTO ROOM	MSU WEST DOOR	6/17/2015	CHECKED DOOR SETTINGS AND KEY SWITCH. ADJUSTED KEY SWITCH TO 1200. WORKS AGAIN	0.50
2015063412	MAINTENANCE ODW CLOCKS	RMS 46 AND 47 DIGITAL CLOCKS NOT WORKING	RMS 46, 47	6/17/2015	(NOT DIGITAL) REPLACED BATTERY	0.50
2015063413	MAINTENANCE ODW CLOCKS	RM 302 DIGITAL CLOCK NOT WORKING	RM 302	6/17/2015	(NOT DIGITAL) REPLACED BATTERY	0.50
2015063415	MAINTENANCE ODW INT. LIGHTING	POLE 3X LIGHT IS FLICKERING	POLE 3X	6/17/2015	REPLACED 12 LIGHT BULBS	0.75
2015063470	MAINTENANCE ODW WATER FOUNTAIN	WATER NOT COLD	CHILD CARE	6/18/2015	RESET GFI BREAKER. REASON FOR BEING TRIPPED, UNKNOWN. WILL MONITOR.	0.50
2015063480	MAINTENANCE ODW WATER FOUNTAIN	POLE 5X WATER FOUNTAIN HAS A CLOGGED DRAIN	POLE 5X	6/18/2015	VACUUMED OUT DRAIN, OK NOW.	0.50
2015063498	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 HANDICAP TOILET CLOGGED	W'S R/R A309	6/19/2015	PLUNGED, FLUSHED, OK.	0.50
2015063501	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 TOILET CLOGGED	W'S R/R A34	6/19/2015	PLUNGED, FLUSHED, OK.	0.50
2015063503	MAINTENANCE ODW PLUMBING	AHU 6-5 CHECK DRAIN	AHU 6-5 DRAIN	6/19/2015	DRAIN IS CLEAR. EVIDENCE OF WATER ON FLOOR AROUND UNIT FROM OVERNIGHT. NOW DRY. CHECKED SMOKE HEAD IN RESTROOM 600, NOW DRY. NO EVIDENCE OF FURTHER LEAKING.	1.00
2015063505	MAINTENANCE ODW INT. LIGHTING	POLE 4V LIGHT FIXTURE COMPLETELY OUT	POLE 4V	6/19/2015	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2015063506	MAINTENANCE ODW INT. LIGHTING	AREA 3 WEST LIGHT OUT OVER CUBICLE 24	AREA 3 WEST	6/19/2015	REPLACED LAMPS OVER CUBICLE	0.50
2015063507	MAINTENANCE ODW INT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	6/19/2015	REPLACED 11 LIGHT BULBS AND VACUUMED THREE LIGHT FIXTURES	1.00
2015063508	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT RESPOND TO COMMAND FROM COMMAND CENTER	GATEHOUSE 2	6/19/2015	OPENED GATE AT GATEHOUSE MANUALLY	0.50
2015063568	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #1 CLOGGED	M'S R/R 1005	6/22/2015	UNCLOGGED THE COMMODO	0.50
2015063569	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	6/22/2015	REPLACED 4 LIGHT BUBLS AND VACUUMED LENS	0.50
2015063570	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	6/22/2015	6-19-15: REPLACED 28 LIGHT BULBS AROUND POLE 5X. 6-20-15: REPLACED 33 LIGHT BULBS.	2.00
2015063571	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 #5 TOILET CLOGGED	W'S R/R A309	6/22/2015	UNCLOGGED COMMODO WITH SNAKE	0.50
2015063572	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS OUT	AREA 1	6/22/2015	REPLACED LAMPS	0.75
2015063591	MAINTENANCE ODW CLOCKS	DIGITAL CLOCKS THROUGHOUT BUILDING NOT FUNCTIONING PROPERLY	CSC SERVICE CENTER	6/22/2015	MASTER CLOCK NOT ABLE TO BE REPAIRED. SIMPLEX GRINNELL HAD TO REMOVE DEFECTIVE MASTER CLOCK. REPLACED WITH NEW. NEW RETROFIT RETAINER NEEDED. CONNECTED WIRING TO NEW CLOCK. (IDIQ, JOB NO. 3822, DO NO. 0039. \$3,092.00)	0.00
2015063617	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A700i TOILET CLOGGED	M'S R/R A700i	6/23/2015	UNCLOGGED WITH PLUNGER	0.50
2015063618	MAINTENANCE ODW INT. LIGHTING	AREA 12 LIGHTS OUT	AREA 12	6/23/2015	REPLACED WITH NEW	3.00
2015063623	MAINTENANCE ODW TEMPERATURE HOT	MAG HALL RM 32 TOO HOT. NO AIR CIRCULATING FROM A/C.	MAG HALL RM 32	6/23/2015	UNIT 13-3-4 RUNNING NORMALLY. PROVIDING MAXIMUM COOLING WITH A DISCHARGE AIR TEMP OF 60.2 DEG F.	0.50
2015063624	MAINTENANCE ODW TEMPERATURE HOT	RM 111A OLD BADGE ROOM TOO HOT AND THERE IS A MEETING THERE BEGINNING AT 12:30 PM TODAY	RM 111A	6/23/2015	LOWERED DISCHRGE AIR SETPOINT TO 62 DEG F ON UNIT 8-1	0.50
2015063625	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 8F FLOOR BOX COVER MISSING	POLE 8F	6/23/2015	REPLACED MISSING COVER	0.50
2015063669	MAINTENANCE ODW TEMPERATURE COLD	AREA 3 RM 300C TOO COLD	AREA 3 RM 300C	6/24/2015	ADJUSTED SET POINT TEMP ON AHU 11-1-3.	0.50
2015063673	MAINTENANCE ODW BLDG/EQUIP. REP	RM 807 EXHAUST FAN MOTOR NOT WORKING	RM 807	6/24/2015	NEEDS A NEW MOTOR. (ORDERED FROM A1 ELECTRIC.) INSTALLED NEW FAN MOTOR. A1 ELECTRIC: \$67.37	1.25
2015063674	MAINTENANCE ODW INT. LIGHTING	AREA 13 LIGHTS OUT	AREA 13	6/24/2015	REPLACED WITH NEW	3.00

2015063691	MAINTENANCE ODW PLUMBING	MAG HALL 4 URINAL WILL NOT FLUSH	MAG HALL 4	6/25/2015	REPLACED BATTERIES	0.50
2015063692	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #4 TOILET CLOGGED	M'S R/R 1005	6/25/2015	UNCLOGGED WITH PLUNGER	0.50
2015063693	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #9 TOILET CLOGGED	W'S R/R B211	6/25/2015	UNCLOGGED WITH PLUNGER	0.50
2015063694	MAINTENANCE ODW TEMPERATURE COLD	POLE 4Q TOO COLD	POLE 4Q	6/25/2015	TEMP RANGE 72.3 - 72.7. NO ADJUSTMENT.	0.50
2015063695	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 TOO HOT	AREA 1	6/25/2015	LOWERED DISCHARGE AIR SET POINT FOR UNIT 8-1	0.50
2015063746	MAINTENANCE ODW INT. LIGHTING	M'S R/R 1005 SPOT LIGHT OUT BY URINALS	M'S R/R 1005	6/26/2015	REPLACED TWO LIGHT BULBS	0.50
2015063747	MAINTENANCE ODW INT. LIGHTING	RM 809 LIGHTS OUT	RM 809	6/26/2015	REPLACED TWO LIGHT BULBS	0.50
2015063756	MAINTENANCE ODW PLUMBING	M'S R/R B309 #3 SINK NOT WORKING. TWO URINALS NOT WORKING.	M'S R/R B309	6/26/2015	ALL THREE URINALS ARE FLUSHING PROPERLY AND ARE NOT CLOGGED. TIGHTENED PACKING NUT ON SHUT-OFF VALVE.	0.50
2015063775	MAINTENANCE ODW INT. LIGHTING	DATA CONVERSION OPERATIONS MANAGER OFFICE RM 19 LIGHTS OUT	RM 19	6/26/2015	REPLACED LIGHT BALLAST AND TWO LIGHT BULBS	1.00
2015063798	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP COMMODE CLOGGED	W'S R/R 34	6/29/2015	UNCLOGGED THE COMMODE	0.50
2015063799	MAINTENANCE ODW BLDG/EQUIP. REP	COMPUTER ROOM A TROUBLE ALARM SOUNDING	COMPUTER ROOM A	6/29/2015	REPLACED IONIZATION SMOKE HEAD	1.50
2015063800	MAINTENANCE ODW BLDG/EQUIP. REP	RM 1002 METAL DRAIN COVER THAT SERVES AHU 11-9 DOES NOT FIT	RM 1002	6/29/2015	CUT DRAIN COVER TO FIT WITH NEW PIPING AND CLEANED UP.	1.00
2015063802	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 1 LIGHTS OUT	MAG HALL RM 1	6/29/2015	REPLACED BALLAST AND 2T8 BULBS	0.50
2015063811	MAINTENANCE ODW DOOR	COMMAND CENTER BREAK RM DOOR KNOB FELL OFF OF DOOR	COMMAND CENTER BREAK RM	6/29/2015	REATTACHED DOOR KNOB AND TIGHTENED KNOB	0.50
2015063827	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 CLOGGED	M'S R/R B309	6/29/2015	PLUNGED TOILET. OK.	0.50
2015063836	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 #8 STOPPED UP	W'S R/R A306	6/29/2015	FLUSHED ALL 9 TOILETS. NO CLOG.	0.50
2015063837	MAINTENANCE ODW PLUMBING	W'S R/R 600 #2 WILL NOT FLUSH	W'S R/R 600	6/29/2015	REPLACED FOUR AA BATTERIES	0.50
2015063839	MAINTENANCE ODW INT. LIGHTING	RM 307C MANY LIGHTS OUT IN RM 307C	RM 307C	6/29/2015	ONE FIXTURE OUT IN ROOM. REPLACED 3 LAMPS.	0.50
2015063845	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 POLES 8F-8H TOO HOT	AREA 1	6/30/2015	AREA TEMPS ARE BETWEEN 71.5 AND 72.5 DEG WHICH IS AT THE LOW END OF THE CONTRACTUAL REQUIREMENT OF 74+/-2 DEG F. UNIT IS PROVIDING 61 DEG DISCHARGE AIR TEMP. NO CHANGE MADE.	0.50
2015063872	MAINTENANCE ODW BLDG/EQUIP. REP	SKYLIGHT CANTEEN WATER FROM THE DOUBLE SS SINK IS NOT HOT ENOUGH	SKYLIGHT CANTEEN	6/30/2015	WATER HEATER SUPPLYING SINKS ALSO SUPPLIES 2 RESTROOMS (1003 AND 1005) AND JANITOR'S CLOSET. REPLUMBED HOT WATER SUPPLY SO IT IS NOW FED BY INSTANTANEOUS WATER HEATER LOCATED BETWEEN HAND SINK AND WASH SINKS.	2.00
2015070000	MAINTENANCE ODW TEMPERATURE HOT	AREA 3 EAST TOO HOT	AREA 3 EAST	7/1/2015	IRS CONTRACTORS HAVE AIR HANDLING UNIT OFF FOR SERVICE	0.50
2015070988	MAINTENANCE ODW ELECTRICAL	RM 30 AND 31 ELECTRICAL OUTLETS NOT WORKING IN HER CUBICLE	RMS 30 AND 31	7/1/2015	RESET BREAKER	0.50
2015071351	MAINTENANCE ODW BLDG/EQUIP. REP	603 POLE 8P ALARM SOUNDING	603 POLE 8P	7/1/2015	ALARM SWITCH HAD BEEN BUMPED. TURNED TO CORRECT POSITION AND CHECKED FLOATS. OK.	0.50
2015072514	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT RESPOND TO COMMAND FROM COMMAND CENTER	GATEHOUSE 2	7/2/2015	OPENED GATE AT GATEHOUSE MANUALLY	0.50
2015072515	MAINTENANCE ODW BLDG/EQUIP. REP	CENTRAL PLANT REFRIGERANT MONITOR IN "TROUBLE" SHOWING "FLOW FAILURE"	CENTRAL PLANT	7/2/2015	TRACED PROBLEM TO INTERMITTENT FLOW SWITCH OPERATION. REPLACED SWITCH AND MONITORED OPERATION OVERNIGHT. PROBLEM SOLVED AND MONITOR IS OPERATING CORRECTLY. FLOW SWITCH (MSA) \$62.00.	1.00
2015072531	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 #14, 15 AND 16 CLOGGED	W'S R/R A1003	7/2/2015	7-2-15: MM - PLUNGED ALL THREE TOILETS. POSSIBLE CLOG IN MAIN. 7-2-16: TD - STALLED #17 CLOGGED ALSO. PLUNGED ALL. GOT TO #17, BROKE FREE. CHECKED FOR LEAKS.	2.00
2015072543	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 POLES 8F-8H TOO HOT	AREA 1	7/6/2015	TEMP IS 71.8 TO 72.3 IN AREA. UNIT OPERATING CORRECTLY. NO CHANGE MADE.	0.50
2015072548	MAINTENANCE ODW TEMPERATURE HOT	AREA 7 EXTRACTING TOO HOT	AREA 7	7/6/2015	TEMP IS 71 DEG F IN AERA. UNIT OPERATING CORRECTLY. NO CHANGE MADE.	0.50
2015072570	MAINTENANCE ODW PLUMBING	M'S R/R 35 MAG HALL FAUCET BARELY PRODUCING WATER TO RINSE SOAP OFF HANDS	M'S R/R 35	7/6/2015	OPENED STOP VALVE TO INCREASE WATER FLOW	0.50
2015072574	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 28 - FLOOR TILE POPPED UP	CHILDCARE RM 28	7/6/2015	CHECKED TILE. IT IS 9' FROM THE ENTRY TO RM 128. REPLACED FLOOR TILE WITH NEW.	0.75
2015072575	MAINTENANCE ODW INT. LIGHTING	604 LIGHTS OUT	604	7/6/2015	REPLACED BALLAST AND 2 LAMPS IN FIXTURE. REPLACED LAMPS IN OTHER FIXTURES.	1.50
2015072583	MAINTENANCE ODW BLDG/EQUIP. REP	"A" PLANT CONDENSER WATER PIT MAKE-UP WATER METER NOT OPERATING, NOT DISPLAYING CORRECT WATER USAGE.	"A" PLANT	7/6/2015	REPLACED WATER METER. VERIFIED PROPER OPERATION. OK. COST: \$219.00	1.00
2015072584	MAINTENANCE ODW BLDG/EQUIP. REP	PLANT CONDENSER WATER PIT MAKE-UP WATER METER NOT OPERATING, NOT DISPLAYING CORRECT WATER USAGE.	CENTRAL PLANT	7/6/2015	REPLACED WATER METER. VERIFIED PROPER OPERATION. OK. COST: \$219.00	1.00
2015072645	MAINTENANCE ODW INT. LIGHTING	OFFICE 300A - LIGHTS OUT	OFFICE 300A	7/7/2015	REPLACED THREE LAMPS	0.50
2015072650	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP TOILET CLOGGED	M'S R/R A810	7/7/2015	PLUNGED TOILET. OK.	0.50
2015072653	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #3 TOILET CLOGGED	M'S R/R 1005	7/7/2015	UNCLOGGED WITH PLUNGER	0.50
2015072654	MAINTENANCE ODW TEMPERATURE HOT	8P RM 603 TOO HOT	8P RM 603	7/7/2015	CHECKED LIEBERTS, LOWERED L-6 SET POINT 72 DEG TO 71 DEG. L-5 SET POINT 73 DEG TO 71 DEG. MONITORED TO 72 DEG.	0.50
2015072739	MAINTENANCE ODW TEMPERATURE HOT	8H AND 8F NEEDS AIR	8H AND 8F	7/8/2015	TURNED ON LIEBERT UNIT 1-1. SPACE TEMP IS BETWEEN 71.5 DEG AND 72.2 DEG F.	0.50

2015072740	MAINTENANCE ODW TEMPERATURE HOT	10N EXTRACTING TOO HOT	10N	7/8/2015	LOWERED SPACE TEMP TO SET POINT FROM 71 DEG TO 70 DEG F. SPACE TEMP IS 72 DEG.	0.50
2015072754	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 FIRST THREE SINKS ARE EMITTING AN ODOR	W'S R/R B211	7/8/2015	CHECKED SINKS, COULD NOT SMELL ANY ODOR.	0.50
2015072755	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 #2 TOILET CLOGGED	M'S R/R 810	7/8/2015	UNCLOGGED WITH PLUNGER	0.50
2015072756	MAINTENANCE ODW INT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	7/8/2015	REPLACED 12 LIGHT BULBS	0.50
2015072757	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 #3 TOILET CLOGGED	W'S R/R A309	7/8/2015	UNCLOGGED TOILET. OK.	0.50
2015072765	MAINTENANCE ODW ELECTRICAL	AREA 1 STILL HAVING AN ISSUE WITH ELECTRICAL OUTLET	AREA 1	7/8/2015	MR: SPOKE TO TWO EMPLOYEES IN THE AREA. THEY STATED THAT THERE WAS NOTHING WRONG WITH THE ELECTRICAL OUTLET. IT HAS BEEN FINE SINCE IT WAS REPAIRED OVER TWO WEEKS AGO.	0.50
2015072781	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #3 TOILET CLOGGED	M'S R/R 1005	7/8/2015	TOILET HAD BEEN STUFFED WITH PAPER TOWELS AND TOILET PAPER. CLEARED CLOG WITH PLUNGER.	0.50
2015072802	MAINTENANCE ODW DOOR	AREA 1 DOOR BEHIND DESK MONITOR - THE STRIKE PLATE IS READY TO FALL OFF	AREA 1	7/9/2015	REPLACED MISSING SCREW IN STRIKE PAD	0.50
2015072803	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHT FIXTURE NOT WORKING AND A FEW LAMPS OUT	SATELLITE CANTEEN	7/9/2015	REPLACED 4 U-SHAPED LAMPS, 2 LAMPS, 1 BALLAST	1.50
2015072804	MAINTENANCE ODW INT. LIGHTING	IDF CLOSET BY NEW COMPUTER ROOM OVERHEAD LIGHTS OUT	IDF IN AREA 14	7/9/2015	THE ISSUE WAS THAT THE LIGHT SWITCH WAS NOT FLIPPED ON. TURNED ON LIGHT SWITCH.	0.50
2015072851	MAINTENANCE ODW BLDG/EQUIP. REP	RM 903 COVE BASE COMING OFF WALL, 5' PAST THRESHOLD AT TOP OF RAMP	RM 903	7/10/2015	REGLUED ANOTHER FOUR FOOT SECTION OF BLACK COVE BASE TO WALL	0.50
2015072852	MAINTENANCE ODW TEMPERATURE COLD	POLE 8K TOO COLD	POLE 8K	7/10/2015	TOOK THREE TEMPS OF AREA - 76, 76 AND 76.1. MADE NO ADJUSTMENT.	0.50
2015072853	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT RESPOND TO COMMAND FROM COMMAND CENTER	GATEHOUSE 2	7/10/2015	OPENED GATE AT GATEHOUSE MANUALLY	0.50
2015072854	MAINTENANCE ODW GATE/FENCE	FENCE NEAR GATEHOUSE 5, NORTH END GOING INTO SOUTH BREEZEWAY HAS A BROKEN SCREW IN TOP FENCE SUPPORT	GATEHOUSE 5	7/10/2015	DRILLED OUT BROKEN SCREW AND REPLACED. TIGHTENED THE OTHER THREE SCREWS.	0.50
2015072855	MAINTENANCE ODW TEMPERATURE HOT	COURTYARD CANTEEN - CHECK THE TEMP AROUND 11:00 AM TODAY AND DOCUMENT THE TEMP	COURTYARD CANTEEN	7/10/2015	FLUKE METER READING 72.4 DEG F, 77% RH. METASYS READING 72.1 DEG F, 76.5 RH. SPACE SETPOINT IS 73 DEG F. CANTEEN KITCHEN TEMP VIA FLUKE 74.4 DEG F.	0.50
2015072862	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 HANDICAP TOILET CLOGGED	M'S R/R 1005	7/10/2015	PLUNGED TOILET, OK. TIGHTENED SEAT BOLTS.	0.50
2015072869	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 CLOGGED; TOILET #1 SEAT BROKEN	W'S R/R 306	7/10/2015	PLUNGED THE TOILET, FLUSHED, OK. TOILET SEAT NOT BROKEN, JUST LOOSE. CHECKED ALL TOILET SEATS AND TIGHTENED THOSE WHICH NEEDED TO BE TIGHTENED.	0.75
2015072876	MAINTENANCE ODW INT. LIGHTING	AISLEWAY AT POLE 4F - LIGHT LENS LOOSE	POLE 4F	7/10/2015	REATTACHED LOOSE LENS LATCH TO LIGHT FIXTURE	0.50

1363

1,342.50