

FILTERS FOR THE IRS BUILDING 9-27-17
NEW TRANE 1-24-20X20X2 / 12-20X25X2
NEW TRANE 2- 24-20X20X2 / 12-20X25X2
NEW TRANE 3 -24-20X20X2 /12-20X25 X2
NEW TRANE 4 -25-20X20X2 / 12-20X25X2
CARRIER 9 -6-16X25X2 / 2-16X20X2
CARRIER 10- 4- 16X25X2
HEALTH UNIT 6-20X20X2
CAFÉ SOUTH 17-20X16X2
CAFÉ NORTH 17-20X16X2
RPS TRAIN(ic/Mits ad)16-16x20x2
FILTER RACKS (POWER HOUSE) 16-20X20X2
CONSOLE RM RM 256/257 3-20X20X1
PRINT SHOP 1-24X24X1
MACHINE SERV. 4-16X20X2 / 2-16X25X2
DIRECTORS OFFICE- ELECTROSTATIC FILTER
MAIL ROOM 4-16X20X1
LIEBERTS-10,11,13,14-2EACH UNIT 18X24X2
LIEBERTS IN ROOM 315 ??????????????????
R&C EAST 4-12X24X2 / 8-24X24X2
R&C WEST 18- 24X24X2
SCAMPS 8-24X24X4
SCAMPS EXHAUST 1-24X24X4 BELT AP31-1
OLD TRANE 1 1-61T ROLLED FILTERS
OLD TRANE 2 1-61T ROLLED FILTERS
OLD TRANE 3 2-31T ROLLED FILTERS
OLD TRANE 4 2-31T ROLLED FILTERS
TRANE 6 3-24X24X2 / 3-12X24X2
UPS TRANE 12-20X20X2
CCC KITCHEN 1-20X20X1
CCC AHU 4-16X25X2 / 2-16X20X2
RM 502-503 1-20X20X1
POST OFFICE 4-16X20X1
MAIN COMPUTER COMPUAIRE 1 10,11,12 BLUE PRE FILTER 8-16X25X2
HEPA FILTERS SCAMPS,EAST, WEST-7-24X24X11.5(GR#6RG14/5W996/2W235)
LASER PRINT LIEBERT 17,19 Blue pre filter 5-18x24x4 in each unit
MAIN COMPUTER ROOM LIEBERT 3 AND 4. BLUE PRE FILTER 5 24X18X4 EACH UNIT
MAIN COMPUTER ROOM LIEBERT 20 BLUE PRE FILTERED 5-24X24X4

HEPA FILTERS NOT INCLUDED ABOVE
 12 EACH 24" X 24" X 12"
 7 EACH 24" X 24" X 11"

NOT ON ROUTING
 CHANGES SCHEDULED
 CHANGES AS NEEDED