

Fire Alarm and Life Safety System Inspection Certificate

For

IRS Building
4800 Buford Highway
Chamblee, GA 30341

Tested to NFPA 72 Standards

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date
Sep 20, 2012

Building: IRS Building
Contact: Richard Hart
Title: n/a

Company: Convergent Technology Atlanta
Contact: John A. Medford
Title: Service Account Manager

Executive Summary

Generated by: BuildingReports.com


Building Information		
Building: IRS Building	Contact: Richard Hart	
Address: 4800 Buford Highway	Phone: 770-455-2492	
Address:	Fax: 770-452-4033	
City/State/Zip: Chamblee, GA 30341	Mobile:	
Country: United States of America	Email: richard.n.hart@irs.gov	
Inspection Performed By		
Company: Convergent Technology Atlanta	Inspector: John A. Medford	
Address: 1555 Oakbrook Drive	Phone: (770) 840-7007	
Address: Suite 165	Fax: (770) 840-7072	
City/State/Zip: Norcross, GA 30093	Mobile: (404) 384-5065	
Country: United States of America	Email: john.medford@convergent.com	
System Control Unit		
Manufacturer: EST	Inspection Date: 08/28/2012	IDC Style: B
Model Number: QuickStart	Install Date: 06/05/2008	SLC Style:
Software Version: 2.50	Version Date: 06/05/2008	NAC Style: Y
Location: Ground Door 4 Security	Current Protection: Breaker	
Monitoring		
Type:	Mfg:	Model #:
Test Time/Date:	Restore Time:	

Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Monitor	3	1.64%	3	100.00%	3	100.00%	0	0%
Supervisory	13	7.10%	13	100.00%	13	100.00%	0	0%
Auxiliary	3	1.64%	3	100.00%	3	100.00%	0	0%
Sound Test	1	0.55%	1	100.00%	1	100.00%	0	0%
Initiating	98	53.55%	98	100.00%	98	100.00%	0	0%
Indicating	14	7.65%	14	100.00%	14	100.00%	0	0%
Control	51	27.87%	51	100.00%	51	100.00%	0	0%
Totals	183	100%	183	100.00%	183	100.00%	0	0%

Certification

Building: IRS Building
 Contact: Richard Hart

Company: Convergent Technology Atlanta
 Inspector: John A. Medford




Signed: Aug 28, 2012 11:34:22 AM

Signed: Aug 28, 2012 11:34:33 AM

Inspection & Testing

Generated by: BuildingReports.com

Building: IRS Building	Control Panel: 1 - EST QuickStart
-------------------------------	--

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
Passed				
Auxiliary				
Fan Shutdown	General Shutdown	Tested	11:29:29 AM	08/28/2012
Locking Device		Tested	11:31:14 AM	08/28/2012
Releasing Device		Tested	11:29:56 AM	08/28/2012
Control				
Annunciator	Ground Door 1 Lobby	Tested	6:23:05 AM	08/28/2012
Annunciator	Ground Loading Dock	Tested	6:47:33 AM	08/28/2012
Battery	Ground Door 4 Security	Tested	5:56:57 AM	08/28/2012
Battery	Ground Door 4 Security	Tested	5:57:01 AM	08/28/2012
Battery	Ground G15W	Tested	6:14:28 AM	08/28/2012
Battery	Ground G15W	Tested	6:14:36 AM	08/28/2012
Battery	Ground G20W	Tested	6:17:34 AM	08/28/2012
Battery	Ground G20W	Tested	6:17:43 AM	08/28/2012
Battery	Ground G5W	Tested	6:29:55 AM	08/28/2012
Battery	Ground G5W	Tested	6:30:01 AM	08/28/2012
Battery	Ground G9W	Tested	6:33:07 AM	08/28/2012
Battery	Ground G9W	Tested	6:33:14 AM	08/28/2012
Battery	Ground V22S	Tested	7:14:13 AM	08/28/2012
Battery	Ground V22S	Tested	7:14:19 AM	08/28/2012
Battery	Ground X24E	Tested	7:17:50 AM	08/28/2012
Battery	Ground X24E	Tested	7:17:57 AM	08/28/2012
Battery	Ground X24E	Tested	7:19:39 AM	08/28/2012
Battery	Ground X24E	Tested	7:19:48 AM	08/28/2012
Battery	Ground Z19N	Tested	7:27:01 AM	08/28/2012
Battery	Ground Z19N	Tested	7:27:11 AM	08/28/2012
Battery	Ground V19N	Tested	7:30:40 AM	08/28/2012
Battery	Ground V19N	Tested	7:30:48 AM	08/28/2012
Battery	Ground Electrical Closet	Tested	7:46:21 AM	08/28/2012
Battery	Ground Electrical Closet	Tested	7:46:29 AM	08/28/2012
Battery	Ground Electrical Closet	Tested	7:46:39 AM	08/28/2012
Battery	Ground Electrical Closet	Tested	7:46:41 AM	08/28/2012
Battery	Ground Computer Room BPS-8	Tested	8:24:35 AM	08/28/2012
Battery	Ground Computer Room BPS-8	Tested	8:24:41 AM	08/28/2012
Battery	Ground Room 304	Tested	8:30:24 AM	08/28/2012
Battery	Ground Room 304	Tested	8:30:51 AM	08/28/2012
Battery	Ground Telecommunications Room	Tested	8:37:26 AM	08/28/2012
Battery	Ground Telecommunications Room	Tested	8:37:35 AM	08/28/2012
Battery	Ground Door 4 Security	Replaced	7:53:45 PM	09/20/2012
Battery	Ground Door 4 Security	Replaced	7:54:15 PM	09/20/2012

Device Type	Location	Service	Time	Date
Passed				
Control Panel	Ground Door 4 Security	Tested	11:29:27 AM	08/28/2012
Power Supply	Ground Door 4 Security	Tested	5:57:05 AM	08/28/2012
Power Supply	Ground G15W	Tested	6:14:47 AM	08/28/2012
Power Supply	Ground G20W	Tested	6:17:52 AM	08/28/2012
Power Supply	Ground G5W	Tested	6:30:12 AM	08/28/2012
Power Supply	Ground G9W	Tested	6:33:25 AM	08/28/2012
Power Supply	Ground V22S	Tested	7:14:26 AM	08/28/2012
Power Supply	Ground X24E	Tested	7:18:04 AM	08/28/2012
Power Supply	Ground X24E	Tested	7:19:53 AM	08/28/2012
Power Supply	Ground Z19N	Tested	7:27:18 AM	08/28/2012
Power Supply	Ground V19N	Tested	7:30:56 AM	08/28/2012
Power Supply	Ground Electrical Closet	Tested	7:45:07 AM	08/28/2012
Power Supply	Ground Electrical Closet	Tested	7:46:17 AM	08/28/2012
Power Supply	Ground Computer Room BPS-8	Tested	8:24:44 AM	08/28/2012
Power Supply	Ground Room 304	Tested	8:30:21 AM	08/28/2012
Power Supply	Ground Telecommunications bps2 Room	Tested	8:37:41 AM	08/28/2012
Printer	Ground Door 4 Security	Tested	9:04:02 AM	01/27/2012
Indicating				
Horn/Strobe	Ground Corridor By Mechanical Room 393 Near Locker 189	Tested	8:59:39 AM	01/27/2012
Horn/Strobe	Ground Computer Hallway Above Ramp	Tested	8:59:58 AM	01/27/2012
Horn/Strobe	Ground Room 318 By Marsha Camps Desk	Tested	9:00:06 AM	01/27/2012
Horn/Strobe	Ground Laser Print Room	Tested	9:00:17 AM	01/27/2012
Horn/Strobe	Ground Laser Print Room	Tested	9:00:25 AM	01/27/2012
Horn/Strobe	Ground Computer Hallway By Simplex Panel	Tested	9:00:34 AM	01/27/2012
Horn/Strobe	Ground Main Computer Hallway By Room 318	Tested	9:00:43 AM	01/27/2012
Horn/Strobe	Ground Main Computer Room	Tested	9:00:51 AM	01/27/2012
Horn/Strobe	Ground Main Computer Room	Tested	9:00:59 AM	01/27/2012
Horn/Strobe	Ground Machine Services	Tested	9:01:07 AM	01/27/2012
Horn/Strobe	Ground Dock Area By Machine Services	Tested	9:01:15 AM	01/27/2012
Horn/Strobe	Ground Spif Room Center	Tested	9:01:23 AM	01/27/2012
Horn/Strobe	Ground Laser Print Room	Tested	9:01:30 AM	01/27/2012
Strobe	Ground Women's Restroom 6	Tested	8:59:48 AM	01/27/2012
Initiating				
Duct Detector	Roof RPS supply R-10	Not tested	9:04:19 AM	01/27/2012
Duct Detector	Roof RPS supply Q-13	Not tested	9:04:24 AM	01/27/2012
Duct Detector	Roof Old Unit 3	Tested/Cleaned	10:34:21 AM	08/28/2012
Duct Detector	Roof Old Unit 3	Tested/Cleaned	10:36:14 AM	08/28/2012
Duct Detector	Roof Old Unit 4	Tested/Cleaned	10:38:14 AM	08/28/2012
Duct Detector	Roof Old Unit 4	Tested/Cleaned	10:39:55 AM	08/28/2012
Duct Detector	Roof West RNC	Tested/Cleaned	6:23:58 AM	09/07/2012
Duct Detector	Roof West RNC	Tested/Cleaned	6:25:12 AM	09/07/2012
Duct Detector	Roof East RNC	Tested/Cleaned	6:26:45 AM	09/07/2012
Duct Detector	Roof SCAMPS	Tested/Cleaned	6:28:44 AM	09/07/2012
Duct Detector	Roof SCAMPS	Tested/Cleaned	6:29:46 AM	09/07/2012
Duct Detector	Roof East RNC	Tested/Cleaned	6:30:50 AM	09/07/2012
Duct Detector	Roof New Unit 2	Tested/Cleaned	6:44:04 AM	09/07/2012
Duct Detector	Roof New Unit 3	Tested/Cleaned	6:46:32 AM	09/07/2012
Duct Detector	Roof New Unit 4	Tested/Cleaned	6:49:16 AM	09/07/2012

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Duct Detector	Roof Unit 6	Tested/Cleaned	7:02:00 AM	09/07/2012
Duct Detector	Roof Unit 7	Tested/Cleaned	7:03:15 AM	09/07/2012
Duct Detector	Roof Old Unit 1	Tested/Cleaned	7:06:10 AM	09/07/2012
Duct Detector	Roof Old Unit 2	Tested/Cleaned	7:06:31 AM	09/07/2012
Duct Detector	Roof Old Unit 1	Tested/Cleaned	7:07:19 AM	09/07/2012
Duct Detector	Roof Old Unit 2	Tested/Cleaned	7:09:03 AM	09/07/2012
Duct Detector	Roof New Unit 1	Tested/Cleaned	7:15:41 AM	09/07/2012
Duct Detector	Ground UPS Room	Tested/Cleaned	8:00:06 AM	08/28/2012
Duct Detector	Ground South Cafe AHU	Tested/Cleaned	11:02:15 AM	08/28/2012
Duct Detector	Ground North Cafe AHU	Tested/Cleaned	11:03:55 AM	08/28/2012
Duct Detector	Ground Kitchen AHU	Tested/Cleaned	11:06:10 AM	08/28/2012
Duct Detector	Ground AHU 1 Supply By Room 202	Tested/Cleaned	11:10:28 AM	08/28/2012
Duct Detector	Ground AHU 1 Conference Room 209	Tested/Cleaned	11:18:27 AM	08/28/2012
Duct Detector	Ground AHU 1 Supply Room 206	Tested/Cleaned	11:20:27 AM	08/28/2012
Duct Detector	Ground AHU 1 Supply Room 202	Tested/Cleaned	11:21:33 AM	08/28/2012
Pull Station	Roof Penthouse Exit	Tested	10:34:11 AM	08/28/2012
Pull Station	Roof Penthouse Exit	Tested	10:47:00 AM	08/28/2012
Pull Station	Roof Penthouse Exit	Tested	10:49:17 AM	08/28/2012
Pull Station	Ground Door 4 Lobby	Tested	6:02:12 AM	08/28/2012
Pull Station	Ground Door 3 Exit	Tested	6:19:35 AM	08/28/2012
Pull Station	Ground Door 2 Exit	Tested	6:20:33 AM	08/28/2012
Pull Station	Ground Door 1 Lobby	Tested	6:22:57 AM	08/28/2012
Pull Station	Ground Door 14A Exit	Tested	6:24:40 AM	08/28/2012
Pull Station	Ground Door 13 Exit	Tested	6:26:16 AM	08/28/2012
Pull Station	Ground Trophy Case	Tested	6:34:46 AM	08/28/2012
Pull Station	Ground Door 4AM/N23 Lobby	Tested	6:37:49 AM	08/28/2012
Pull Station	Ground Door 5A	Tested	6:38:51 AM	08/28/2012
Pull Station	Ground Kitchen	Tested	6:40:14 AM	08/28/2012
Pull Station	Ground Cafeteria Boiler Room	Tested	6:41:12 AM	08/28/2012
Pull Station	Ground Door 7 Exit	Tested	6:42:43 AM	08/28/2012
Pull Station	Ground by Paper Storage	Tested	6:50:08 AM	08/28/2012
Pull Station	Ground Cafeteria Corridor	Tested	6:59:19 AM	08/28/2012
Pull Station	Ground Cafeteria Corridor	Tested	7:00:26 AM	08/28/2012
Pull Station	Ground Door 8 Exit	Tested	7:23:30 AM	08/28/2012
Pull Station	Ground Door 9 Exit	Tested	7:24:51 AM	08/28/2012
Pull Station	Ground Door 10 Exit	Tested	7:33:19 AM	08/28/2012
Pull Station	Ground Door 11 Exit	Tested	7:49:38 AM	08/28/2012
Pull Station	Ground Electrical Room	Tested	8:14:00 AM	08/28/2012
Pull Station	Ground Door 12A Exit	Tested	8:19:12 AM	08/28/2012
Pull Station	Ground Door 11A Exit	Tested	10:20:16 AM	08/28/2012
Smoke Detector	Ground Door 4 Security	Tested/Cleaned	6:05:38 AM	08/28/2012
Smoke Detector	Ground Door 255	Tested/Cleaned	6:06:23 AM	08/28/2012
Smoke Detector	Ground Door 255	Tested/Cleaned	6:06:54 AM	08/28/2012
Smoke Detector	Ground Door 335	Tested/Cleaned	6:08:15 AM	08/28/2012
Smoke Detector	Ground Door 335	Tested/Cleaned	6:08:45 AM	08/28/2012
Smoke Detector	Ground Door 331	Tested/Cleaned	6:10:05 AM	08/28/2012
Smoke Detector	Ground Door 331	Tested/Cleaned	6:10:34 AM	08/28/2012
Smoke Detector	Ground BPS 3 @ G15W	Tested/Cleaned	6:15:05 AM	08/28/2012
Smoke Detector	Ground BPS 5 @ G20W	Tested/Cleaned	6:19:00 AM	08/28/2012
Smoke Detector	Ground Door 303	Tested/Cleaned	6:26:57 AM	08/28/2012

Device Type	Location	Service	Time	Date
Passed				
Smoke Detector	Ground Door 303	Tested/Cleaned	6:27:27 AM	08/28/2012
Smoke Detector	Ground BPS 1 @ G5W	Tested	6:28:30 AM	08/28/2012
Smoke Detector	Ground BPS 4 @ G9W	Tested/Cleaned	6:31:19 AM	08/28/2012
Smoke Detector	Ground Door by Cafeteria	Tested/Cleaned	6:58:58 AM	08/28/2012
Smoke Detector	Ground Door by Cafeteria	Tested/Cleaned	7:00:03 AM	08/28/2012
Smoke Detector	Ground BPS 13 @ V22S	Tested/Cleaned	7:14:58 AM	08/28/2012
Smoke Detector	Ground @ BPS 14	Tested/Cleaned	7:20:52 AM	08/28/2012
Smoke Detector	Ground BPS 11 @ Z19N	Tested/Cleaned	7:27:23 AM	08/28/2012
Smoke Detector	Ground BPS 12 @ V19N	Tested/Cleaned	7:31:04 AM	08/28/2012
Smoke Detector	Ground Door to RPS	Tested/Cleaned	7:34:14 AM	08/28/2012
Smoke Detector	Ground Door to RPC	Tested/Cleaned	7:36:24 AM	08/28/2012
Smoke Detector	Ground RPS	Tested/Cleaned	7:36:57 AM	08/28/2012
Smoke Detector	Ground Above BPS 9 & 10	Tested/Cleaned	7:47:05 AM	08/28/2012
Smoke Detector	Ground Door RNC	Tested/Cleaned	7:48:54 AM	08/28/2012
Smoke Detector	Ground UPS Room	Tested/Cleaned	7:58:39 AM	08/28/2012
Smoke Detector	Ground Electrical Room	Tested/Cleaned	8:11:00 AM	08/28/2012
Smoke Detector	Ground Electrical Room	Tested/Cleaned	8:12:12 AM	08/28/2012
Smoke Detector	Ground Electrical Room	Tested/Cleaned	8:13:43 AM	08/28/2012
Smoke Detector	Ground Computer room above BPS-8	Tested/Cleaned	8:22:29 AM	08/28/2012
Smoke Detector	Ground Room 304 above BPS-7	Tested/Cleaned	8:28:01 AM	08/28/2012
Smoke Detector	Ground Telecommunications Room	Tested/Cleaned	8:38:22 AM	08/28/2012
Smoke Detector	Ground Computer Hall	Tested/Cleaned	8:47:58 AM	08/28/2012
Smoke Detector	Ground Door 302	Tested/Cleaned	8:49:45 AM	08/28/2012
Smoke Detector	Ground Door 302	Tested/Cleaned	8:50:11 AM	08/28/2012
Smoke Detector	Ground at Computer Room FACP	Tested/Cleaned	8:50:27 AM	08/28/2012
Waterflow Switch	Ground Loading Dock	Tested	8:07:22 AM	08/28/2012
Waterflow Switch	Ground Loading Dock	Tested	8:07:24 AM	08/28/2012
Waterflow Switch	Ground RNC Door 11A	Tested	8:15:07 AM	08/28/2012
Waterflow Switch	Ground Mechanical Room	Tested	8:15:19 AM	08/28/2012
Waterflow Switch	Ground Mechanical Room	Tested	8:15:24 AM	08/28/2012
Waterflow Switch	Ground Zone 8	Tested	8:38:38 AM	08/28/2012
Waterflow Switch	Ground Door 4 Lobby	Tested	8:38:42 AM	08/28/2012
Waterflow Switch	Ground RNC Door 11A	Tested	8:50:42 AM	08/28/2012
Monitor				
Monitoring		Tested	11:30:12 AM	08/28/2012
Monitoring		Tested	11:30:22 AM	08/28/2012
Monitoring		Tested	11:30:26 AM	08/28/2012
Supervisory				
Air Pressure Switch	Ground Zone 8	Tested	8:38:29 AM	08/28/2012
Air Pressure Switch	Ground Door 4 Lobby	Tested	8:38:40 AM	08/28/2012
Tamper Switch	Ground Loading Dock	Tested	8:06:07 AM	08/28/2012
Tamper Switch	Ground Loading Dock	Tested	8:07:34 AM	08/28/2012
Tamper Switch	Ground Loading Dock	Tested	8:07:36 AM	08/28/2012
Tamper Switch	Ground Loading Dock	Tested	8:07:41 AM	08/28/2012
Tamper Switch	Ground Loading Dock	Tested	8:07:43 AM	08/28/2012
Tamper Switch	Ground RNC Door 11A	Tested	8:15:09 AM	08/28/2012
Tamper Switch	Ground Mechanical Room	Tested	8:15:12 AM	08/28/2012
Tamper Switch	Ground Mechanical Room	Tested	8:15:17 AM	08/28/2012
Tamper Switch	Ground Zone 8	Tested	8:38:31 AM	08/28/2012

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Tamper Switch	Ground Door 4 Lobby	Tested	8:38:44 AM	08/28/2012
Tamper Switch	Ground RNC Door 11A	Tested	8:50:37 AM	08/28/2012

Service Summary

Generated by: BuildingReports.com

Building: IRS Building

The Service Summary section provides an overview of the services performed in this report.

Device Type	Service	Quantity
Passed		
Air Pressure Switch	Tested	2
Annunciator	Tested	2
Battery	Replaced	2
Battery	Tested	30
Control Panel	Tested	1
Duct Detector	Not tested	2
Duct Detector	Tested/Cleaned	28
Fan Shutdown	Tested	1
Horn/Strobe	Tested	13
Locking Device	Tested	1
Monitoring	Tested	3
Power Supply	Tested	15
Printer	Tested	1
Pull Station	Tested	25
Releasing Device	Tested	1
Smoke Detector	Tested	1
Smoke Detector	Tested/Cleaned	34
Strobe	Tested	1
Tamper Switch	Tested	11
Waterflow Switch	Tested	8
Total		182

Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: IRS Building		Control Panel: 1 - EST QuickStart		
<i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i>				
Type	Location	Comment	ScanID	Simulated
<i>Passed</i>				
Fan Shutdown				
	General Shutdown	Passed	19119117	<input type="checkbox"/>
Locking Device				
Magnetic Lock		Passed	19119122	<input type="checkbox"/>
Releasing Device				
Door Holder		Passed	19119118	<input type="checkbox"/>
Smoke Detector				
Door Release	Ground Door 255	Passed	3948941701	<input type="checkbox"/>
Door Release	Ground Door 255	Passed	3947609916	<input type="checkbox"/>
Door Release	Ground Door 335	Passed	3947634437	<input type="checkbox"/>
Door Release	Ground Door 335	Passed	3948941800	<input type="checkbox"/>
Door Release	Ground Door 331	Passed	3947637223	<input type="checkbox"/>
Door Release	Ground Door 331	Passed	3947638978	<input type="checkbox"/>
Door Release	Ground Door 303	Passed	3947496134	<input type="checkbox"/>
Door Release	Ground Door 303	Passed	3947431739	<input type="checkbox"/>
Door Release	Ground Door by Cafeteria	Passed	3947632464	<input type="checkbox"/>
Door Release	Ground Door by Cafeteria	Passed	3947636820	<input type="checkbox"/>
Door Release	Ground Door to RPS	Passed	3947609541	<input type="checkbox"/>
Door Release	Ground Door to RPC	Passed	3947611537	<input type="checkbox"/>
Door Release	Ground RPS	Passed	3948938428	<input type="checkbox"/>
Door Release	Ground Door RNC	Passed	3947637919	<input type="checkbox"/>
Door Release	Ground Computer room above BPS-8	Passed	3947495762	<input type="checkbox"/>
Door Release	Ground Room 304 above BPS-7	Passed	3947609381	<input type="checkbox"/>
Door Release	Ground Door 302	Passed	3947493584	<input type="checkbox"/>
Door Release	Ground Door 302	Passed	3947496103	<input type="checkbox"/>


Sound and Visual Testing

Generated by: BuildingReports.com

Building: IRS Building						
<p><i>The Sound and Visual Testing section lists various points throughout your building where audible and visual alarm notification devices were tested. Any bar-coded audible and visual devices will appear in the Inspection and Testing section of this report. Items in this section are grouped by Passed or Failed/Other. Where specific decibel readings were recorded, they will appear under the ambient and alarm columns. The Voice column indicates whether the Sound Test Point passed the Voice Intelligibility requirements. The STI or Sound Transmission Index is shown if recorded.</i></p>						
<input type="checkbox"/> Location	Comment	Ambient ◀ dB	Alarm ◀ dB	Intelligibility		Sound Test
				Voice	STI	
<i>Passed</i>						
Sound Test Points	Passed			<input type="checkbox"/>		0001

Smoke Management Testing

Generated by: BuildingReports.com

Building: IRS Building		Control Panel: 1 - EST QuickStart		
<i>The Smoke Management Testing section details the test and inspection of device items that are involved in controlling the spread of smoke in a building. Items are grouped by Passed or Failed/Other.</i>				
<input type="checkbox"/> Location	Description	 Comment	ScanID	Simulated
<i>Passed</i>				
Fan Shutdown				
General Shutdown		Passed	19119117	<input type="checkbox"/>
Releasing Device				
	Door Holder	Passed	19119118	<input type="checkbox"/>

Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: IRS Building **Control Panel: 1 - EST QuickStart**

The Control & Power Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Comment	Amps	Volts	Pre Test	Post Test
Passed						
Battery						
Sealed Lead Acid	Ground Door 4 Security	Passed	7	12		
Sealed Lead Acid	Ground Door 4 Security	Passed	7	12		
Sealed Lead Acid	Ground G15W	Passed	7.5	12		
Sealed Lead Acid	Ground G15W	Passed	7.5	12		
Sealed Lead Acid	Ground G20W	Passed	7.5	12		
Sealed Lead Acid	Ground G20W	Passed	7.5	12		
Sealed Lead Acid	Ground G5W	Passed	7.5	12		
Sealed Lead Acid	Ground G5W	Passed	7.5	12		
Sealed Lead Acid	Ground G9W	Passed	7.5	12		
Sealed Lead Acid	Ground G9W	Passed	7.5	12		
Sealed Lead Acid	Ground V22S	Passed	7.5	12		
Sealed Lead Acid	Ground V22S	Passed	7.5	12		
Sealed Lead Acid	Ground X24E	Passed	7.5	12		
Sealed Lead Acid	Ground X24E	Passed	7.5	12		
Sealed Lead Acid	Ground X24E	Passed	7.5	12		
Sealed Lead Acid	Ground X24E	Passed	7.5	12		
Sealed Lead Acid	Ground Z19N	Passed	7.5	12		
Sealed Lead Acid	Ground Z19N	Passed	7.5	12		
Sealed Lead Acid	Ground V19N	Passed	7.5	12		
Sealed Lead Acid	Ground V19N	Passed	7.5	12		
Sealed Lead Acid	Ground Electrical Closet	Passed	7.5	12		
Sealed Lead Acid	Ground Electrical Closet	Passed	7.5	12		
Sealed Lead Acid	Ground Electrical Closet	Passed	7.5	12		
Sealed Lead Acid	Ground Electrical Closet	Passed	7.5	12		
Sealed Lead Acid	Ground Computer Room BPS-8	Passed	7.5	12		
Sealed Lead Acid	Ground Computer Room BPS-8	Passed	7.5	12		
Sealed Lead Acid	Ground Room 304	Passed	7.5	12		
Sealed Lead Acid	Ground Room 304	Passed	7.5	12		
Sealed Lead Acid	Ground Telecommunications Room	Passed	7.5	12		
Sealed Lead Acid	Ground Telecommunications Room	Passed	7.5	12		
Sealed Lead Acid	Ground Door 4 Security	Passed	55	12		
Sealed Lead Acid	Ground Door 4 Security	Passed	55	12		

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: IRS Building **Control Panel: 1 - EST QuickStart**

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Item	Category	% of Inventory	Quantity
Horn/Strobe	Indicating	7.10%	13
Strobe	Indicating	0.55%	1
Printer	Control	0.55%	1
Duct Detector	Initiating	16.39%	30
Battery	Control	17.49%	32
Power Supply	Control	8.20%	15
Pull Station	Initiating	13.66%	25
Smoke Detector	Initiating	19.13%	35
Annunciator	Control	1.09%	2
Tamper Switch	Supervisory	6.01%	11
Waterflow Switch	Initiating	4.37%	8
Air Pressure Switch	Supervisory	1.09%	2
Control Panel	Control	0.55%	1
Fan Shutdown	Auxiliary	0.55%	1
Releasing Device	Auxiliary	0.55%	1
Monitoring	Monitor	1.64%	3
Locking Device	Auxiliary	0.55%	1

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

In Service - 90 Days - 1 Year

Werker				
Battery	2	WKA12-7.5F	Sealed Lead Acid	06/13/2012

In Service - 1 Year to 2 Years

Werker				
Battery	4	WKA12-7.5F	Sealed Lead Acid	07/18/2011
Battery	2	WKA12-55C/FR	Sealed Lead Acid	07/07/2011
Battery	24	WKA12-7.5F	Sealed Lead Acid	07/07/2011

Wheelock				
Power Supply	1	PS-24-8MC		07/07/2011

In Service - 3 Years to 5 Years

Locking Device	1		Magnetic Lock	06/05/2008
Monitoring	1		Alarm	06/05/2008
Monitoring	1		Supervisory	06/05/2008
Monitoring	1		Trouble	06/05/2008

EST				
Annunciator	2	SRA-4	LCD Display	06/05/2008
Control Panel	1	QuickStart		06/05/2008
Duct Detector	30	SuperDuct	Photoelectric	06/05/2008

Fan Shutdown	1			06/05/2008
Power Supply	1	BPS6A		06/05/2008
Printer	1	PT-1S		06/05/2008
Pull Station	25	Siga-278	Dual Action	06/05/2008
Releasing Device	1		Door Holder	06/05/2008
Smoke Detector	35	Siga-PS	Photoelectric	06/05/2008
Potter Electric				
Air Pressure Switch	2	PS40-2		06/05/2008
Tamper Switch	11			06/05/2008
Waterflow Switch	8			06/05/2008
Wheelock				
Horn/Strobe	13	NS-24MCC		06/05/2008
Power Supply	12	PS-24-8MC		06/05/2008
Power Supply	1	PS-8		06/05/2008
Strobe	1	RSS-24MCCR		06/05/2008

Zone Address Report

Generated by: BuildingReports.com

Building: IRS Building

Control Panel: 1 - EST QuickStart

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Description	ScanID
0101001	Smoke Detector	Ground Door 4 Security	Photoelectric	3947634147
0101002	Smoke Detector	Ground Door 255	Photoelectric	3947609916
0101003	Smoke Detector	Ground Door 255	Photoelectric	3948941701
0101004	Smoke Detector	Ground Door 335	Photoelectric	3947634437
0101005	Smoke Detector	Ground Door 335	Photoelectric	3948941800
0101006	Smoke Detector	Ground Door 331	Photoelectric	3947638978
0101007	Smoke Detector	Ground Door 331	Photoelectric	3947637223
0101008	Smoke Detector	Ground Door 303	Photoelectric	3947496134
0101009	Smoke Detector	Ground Door 303	Photoelectric	3947431739
0101010	Smoke Detector	Ground Door 302	Photoelectric	3947496103
0101011	Smoke Detector	Ground Door 302	Photoelectric	3947493584
0101012	Smoke Detector	Ground BPS 1 @ G5W	Photoelectric	3947496189
0101013	Smoke Detector	Ground BPS 4 @ G9W	Photoelectric	3947610240
0101015	Smoke Detector	Ground Telecommunications Room	Photoelectric	3947634482
0101016	Smoke Detector	Ground BPS 3 @ G15W	Photoelectric	3947634925
0101017	Duct Detector	Ground AHU 1 Supply Room 202	Photoelectric	08342565
0101018	Duct Detector	Ground AHU 1 Supply By Room 202	Photoelectric	08342564
0101019	Duct Detector	Ground AHU 1 Supply Room 206	Photoelectric	08342563
0101020	Duct Detector	Ground AHU 1 Conference Room 209	Photoelectric	08342562
0101021	Smoke Detector	Ground BPS 5 @ G20W	Photoelectric	3947609633
0101022	Smoke Detector	Ground Computer Hall	Photoelectric	3947634536
0101023	Smoke Detector	Ground Room 304 above BPS-7	Photoelectric	3947609381
0101026	Duct Detector	Roof New Unit 1	Photoelectric	08342525
0101027	Smoke Detector	Ground Computer room above BPS-8	Photoelectric	3947495762
0101029	Duct Detector	Ground Kitchen AHU	Photoelectric	12589916
0101032	Smoke Detector	Ground Electrical Room	Photoelectric	08342522
0101033	Smoke Detector	Ground Electrical Room	Photoelectric	08342591
0101034	Smoke Detector	Ground Electrical Room	Photoelectric	08342520
0101035	Smoke Detector	Ground UPS Room	Photoelectric	11435070
0101036	Duct Detector	Ground UPS Room	Photoelectric	3948735928
0101128	Pull Station	Ground Trophy Case	Dual Action	4894070842
0101132	Pull Station	Ground Door 13 Exit	Dual Action	08342605
0101134	Pull Station	Ground Door 14A Exit	Dual Action	08342589
0101138	Pull Station	Ground Door 1 Lobby	Dual Action	08342523
0101145	Pull Station	Ground Door 2 Exit	Dual Action	08342524
0101146	Pull Station	Ground Door 3 Exit	Dual Action	07239979
0101166	Pull Station	Ground Electrical Room	Dual Action	08342521
0101171	Pull Station	Ground Kitchen	Dual Action	08342603
0101172	Pull Station	Ground Door 12A Exit	Dual Action	08342590
0101173	Waterflow Switch	Ground Loading Dock		08342538
0101174	Tamper Switch	Ground Loading Dock		08342539
0101175	Tamper Switch	Ground Loading Dock		08342542

0101176	Waterflow Switch	Ground Loading Dock		08342541
0101177	Tamper Switch	Ground Loading Dock		08342540
0101178	Tamper Switch	Ground Loading Dock		08342566
0101179	Tamper Switch	Ground Loading Dock		08342567
0101180	Pull Station	Ground by Paper Storage	Dual Action	08342593
0101182	Waterflow Switch	Ground Zone 8		07239971
0101183	Tamper Switch	Ground Zone 8		07239970
0102001	Duct Detector	Roof New Unit 4	Photoelectric	08342583
0102003	Duct Detector	Roof New Unit 3	Photoelectric	08342584
0102005	Smoke Detector	Ground at Computer Room FACP	Photoelectric	3947610073
0102008	Duct Detector	Roof New Unit 2	Photoelectric	08342585
0102010	Duct Detector	Roof RPS supply Q-13	Photoelectric	19119116
0102011	Smoke Detector	Ground Door to RPC	Photoelectric	3947611537
0102012	Smoke Detector	Ground RPS	Photoelectric	3948938428
0102013	Smoke Detector	Ground Above BPS 9 & 10	Photoelectric	3947637582
0102014	Smoke Detector	Ground Door RNC	Photoelectric	3947637919
0102015	Smoke Detector	Ground Door to RPS	Photoelectric	3947609541
0102016	Smoke Detector	Ground BPS 11 @ Z19N	Photoelectric	3947498503
0102017	Duct Detector	Ground North Cafe AHU	Photoelectric	12589917
0102018	Duct Detector	Ground South Cafe AHU	Photoelectric	12589918
0102019	Smoke Detector	Ground Door by Cafeteria	Photoelectric	3947636820
0102020	Smoke Detector	Ground Door by Cafeteria	Photoelectric	3947632464
0102023	Duct Detector	Roof Old Unit 1	Photoelectric	08342527
0102024	Duct Detector	Roof Old Unit 1	Photoelectric	08342582
0102025	Duct Detector	Roof Old Unit 2	Photoelectric	08342526
0102026	Duct Detector	Roof Old Unit 2	Photoelectric	08342581
0102027	Smoke Detector	Ground BPS 12 @ V19N	Photoelectric	3947637155
0102028	Smoke Detector	Ground BPS 13 @ V22S	Photoelectric	3947633768
0102030	Duct Detector	Roof Old Unit 4	Photoelectric	08342530
0102031	Duct Detector	Roof Old Unit 4	Photoelectric	08342529
0102032	Duct Detector	Roof Old Unit 3	Photoelectric	08342531
0102033	Duct Detector	Roof Old Unit 3	Photoelectric	08342532
0102034	Duct Detector	Roof Unit 6	Photoelectric	08342580
0102035	Duct Detector	Roof Unit 7	Photoelectric	08342579
0102036	Smoke Detector	Ground @ BPS 14	Photoelectric	3947610066
0102037	Duct Detector	Roof RPS supply R-10	Photoelectric	19119115
0102038	Duct Detector	Roof West RNC	Photoelectric	08342577
0102039	Duct Detector	Roof West RNC	Photoelectric	08342576
0102040	Duct Detector	Roof SCAMPS	Photoelectric	08342575
0102041	Duct Detector	Roof SCAMPS	Photoelectric	08342574
0102042	Duct Detector	Roof East RNC	Photoelectric	08342578
0102043	Duct Detector	Roof East RNC	Photoelectric	08342535
0102126	Pull Station	Ground Door 4 Lobby	Dual Action	07239993
0102127	Air Pressure Switch	Ground Door 4 Lobby		07239990
0102127	Air Pressure Switch	Ground Zone 8		07239969
0102127	Waterflow Switch	Ground Door 4 Lobby		07239991
0102128	Tamper Switch	Ground Door 4 Lobby		07239992
0102143	Waterflow Switch	Ground Mechanical Room		08342572
0102144	Tamper Switch	Ground Mechanical Room		08342570
0102145	Waterflow Switch	Ground Mechanical Room		08342573
0102146	Tamper Switch	Ground Mechanical Room		08342571
0102149	Pull Station	Roof Penthouse Exit	Dual Action	08342528
0102154	Pull Station	Ground Door 11A Exit	Dual Action	08342595

0102160	Pull Station	Ground Door 11 Exit	Dual Action	08342594
0102161	Pull Station	Ground Door 10 Exit	Dual Action	08342516
0102162	Pull Station	Ground Door 9 Exit	Dual Action	08342599
0102164	Pull Station	Ground Door 4AM/N23 Lobby	Dual Action	07239988
0102165	Pull Station	Ground Door 5A	Dual Action	08342604
0102166	Pull Station	Ground Cafeteria Boiler Room	Dual Action	12589919
0102172	Pull Station	Ground Door 7 Exit	Dual Action	08342600
0102179	Pull Station	Roof Penthouse Exit	Dual Action	08342533
0102186	Pull Station	Roof Penthouse Exit	Dual Action	08342534
0102189	Pull Station	Ground Cafeteria Corridor	Dual Action	08342602
0102190	Pull Station	Ground Cafeteria Corridor	Dual Action	08342601
0102201	Pull Station	Ground Door 8 Exit	Dual Action	08342506
0102405	Waterflow Switch	Ground RNC Door 11A		08342568
0102406	Tamper Switch	Ground RNC Door 11A		08342569
0102407	Waterflow Switch	Ground RNC Door 11A		08342537
0102408	Tamper Switch	Ground RNC Door 11A		08342536