

Work Order Code	Problem Type	Work Description	Problem Location	Date Work Requested	Parts Used	Worker Resolution	Actual Labor Hours
2014010457	MAINTENANCE ODW INT. LIGHTING	2 BALLASTS BAD. 8 LIGHTS OUT.	LASER PRINT	1/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW BALLASTS AND BULBS	2.00
2014010510	MAINTENANCE ODW BLDG/EQUIP. REP	BOILER RM CONDENSATE TREATMENT CHEMICAL PUMP NOT FEEDING CHEMICAL	BOILER RM	1/2/2014		REBUILT CHEMICAL PUMP VALVE BODY AND TESTED PUMP FOR PROPER OPERATION. OK.	1.00
2014011329	MAINTENANCE ODW INT. LIGHTING	AREA 1 MEZZANINE LIGHT NOT WORKING IN HOT DECK ACCESS	AREA 1 MEZZANINE	1/2/2014		REPLACED LIGHT SOCKET. OK.	1.00
2014011332	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 THERE ARE 6 TOILETS THAT ARE CLOGGED	W'S R/R B302	1/2/2014		CLEARED CLOG IN MAIN DRAIN WITH SNAKE AND FLUSHED TOILETS SEVERAL TIMES TO MAKE SURE DRAINS WERE CLEAR.	1.00
2014011782	MAINTENANCE ODW CEILING TILE	MAG HALL RM 31 CEILING TILE ABOVE FAN IS HANGING DOWN	MAG HALL RM 31	1/3/2014		PUT TILE BACK IN TRACK.	0.50
2014012340	MAINTENANCE ODW INT. LIGHTING	W'S R/R A404 THERE ARE 3 LIGHTS OUT	W'S RR A404	1/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS OVER TOILETS 6, 7 AND 8	0.50
2014012376	MAINTENANCE ODW INT. LIGHTING	S SIDE OF POLE 7N LIGHTS BURNED OUT	S SIDE OF POLE 7N	1/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 4 BULBS AND ONE BALLAST	1.00
2014012377	MAINTENANCE ODW INT. LIGHTING	CHILDCARE CAFETERIA LIGHTS BURNED OUT	CHILDCARE CAFETERIA	1/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014012378	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS BURNED OUT	AREA 11	1/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014012379	MAINTENANCE ODW BLDG/EQUIP. REP	HALLWAY CAFETERIA HAS A LOOSE BASEBOARD BY ENTRANCE	HALLWAY CAFETERIA	1/6/2014		REMOVED BASEBOARD, REGLUED AND REAPPLIED	0.50
2014012444	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET CLOGGED	W'S R/R B211	1/7/2014		UNCLOGGED WITH PLUNGER	0.50
2014012446	MAINTENANCE ODW GATE/FENCE	GATE 2 W. RIVER CENTER BLVD. GATE WILL NOT CLOSE	GATE 2	1/7/2014		WEST SIDE OVERLOAD TRIPPED. RESET.	0.50
2014012447	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET CLOGGED	M'S R/R A1005	1/7/2014		UNCLOGGED WITH PLUNGER	0.50
2014012501	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 130 SINK CLOGGED	CHILDCARE	1/7/2014		SNAKED SINK DRAIN TO THE RIGHT OF AQUARIUM	2.00
2014012526	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 FIRST SINK CLOGGED	W'S R/R B211	1/7/2014		ALL SINKS DRAINING PROPERLY UPON RESPONSE	0.50
2014012531	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 HANDICAP STALL IS STOPPED UP AND □ TOILET #2 TOILET SEAT IS LOOSE.	M'S R/R A1005	1/7/2014		UNCLOGGED THE COMMODE AND TIGHTENED TOILET #2'S SEAT	0.50
2014012548	MAINTENANCE ODW INT. LIGHTING	AREA 3 NEAR POLE 4A LIGHTS OUT	AREA 3	1/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012549	MAINTENANCE ODW TEMPERATURE COLD	AREA 4 IS TOO COLD	AREA 4	1/8/2014		TOOK 3 READINGS OF AREA: 70.4, 70.4, 70.3. CHANGED METSYS SPACE SET POINT (75 DEG.)	0.50
2014012584	MAINTENANCE ODW LEAKS	LEAK AT POLE 6EE	POLE 6EE	1/8/2014		NOT AN ACTIVE LEAK. WILL CONTINUE TO MONITOR PERIODICALLY.	1.00
2014012610	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS BURNED OUT	AREA 7	1/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 14 LIGHTS BULBS, VACUUMED 4 LIGHT FIXTURES AND REPLACED 1 LIGHT BALLAST.	1.50
2014012611	MAINTENANCE ODW INT. LIGHTING	MH 34 LIGHT OUT OVER TOILET	MH 34	1/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012612	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 TOILET CLOGGED	M'S R/R A810	1/9/2014		UNCLOGGED WITH PLUNGER	0.50
2014012639	MAINTENANCE ODW INT. LIGHTING	EXTRACTING RM 700 1 LIGHT OUT IN OFFICE AND 2 HAVE TO BE ADJUSTED TO STAY ON	EXTRACTING RM 700	1/9/2014		CHECKED. THE LIGHTS ARE UNDER A WORK STATION (OUT OF MY SCOPE).	0.10
2014012651	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL 3 TOILET CLOGGED	W'S RR A404	1/9/2014		CLEARED CLOG WITH PLUNGER	0.50
2014012652	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A403 TOILET CLOGGED	M'S R/R A403	1/9/2014		CLEARED CLOG WITH PLUNGER	0.50
2014012679	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALLS 1 AND 5 ARE CLOGGED	M'S R/R A1005	1/10/2014		SNAKED HANDICAP COMMODE. PLUNGED COMMODE 5.	0.50
2014012680	MAINTENANCE ODW INT. LIGHTING	AREA 3 POLE 5D LIGHTS OUT	AREA 3	1/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012681	MAINTENANCE ODW PLUMBING	W'S R/R A1003 STALL 1 COMMODE LEAKING	W'S R/R A1003	1/10/2014		REPLACED VACUUM BREAKER. REPLACED RUBBER SLIP RING THAT ATTACHES PIPING TO SPUD.	0.75
2014012744	MAINTENANCE ODW PLUMBING	M'S R/R 1005 STALL 5 COMMODE'S PIPING LEAKING, STALL 1 COMMODE IS CLOGGED	M'S R/R 1005	1/13/2014		TIGHTENED UP FLUSHHEAD. PLUNGED COMMODE.	1.00
2014012745	MAINTENANCE ODW PLUMBING	M'S RM AREA 7 TOILET CONTINUOUSLY RUNNING	M'S RM AREA 7	1/13/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLULSH HEAD ASSEMBLY	0.50
2014012746	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM'S 110, 126 AND HALL BATHROOM LIGHTS OUT	CHILDCARE RM'S 110, 126	1/13/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 3 BULBS IN 110, 3 IN 126 AND 1 IN HALL BATHROOM	0.75
2014012747	MAINTENANCE ODW DOOR	W'S R/R 700H AUTO DOOR BUTTON NOT WORKING	W'S R/R 700H	1/13/2014	9V BATTERY-COV;9V BATTERY ;	REPLACED 9V BATTERY	0.50
2014012748	MAINTENANCE ODW CEILING TILE	AREA 3 CEILING TILE IS STAINED	AREA 3	1/13/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED STAINED CEILING TILE	0.50
2014012769	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 HANDICAP STALL STOPPED UP	W'S R/R A600	1/14/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014012808	MAINTENANCE ODW INT. LIGHTING	RM'S 23 AND 26 LIGHTS BURNED OUT	RM'S 23 AND 36	1/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED (4) F32 T8 TL 735 ALTO	0.50
2014012884	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT AT POLE 5E	AREA 3	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012885	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET CLOGGED	M'S R/R A1005	1/16/2014		CLEARED CLOG WITH PLUNGER	0.50
2014012886	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 COMMODE CLOGGED	W'S R/R B211	1/16/2014		PLUNGED THE COMMODE	0.50
2014012887	MAINTENANCE ODW INT. LIGHTING	W'S R/R B302 LAMPS BURNED OUT	W'S R/R B302	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012888	MAINTENANCE ODW INT. LIGHTING	W'S R/R B302 LIGHTS BURNED OUT	B203	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014012889	MAINTENANCE ODW INT. LIGHTING	B200 LAMPS BURNED OUT	B200	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014012890	MAINTENANCE ODW INT. LIGHTING	M'S R/R B309 LAMPS BURNED OUT	M'S R/R B309	1/16/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012891	MAINTENANCE ODW INT. LIGHTING	CENTRAL PLANT LIGHTS BURNED OUT	CENTRAL PLANT	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014012892	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILETS CLOGGED	M'S R/R B309	1/16/2014		UNCLOGGED WITH PLUNGER	0.50
2014012893	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT IN FIXTURE AT BOTTOM OF RAMP TO 300	AREA 3	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014012894	MAINTENANCE ODW TEMPERATURE COLD	POLE 8K CHECK TEMP	POLE 8K	1/16/2014		LOW 73.2. HIGH 73.7. NO ADJUSTMENT.	0.50
2014012895	MAINTENANCE ODW TEMPERATURE COLD	POLE 10 N-L TOO COLD	POLE 10 N-L	1/16/2014		TEMPS READ LOW 73.1. HIGH 73.7. NO ADJUSTMENT.	0.50
2014012896	MAINTENANCE ODW INT. LIGHTING	B313 LAMPS BURNED OUT	B313	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITI H NEW	1.00
2014012897	MAINTENANCE ODW INT. LIGHTING	B314 LAMPS BURNED OUT	B314	1/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014012929	MAINTENANCE ODW TEMPERATURE COLD	8-O TOO COLD	8-O	1/16/2014		SPACE TEMP 73 DEG. RAISED SET POINT TO 74 DEG.	0.50
2014012930	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R 700H HANDICAP BUTTON IN AND OUT NOT WORKING	W'S R/R 700H	1/16/2014		REPLACED FUSE BETWEEN CONTROLLER AND MOTOR	0.00
2014012932	MAINTENANCE ODW RESTROOM FIXTURE	DOORS WILL NOT OPEN	W'S R/R B211	1/16/2014	DOOR OPERATOR-COV;DOOR OPERATOR ;	DOOR CONTROLLER DEFECTIVE. REPLACED DOOR OPERATOR CONTROLLER. TESTED DOOR FOR PROPER OPERATION. OK.	4.00
2014012942	MAINTENANCE ODW DOOR	DOOR 18 IS MAKING NOISE	DOOR 18	1/17/2014		LUBED ALL HINGES AND PIVOT POINTS	0.50
2014012983	MAINTENANCE ODW CEILING TILE	POLE 7V PANEL HAS WATER DAMAGE	POLE 7V	1/21/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILING TILE	0.50
2014012996	MAINTENANCE ODW INT. LIGHTING	RM 201 LIGHT LENS FALLING. RM 201 CEILING TILE NEEDS REPLACED DUE TO WATER STAIN.	RM 201	1/21/2014	CEILING TILE-COV;CEILING TILE ;	NEW BRAKETS WERE USED TO KEEP THE LENS IN PLACE.REPLACED CEILING TILE.	1.00
2014012997	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 FLOOR TILES LOOSE	CHILDCARE RM 128	1/21/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	PUT DOWN GLUE AND INSTALLED TILES	1.00
2014012998	MAINTENANCE ODW DOOR	ALL CHILDCARE DOOR HANDLES ARE LOOSE	CHILDCARE	1/21/2014		TIGHTENED ALL DOOR HANDLES, TOOK OFF COVERS AND TIGHTENED SCREWS	1.00

2014012999	MAINTENANCE ODW DOOR	CHILDCARE RM 109 DOOR LATCH BROKEN	CHILDCARE RM 109	1/21/2014		REPLACED HANDLE	0.50
2014013000	MAINTENANCE ODW INT. LIGHTING	CHILDCARE LIGHT BURNED OUT	CHILDCARE	1/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULB	0.50
2014013001	MAINTENANCE ODW INT. LIGHTING	AREA 3 HAS A BROKEN LENS COVER AT CUBICLE 01-03-055 S OF POLE 56	AREA 3	1/21/2014		REPLACED BROKEN COVER	0.50
2014013002	MAINTENANCE ODW INT. LIGHTING	AREA 3 PAST RAMP TO 300 LIGHTS BURNED OUT	AREA 3 RAMP TO 300	1/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;		0.50
2014013051	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A1003 STALL 20 COMMODE CONSTANTLY RUNNING	W'S R/R A1003	1/22/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD	0.50
2014013052	MAINTENANCE ODW DOOR	W'S R/R A306 AUTO DOOR BROKEN	W'S R/R A306	1/22/2014	9V BATTERY-COV;9V BATTERY ;	REPLACED BATTERY ON INSIDE DOOR BUTTON	0.50
2014013053	MAINTENANCE ODW INT. LIGHTING	CHILLER RM LIGHTS BURNED OUT	CHILLER RM	1/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014013120	MAINTENANCE ODW INT. LIGHTING	RM 816 LIGHTS OUT	RM 816	1/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014013121	MAINTENANCE ODW INT. LIGHTING	W'S R/R A811 LIGHTS OUT	W'S R/R A811	1/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014013122	MAINTENANCE ODW INT. LIGHTING	RM 809 LIGHTS OUT	RM 809	1/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 4 LIGHT BULBS	0.50
2014013176	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A-700H WATER HEATER LEAKING WATER	W'S R/R A-700H	1/23/2014	DIELECTRIC UNION-COV;DIELECTRIC UNION ;; WATER HEATER-COV;2.5 GAL WATER HEATER ;	REMOVED AND REPLACED HOT WATER HEATER	3.50
2014013206	MAINTENANCE ODW DOOR	B2 AUTO HANDICAP DOOR WILL NOT CLOSE	B2	1/24/2014		BENT SENSOR BACK INTO PLACE	0.75
2014013207	MAINTENANCE ODW BLDG/EQUIP. REP	CENTRAL PLAN PUNCH CONDENSOR TUBES	CENTRAL PLANT	1/24/2014		PUNCHED TUBES AND CLEANED UP	2.50
2014013208	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL 1 COMMODE IS CLOGGED	M'S R/R A-1005 STALL 1	1/24/2014		PLUNGED THE COMMODE	0.50
2014013209	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT RESPOND FROM COMMAND CENTER	GATEHOUSE 2	1/24/2014		OPENED GATE AT GATEHOUSE MANUALLY	1.00
2014013210	MAINTENANCE ODW DOOR	CHILDCARE STAFF LOUNGE RESTROOM DOOR WILL NOT LOCK	CHILDCARE STAFF LOUNGE	1/24/2014		INSTALLED NEW DOOR KNOB	0.50
2014013211	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 126 LOCK ON THE LOCKED CABINET IS NOT WORKING	CHILDCARE RM 126	1/24/2014		REBUILT LOCK CYLINDER	0.50
2014013212	MAINTENANCE ODW INT. LIGHTING	POLE 4A CEILING LIGHT IS OUT	POLE 4A	1/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014013213	MAINTENANCE ODW INT. LIGHTING	POLE 4C LIGHTS FLASHING	POLE 4C	1/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LIGHT BALLAST AND 2 LIGHT BULBS	1.00
2014013214	MAINTENANCE ODW TEMPERATURE COLD	MAG HALL 3A TOO COLD	MAG HALL 3A	1/24/2014		UNIT IS PROVIDING MAXIMUM HEAT. NO ACTION TAKEN.	0.25
2014013241	MAINTENANCE ODW FLOOR TILE	20 FEET OUT FROM POLE 1DD THERE IS A HOLE. TILE NEEDS REPLACED.	POLE 1DD	1/24/2014		REPLACED FLOOR TILE	0.50
2014013262	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	1/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHT BULBS	0.50
2014013263	MAINTENANCE ODW INT. LIGHTING	AERA 10 OVERHEAD LIGHTS OUT	AREA 10	1/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 36 LIGHT BULBS AND 1 BALLAST. VACUUMED 9 LIGHT LENS COVERS.	2.25
2014013325	MAINTENANCE ODW DOOR	CHILDCARE HINGE TO MAIN ENTRANCE DOOR IS LOOSE	CHILDCARE	1/28/2014		REINSTALLED DOOR HINGE	0.50
2014013365	MAINTENANCE ODW CEILING TILE	MAG HALL 51 TWO CEILING TILES STAINED	MAG HALL 51	1/29/2014		REPLACED TILES AND CLEANED UP	0.50
2014013366	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A-700H STALL 5 COMMODE CONTINUOUSLY RUNNING	W'S R/R A-700H STALL 5	1/29/2014	AA BATTERIES-COV;AA BATTERIES ;	REPAIRED COMMODE. REPLACED FLUSH HEAD BATTERIES.	0.50
2014013506	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL 1 IS CLOGGED	M'S R/R A1005 STALL 1	1/31/2014		PLUNGED THE COMMODE	0.50
2014013507	MAINTENANCE ODW INT. LIGHTING	AREA 3 AT POLE 5E LIGHTS OUT	AREA 3	1/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS AND COVER	1.00
2014013508	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A4 TOILET IS CLOGGED	M'S R/R A4	1/31/2014		PLUNGED THE COMMODE	0.50
2014013509	MAINTENANCE ODW INT. LIGHTING	RM 903 OVERHEAD LIGHTS OUT	RM 903	1/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHT BULBS	0.50
2014013528	MAINTENANCE ODW BLDG/EQUIP. REP	CENTRAL PLANT MOTOR BEARINGS NOISY. ADDING GREASE DOES NOT QUIET THEM.	CENTRAL PLANT	1/31/2014		1-30-14 DISASSEMBLED MOTOR AND REMOVED MOTOR BEARINGS. 1-31-14 INSTALLED NEW BEARINGS AND REASSEMBLED MOTOR. GREASED NEW BEARINGS AND CHECKED MOTOR OPERATION. OK.	8.00
2014020373	MAINTENANCE ODW INT. LIGHTING	RM 1002 HAS OVERHEAD LIGHTS OUT	RM 1002	2/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014020374	MAINTENANCE ODW PLUMBING	M'S R/R A602 RIGHT URINAL WILL NOT TURN OFF	M'S R/R A602	2/3/2014	DIAPHRAGM-COV;DIAPHRAGM ;; STOP REPAIR KIT-COV;STOP REPAIR KIT ;	REPLACED DIAPHRAGM KIT ON FLUSHOMETER. REBUILT STOP VALVE. VACUUMED WATER OFF FLOOR.	1.00
2014020375	MAINTENANCE ODW INT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	2/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 18 LIGHT BULBS. VACUUMED 6 LIGHT FIXTURES. REPLACED 1 LIGHT BALLAST.	2.00
2014020376	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL 2 IS CLOGGED	M'S R/R B309	2/3/2014		PLUNGED THE COMMODE	0.50
2014020378	MAINTENANCE ODW INT. LIGHTING	201 SEVERAL LAMPS OUT	201	2/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014020379	MAINTENANCE ODW INT. LIGHTING	AREA 5 SEVERAL LAMPS BURNED OUT	AREA 5	2/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014020380	MAINTENANCE ODW DOOR	DOOR 18 DRAGGING ON THRESHOLD	DOOR 18	2/3/2014		RAISED UP DOOR. OK NOW.	0.50
2014020382	MAINTENANCE ODW CEILING TILE	903 STAINED TILE	903	2/3/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED TILE	1.00
2014021678	MAINTENANCE ODW DOOR	W'S R/R A404 LAMINATE ON DOOR IS TORN OFF	W'S R/R A404	2/4/2014	LAMINATE-COV;LAMINATE ;	TOOK DOOR AND PIECES TO SHOP. TORE OFF OLD LAMINATE AND REPLACED. REHUNG DOOR.	1.75
2014021679	MAINTENANCE ODW PLUMBING	M'S R/R A810 URINAL WILL NOT FLUSH	M'S R/R A810	2/4/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD WITH NEW STOCK	0.50
2014021680	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT NEAR POLE 4E	AREA 3	2/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014021681	MAINTENANCE ODW PLUMBING	M'S R/R B309 TOILET WILL NOT FLUSH	M'S R/R B309	2/4/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD AND FLUSHOMETER	0.50
2014021682	MAINTENANCE ODW INT. LIGHTING	AREA 14 LAMPS BURNED OUT	AREA 14	2/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014021683	MAINTENANCE ODW INT. LIGHTING	LASER PRINT LAMPS BURNED OUT	LASER PRINT	2/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014021685	MAINTENANCE ODW PLUMBING	W'S R/R A5 SINK CONTINUOUSLY RUNNING	W'S R/R A5	2/4/2014	C BATTERIES-COV;C BATTERIES ;; SOLENOID-COV;SOLENOID ;	REPLACED BATTERIES AND SOLENOID	1.00
2014021687	MAINTENANCE ODW PLUMBING	R/R 103D URINAL CONTINUOUSLY RUNNING	R/R 103D	2/4/2014		REPLACED FLUSH HEAD WITH NEW	1.00
2014022476	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 HANDICAP STALL AND STALL 14 ARE STOPPED UP	W'S R/R A600	2/6/2014		CLEARED CLOGGED TOILETS WITH PLUNGER. OK.	0.50
2014022478	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R A1005 SINK #1 FAUCET IS LOOSE	M'S R/R A1005 SINK #1	2/6/2014	C BATTERIES-COV;C BATTERIES ;	REPLACED WING NUTS AND BATTERIES. SECURED FAUCET TO WASH BASIN.	1.00
2014022489	MAINTENANCE ODW INT. LIGHTING	AREA 14 B319 2 CEILING LIGHTS OUT AND 1 IS FLICKERING	AREA 14 B317	2/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 3 BALLASTS AND 1 LAMP. ACCESSED AREA BY USING LIFT.	4.00
2014022534	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A600 STALL 11 TOILET PAPER DISPENSER IS BROKEN	W'S R/R A600 STALL 11	2/7/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REPLACED DISPENSER	0.50
2014022535	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B302 STALL 6 TOILET WILL NOT FLUSH	W'S R/R B302 STALL 6	2/7/2014		REPLACED FLUSHOMETER	0.50
2014022536	MAINTENANCE ODW INT. LIGHTING	RM 108 HALLWAY LIGHTS OUT AND BALLAST IS BAD	RM 108 HALLWAY	2/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LAMPS AND BALLAST	1.50
2014022538	MAINTENANCE ODW PLUMBING	W'S R/R A600 HANDICAP SINK WILL NOT COME ON	W'S R/R A600 HANDICAP SINK	2/7/2014	C BATTERIES-COV;C BATTERIES ;	REPLACED BATTERIES	0.50
2014022539	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 STALL 8 STOPPED UP	W'S R/R B302 STALL 8	2/7/2014		PLUNGED TOILET. NOW CLEAR.	0.50
2014022540	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 HANDICAP STALL STOPPED UP	M'S R/R A1005 HANDICAP STALL	2/7/2014		UNSTOPPED TOILET. PLUNGED UNTIL CLEAR. FLUSHING CORRECTLY.	0.50
2014022609	MAINTENANCE ODW INT. LIGHTING	M'S R/R A308 2 LIGHTS OUT	M'S R/R A308	2/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014022610	MAINTENANCE ODW INT. LIGHTING	HALLWAY 21 WEST LIGHTS OUT	HALLWAY 21 WEST	2/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50

2014022611	MAINTENANCE ODW INT. LIGHTING	AREA 11 BURNED OUT BULBS AND BALLAST IS BAD	AREA 11	2/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BULBS AND BALLAST	2.00
2014022612	MAINTENANCE ODW INT. LIGHTING	AREA 9 LENS COVER FALLING OUT OF FRAME	AREA 9	2/10/2014		REINSTALLED LENS COVER	0.50
2014022613	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 108 TEACHER'S LOUNGE LIGHTS OUT	CHILDCARE RM 108	2/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BURNED OUT BULBS	0.75
2014022614	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL 3 COMMODE IS CLOGGED	M'S R/R B309 STALL 3	2/10/2014		PLUNGED THE COMMODE	0.50
2014022615	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL 9 COMMODE IS CLOGGED	W'S R/R B211 STALL 9	2/10/2014		PLUNGED THE COMMODE	0.50
2014022657	MAINTENANCE ODW FLOOR TILE	COVER OFF FLOOR TILE SOUTH OF POLE 70	AREA 5	2/11/2014		REPLACED TILE	0.50
2014022658	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET #5 CLOGGED	M'S R/R A1005	2/11/2014		UNCLOGGED WITH PLUNGER	0.50
2014022659	MAINTENANCE ODW INT. LIGHTING	AREA 13 LAMPS BURNED OUT	AREA 13	2/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014022660	MAINTENANCE ODW INT. LIGHTING	6FF LIGHT COVER IS HANGING	6FF	2/11/2014		REHUNG LIGHT LENS. OK.	0.50
2014022663	MAINTENANCE ODW PLUMBING	M'S R/R A700i TOILETS WILL NOT FLUSH	M'S R/R A700i	2/11/2014		CLEARED CLOG WITH PLUNGER	0.50
2014022691	MAINTENANCE ODW POWER OUTAGE	RM B315 NO POWER TO MACHINES	RM B315 LASER PRINT	2/12/2014		RESET PDU IN ROOM B315	0.50
2014022693	MAINTENANCE ODW PLUMBING CLOG	RM B303 SLOP SINK WILL NOT DRAIN	RM B303	2/12/2014		AG: VACUUMED TRAP. RAN RIGID FLOOR MACHINE CABLE DOWN DRAIN APPROXIMATELY 40 FEET. MM: SNAKED DRAIN. OK.	2.50
2014022694	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 STALL 2 COMMODE IS CLOGGED	W'S R/R A5 STALL 2	2/12/2014		UNCLOGGED THE COMMODE	0.50
2014022695	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP STALL CLOGGED	M'S R/R A810	2/12/2014		UNCLOGGED THE COMMODE	0.50
2014022725	MAINTENANCE ODW CEILING TILE	POLE 6X TWO CEILING TILES HAVE WET SPOTS	POLE 6X	2/12/2014		LOCATED LEAK. PLACED A LEAK CONTAINMENT PAN IN AREA. ONCE WEATHER PERMITS, LEAK WILL BE FIXED AND TILES REPLACED.	0.50
2014022726	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP STALL STOPPED UP	M'S R/R A810	2/12/2014		UNCLOGGED THE COMMODE	0.50
2014022731	MAINTENANCE ODW TEMPERATURE COLD	W'S R/R A34 TOO COLD	W'S R/R A34	2/12/2014		CHECKED TEMP WITH THERMOMETER AT 70.6 DEG F. RAISED TEMP ON THERMOSTAT 2 DEGS.	0.50
2014022732	MAINTENANCE ODW PLUMBING	W'S R/R A34 WATER FROM FAUCET IS TOO COLD	W'S R/R A34	2/12/2014		CHECKED BOTH FAUCETS AND THE WATER WAS WARM.	0.50
2014022733	MAINTENANCE ODW TEMPERATURE COLD	W'S R/R A404 TOO COLD	W'S R/R A404	2/12/2014		ROOM TEMP 73 DEG. OK.	0.50
2014022734	MAINTENANCE ODW PLUMBING	W'S R/R A404 WATER FROM FAUCET IS TOO COLD	W'S R/R A404	2/12/2014		SINKS 1 THROUGH 6 HAD HOT WATER SHUT OFF. OK NOW.	0.50
2014022748	MAINTENANCE ODW LEAKS	NORTH BREEZEWAY B312 CEILING IS LEAKING	NORTH BREEZEWAY B12	2/12/2014		LEAK HAS STOPPED. WILL CONTINUE TO MONITOR. WILL CHECK AGAIN ONCE WEATHER PERMITS.	0.50
2014022752	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 123 TOILET CLOGGED	CHILDCARE RM 123	2/12/2014		ACTUAL ROOM NUMBER IS 130 (WRONG NUMBER CALLED IN). PLUNGED THE COMMODE.	0.50
2014022753	MAINTENANCE ODW PLUMBING	W'S R/R A700H TOILET IS OVERFLOWING	W'S R/R A700H	2/12/2014		CLEARED CLOG WITH PLUNGER	0.50
2014022769	MAINTENANCE ODW DOOR	RM 4 INSIDE BUTTON TO AUTO DOOR NOT WORKING	RM 4	2/13/2014	9V BATTERY-COV;9V BATTERY ;	REPLACED BATTERY	0.50
2014022770	MAINTENANCE ODW PLUMBING	W'S R/R A700H SINK HAS CONTINUOUSLY RUNNING WATER	W'S R/R A700H	2/13/2014	C BATTERIES-COV;C BATTERIES ;; SOLENOID-COV;SOLENOID ;	REPAIRED TWO FAUCETS THAT WOULD NOT TURN ON	1.25
2014022771	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A700i TOILET STOPPED UP	M'S R/R A700i	2/13/2014		CLEARED CLOG WITH PLUNGER	0.50
2014022812	MAINTENANCE ODW INT. LIGHTING	MAG HALL OUTSIDE RM 17 LIGHTS OUT	MAG HALL	2/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014022813	MAINTENANCE ODW INT. LIGHTING	POLE 50 AREA 4 LIGHTS OUT	POLE 50 AREA 4	2/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014022814	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 HANDICAP COMMODE IS CLOGGED	M'S R/R A1005	2/14/2014		PLUNGED COMMODE	0.50
2014022827	MAINTENANCE ODW GATE/FENCE	GATE 2 WEST SIDE WILL NOT CLOSE	GATE 2	2/14/2014		GATE DRAGGING ON CONCRETE. RAISED MOUNTING BRACKETS TO CLEAR GROUND. RAISED GATE APPROXIMATELY 1 INCH. CYCLED GATE TO CHECK FOR PROPER OPERATION. OK.	2.50
2014022859	MAINTENANCE ODW DOOR	W'S R/R A700H ELECTRIC DOOR OPENER NOT WORKING	W'S R/R A700H	2/18/2014		REPLACED BLOWN FUSE	0.50
2014022860	MAINTENANCE ODW INT. LIGHTING	AREA 3 POLE 3C NEEDS LIGHT LENS REPLACED	AREA 3 POLE 3C-4C	2/18/2014		AREA 3 BETWEEN POLES 4C AND 3C. REPLACED BROKEN COVER 2'X4'.	0.50
2014022862	MAINTENANCE ODW INT. LIGHTING	SCAMPS LIGHTS OUT	SCAMPS	2/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 4 LIGHT BULBS	0.50
2014022863	MAINTENANCE ODW INT. LIGHTING	AREA 8 FOUR OVERHEAD LIGHTS OUT	AREA 8	2/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 4 LIGHT BULBS	0.50
2014022864	MAINTENANCE ODW PLUMBING	CHILDCARE RM 128 FAUCET LEAKS	CHILDCARE RM 128	2/18/2014	DIAPHRAGM-COV;DIAPHRAGM ;	TOOK FAUCET APART AND REPLACED DIAPHRAGM	0.50
2014022865	MAINTENANCE ODW DOOR	RM 128 LOCK NOT WORKING ON CABINET	RM 128	2/18/2014		REPAIRED LOCK	0.50
2014022867	MAINTENANCE ODW DOOR	RM 130 LOCK NOT WORKING ON CABINET	RM 130	2/18/2014		REPAIRED LOCK	0.50
2014022868	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT AT POLE 5S	AREA 4	2/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014022869	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHT COVER BROKEN NEAR POLE 8W	AREA 9	2/18/2014		REPLACED BROKEN COER AND CLEANED UP.	0.50
2014022873	MAINTENANCE ODW INT. LIGHTING	COURTYARD CANTEEN LIGHTS OUT	COURTYARD CANTEEN	2/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014022880	MAINTENANCE ODW DOOR	SECURITY OFFICE DOOR TO 203 NOT CLOSING	SECURITY OFFICE DOOR 203	2/18/2014		ADJUSTED DOOR CLOSER	0.50
2014022881	MAINTENANCE ODW FLOOR TILE	RM 128 FLOOR TILES CHIPPED AND LOOSE	RM 128	2/18/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REMOVED 4 FLOOR TILES, CLEANED FLOOR AND REPALCED 4 TILES	1.50
2014022961	MAINTENANCE ODW INT. LIGHTING	AREA 3 OUTSIDE A310 LAMPS OUT	AREA 3 OUTSIDE A310	2/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014022963	MAINTENANCE ODW DOOR	RM B211 DOOR WILL NOT PUSH OPEN	RM B211	2/19/2014		TURNUED PUSH OPEN SWITCH ON THE AUTO DOOR CONTROLLER TO THE ON POSITION	0.50
2014022964	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL 14 COMMODE IS CLOGGED	W'S R/R B211 STALL 14	2/19/2014		PLUNGED THE COMMODE	0.50
2014022970	MAINTENANCE ODW DOOR	CHILDCARE RM 128 KEY STUCK IN CABINET	CHILDCARE RM 128	2/19/2014		WRONG KEY FORCED INTO LOCK. HAD TO REMOVE KEY CYLINDER TO REMOVE KEY. REASSEMBLED LOCK AND OPERATED IT TO MAKE SURE IT WOULD WORK.	1.00
2014023008	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET CLOGGED	M'S R/R A1005	2/20/2014		UNCLOGGED WITH PLUNGER	0.50
2014023119	MAINTENANCE ODW ELECTRICAL	SOUTH HALLWAY OUTLETS OUTSIDE RM 303 NOT WORKING	SOUTH HALLWAY	2/24/2014		RESET TWO BREAKERS, PANEL LB3F2 BREAKERS 1 AND 2, RM 303A	0.50
2014023121	MAINTENANCE ODW BLDG/EQUIP. REP	B BUILDING NEEDS CEILING LEAK BUCKETS EMPTIED	B BUILDING	2/24/2014		COMPLETE	0.50
2014023122	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 SINK ON SOUTH WALL LEAKING	CHILDCARE RM 130	2/24/2014	DIAPHRAGM-COV;DIAPHRAGM ;	REBUILT LEAKING FAUCET (SOUTH SIDE). SNAKED DRAIN CONNECTING BOTH SINKS. REPALCED TWO LEAKING NO HUB COUPLERS WITHN EW IN DRAIN LINE.	4.50
2014023123	MAINTENANCE ODW INT. LIGHTING	AREA 5 HAS LAMPS BURNED OUT	AREA 5	2/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014023124	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHT FIXTURE NOT WORKING	AREA 1	2/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.00
2014023125	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS BURNED OUT	AREA 11	2/24/2014		REPLACED BULBS	1.00
2014023126	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LIGHTS OUT NEAR POLE 5M	AREA 4 WEST	2/24/2014		REPLACED LAMPS	0.50
2014023127	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 7 TWO LIGHTS OUT	MAG HALL RM 7	2/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LAMPS	0.50
2014023194	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 URINAL CLOGGED	M'S R/R A810	2/25/2014		UNCLOGGED WITH PLUNGER	0.50
2014023216	MAINTENANCE ODW PLUMBING CLOG	MAG HALL RM 35 TOILET IS CLOGGED	MAG HALL RM 35	2/25/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014023237	MAINTENANCE ODW INT. LIGHTING	CONTROL RM A102 LAMPS OUT OVER COMPUTER	CONTROL RM A102	2/26/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014023238	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST NEAR POLE 5K LIGHTS OUT	AREA 3 EAST	2/26/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS. FIXED SAGGING COVER.	0.50

2014023260	MAINTENANCE ODW BLDG/EQUIP. REP	DOCK/COMPACTOR ELECTRIC UNIT HEATER FAN HOT BLOWING	DOCK/COMPACTOR	2/26/2014	FAN BLADE-COV;FAN BLADE ;	DISASSEMBLED UNIT TO REPLACE FAN. FOUND BROKEN MOTOR COOLING FAN AND REPLACED. REASSEMBLED UNIT AND CHECKED FOR PROPER OPERATION. OK.	6.00
2014023293	MAINTENANCE ODW INDOOR AIR QUAL	AREA 3 EAST BAD ODOR BETWEEN 4J AND 5J	AREA 3 EAST	2/27/2014		CHECKED ENTIRE AREA. THE ONLY ODORS DETECTED WERE CUSTODIAL CLEANING FLUIDS AND BURNED POPCORN FROM COURTYARD CANTEEN.	0.50
2014023294	MAINTENANCE ODW INT. LIGHTING	RM 813 LIGHTS OUT	RM 813	2/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED THREE LIGHT BULBS	0.50
2014023295	MAINTENANCE ODW INT. LIGHTING	RM 805 LIGHTS OUT	RM 805	2/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014023296	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	2/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FIVE LIGHT BULBS	0.50
2014023297	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	2/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED SEVEN LIGHT BULBS AND VACUUMED TWO LIGHT FIXTURES	0.75
2014023298	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET CLOGGED	W'S R/R B211	2/27/2014		UNCLOGGED WITH PLUNGER. ADJUSTED SUPPLY VALVE TO GIVE A STRONGER FLUSH.	0.50
2014023299	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B302 TOILET WILL NOT FLUSH	W'S R/R B302	2/27/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD WITH NEW STOCK	0.50
2014023310	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A-700H THIRD TOILET CLOGGED	W'S R/R A-700H	2/27/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014023355	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 LEFT URINAL CLOGGED	M'S R/R A810	2/28/2014		PLUNGED THE URINAL DRAIN	0.50
2014023356	MAINTENANCE ODW ELECTRICAL	POLE 5HH FLOOR ELECTRICAL OUTLET SPARKED IN CUBICLE GDI-01-13-207	POLE 5HH	2/28/2014		LOOKS LIKE SOMETHING SHORTED ELECTRICAL PLUG THAT WAS IN ORANGE OUTLET. CLEANED OUT ALL METAL ITEMS IN FLOOR OUTLET BOX AND REINSTALLED COVER. OK NOW.	0.50
2014023357	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP COMMODE IS CLOGGED	M'S R/R A810	2/28/2014		PLUNGED THE COMMODE	0.50
2014023358	MAINTENANCE ODW TEMPERATURE COLD	AREA 8K TOO COLD	AREA 8K	2/28/2014		METSYS READING 75 DEG. TOOK THREE AREA READINGS: 73.2, 73.3, 73.2. WITHIN CONTRACT. MADE NO ADJUSTMENTS.	0.50
2014023359	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHTS BURNED OUT	SATELLITE CANTEEN	2/28/2014		REPLACED LAMPS	0.50
2014023360	MAINTENANCE ODW BLDG/EQUIP. REP	DOOR 18 HALLWAY COVE BASE CAME OFF OF WALL	DOOR 18 HALLWAY	2/28/2014		REATTACHED COVE BASE TO WALL WITH POWER GRAB	0.50
2014023361	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 9 HALLWAY CORNER OF RAIL IS BROKEN	AREA 9 HALLWAY	2/28/2014		REPLACED CORNER	0.50
2014030523	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404, STALL 3 TOILET CLOGGED	W'S R/R A404, STALL 3	3/3/2014		PLUNGED THE COMMODE	0.50
2014030524	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS BURNED OUT	AREA 1	3/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014030525	MAINTENANCE ODW INT. LIGHTING	M'S R/R A602 LIGHTS BURNED OUT	M'S R/R A602	3/3/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014030526	MAINTENANCE ODW DOOR	RM 1005 AUTO DOOR RUBBING AGAINST DOOR FRAME	RM 1005	3/3/2014		TIGHTENED ALL HINGE SCREWS	0.50
2014030527	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 LIGHTS BURNED OUT	W'S R/R A1003	3/3/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 1 COMPACT FLOURSCENT AND 2 FLOURSCENT BULBS	0.50
2014030528	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	3/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 20 LIGHT BULBS	0.75
2014031201	MAINTENANCE ODW INT. LIGHTING	W'S R/R A600 LIGHTS OUT	W'S R/R A600	3/3/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014031202	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A1003 EXHAUST VENTS DIRTY OVER COMMODES	W'S R/R A1003	3/3/2014		VACUUMED EXHAUST VENTS AND LIGHT COVERS.	0.75
2014031954	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 BETWEEN POLES 8D-8G TOO HOT	AREA 1 POLES 8D-8G	3/4/2014			0.50
2014033036	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B211 HANDICAP STALL TOILET SEAT IS LOOSE (NOT SURE WHICH ONE)	W'S R/R B211 HANDICAP STALL	3/4/2014		TIGHTENED MOUNTING NUTS ON #7	0.50
2014033039	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R A810 URINAL OVERFLOWING	M'S R/R A810	3/4/2014		UNCLOGGED #1 WITH PLUNGER	0.50
2014033089	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 6HH EMPTY BUCKET	POLE 6HH	3/5/2014		REPLACED BUCKET	0.50
2014033102	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 #4 TOILET CLOGGED. LAMPS OUT OVER #8.	W'S R/R A600	3/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	UNCLOGGED TOILET. REPLACED LAMPS.	0.50
2014033103	MAINTENANCE ODW BLDG/EQUIP. REP	SHOP HALL WALL MARKED UP DUE TO LIGHT CART RUBBING AGAINST IT	SHOP HALL	3/6/2014		PAINTED OVER THE MARKS ON WALL	0.75
2014033104	MAINTENANCE ODW INT. LIGHTING	AREA 3 LENS FELL FROM LIGHT FIXTURE	AREA 3	3/6/2014		CLEANED UP THE BROKEN LENS AND PUT A NEW LENS IN FIXTURE	1.00
2014033105	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET CLOGGED	W'S R/R B211	3/6/2014		UNCLOGGED WITH PLUNGER	0.50
2014033106	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #4 CLOGGED	W'S R/R A600	3/6/2014		UNCLOGGED WITH PLUNGER	0.50
2014033107	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 130 SINK TO THE LEFT OF AQUARIUM WILL NOT DRAIN	CHILDCARE RM 130	3/6/2014		REMOVED TRAP OF SINK AND CLEANED OUT STIR STICKS AND RICE	1.00
2014033141	MAINTENANCE ODW BLDG/EQUIP. REP	LOBBY HALLWAY BLOWER MOTOR CYCLING ON THERMAL OVERLOAD	LOBBY HALLWAY	3/6/2014	CAPACITOR-COV;CONDENSER FAN MOTOR RUN CAPACITOR ;	BLOWER MOTOR FAULTY. REPLACED MOTOR AND CAPACITOR. TESTED BLOWER FOR PROPER OPERATION. OK.	6.00
2014033152	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 STALL #2 CLOGGED	W'S R/R A1003	3/6/2014	DIAPHRAGM-COV;DIAPHRAGM ;	PLUNGED COMMODE. COMMODE WAS MAKING LOUD NOISES WHEN VALVE SLAMMED SHUT. REPLACED INSIDE PART WHEN TIGHTENING DIAPHRAGM ASSEMBLY DID NOT WORK.	0.50
2014033154	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 HANDICAP STALL IS CLOGGED	M'S R/R A1005	3/6/2014		SNAKED COMMODE	0.50
2014033177	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL 4 COMMODE IS CLOGGED	W'S R/R B211 STALL 4	3/7/2014		UNCLOGGED COMMODE	0.50
2014033178	MAINTENANCE ODW PLUMBING CLOG	RM 1006 CUSTODIAN SLOP SINK IS CLOGGED	RM 1006	3/7/2014		VACUUMED OUT TRAP. SNAKED DRAIN LINE.	1.00
2014033179	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALLS 1 AND 3 TOILETS CLOGGED	M'S R/R B309	3/7/2014		PLUNGED TWO COMMODES	0.50
2014033181	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE TEACHER'S LOUNGE TOILET CLOGGED	CHILDCARE TEACHER'S LOUNGE	3/7/2014		UNCLOGGED TOILET. FLUSHES OK.	0.50
2014033184	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 FIRST STALL ON LEFT IS CLOGGED	W'S R/R A600	3/7/2014		UNCLOGGED THE COMMODE IN STALL 4	0.50
2014033191	MAINTENANCE ODW PLUMBING	W'S R/R A306 A TOILET CONTINUES TO RUN (WAS NOT GIVEN THE STALL NUMBER)	W'S R/R A306	3/7/2014		FLUSHED ALL STALLS THREE TIMES. ALL TOILETS WORKING CORRECTLY. NO PROBLEMS FOUND.	0.50
2014033224	MAINTENANCE ODW BLDG/EQUIP. REP	DOOR B2 RA CONTRETE STOPPER MISSING AND NEEDS A NEW ONE	DOOR B2 RA PARKING	3/10/2014		REPLACED WITH ANOTHER BUMPER	0.50
2014033225	MAINTENANCE ODW INT. LIGHTING	CHILDCARE LIGHT BURNED OUT	CHILDCARE	3/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULB	0.50
2014033274	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 FOURTH STALL TO THE LEFT IS STOPPED UP	W'S R/R A600	3/11/2014		CLEARED CLOG WITH PLUNGER	0.50
2014033276	MAINTENANCE ODW TEMPERATURE COLD	POLE 8JJ IS TOO COLD	POLE 8JJ	3/11/2014		SPACE TEMP 72 DEG AND IS IN RANGE. NO ACTION TAKEN.	0.50

2014033280	MAINTENANCE ODW TEMPERATURE HOT	B305A TOO HOT	B305A	3/11/2014		CHECKED SPACE TEMP 72.1 DEG F. SET POINT IS AT 70 DEG F. NO ACTION TAKEN.	0.50
2014033281	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B302 ALL SINKS CLOGGED	W'S R/R B302	3/11/2014		SNAKED MAIN DRAIN LINE. OK.	1.50
2014033282	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A700H TOILET CLOGGED	W'S R/R A700H	3/11/2014		UNCLOGGED WITH PLUNGER. REMOVED BIG WAD OF PAPER.	0.50
2014033286	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET #12 OVERFLOWING AND #5 WILL NOT STOP FLUSHING	W'S R/R A1003	3/11/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	UNCLOGGED #12 WITH PLUNGER. REPLACED FLUSH HEAD ON #15 WITH NEW STOCK.	0.50
2014033377	MAINTENANCE ODW PLUMBING CLOG	RM B303 SLOP SINK IS CLOGGED	RM B303 SLOP SINK	3/12/2014		SNAKED SINK DRAIN AND VENT STACK. OK	4.00
2014033378	MAINTENANCE ODW BLDG/EQUIP. REP	COURTYARD CANTEEN ICE MACHINE LEAKING WATER	COURTYARD CANTEEN	3/12/2014		FOUND DISCHARGE HOSE KINKED FROM WATER WEIGHT. SECURED TO DRAIN HOSE WITH ZIP TIES. MOPPED UP WATER.	0.50
2014033379	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #4 CLOGGED	W'S R/R A600	3/12/2014		REMOVED PAPER AND PLUNGED	0.50
2014033380	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1005 TOILET #12 CLOGGED	W'S R/R A1005	3/12/2014		REMOVED PAPER AND PLUNGED	0.50
2014033381	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 HANDICAP STALL CLOGGED	W'S R/R A306	3/12/2014		CLEARED CLOG WITH PLUNGER	0.50
2014033382	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 LAST STALL ON LEFT IS CLOGGED	W'S R/R A1003	3/12/2014		FLUSHED ALL TOILETS. NONE WERE CLOGGED UPON ARRIVAL.	0.50
2014033383	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 URINAL #1 CLOGGED	M'S R/R B309	3/12/2014		SNAKED URINAL #1, URINAL #2 IS DRAINING SLOW SO I SNAKED IT AS WELL. OK.	0.50
2014033415	MAINTENANCE ODW PLUMBING	W'S R/R A306 TOILET WILL NOT STOP RUNNING	W'S R/R A306	3/13/2014		NO TOILETS WERE RUNING UPON ARRIVAL. FLUSHED ALL TOILETS AND ALL OF THEM WORKED PROPERLY.	0.50
2014033416	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 35 URINAL DRAIN CLOGGED	MAG HALL 35	3/13/2014		UNCLOGGED WITH PLUNGER	0.50
2014033454	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 STALL #4 IS CLOGGED	W'S R/R A600 STALL #4	3/13/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	PLUNGED COMMODE AND REPLACED FLUSH HEAD	0.50
2014033468	MAINTENANCE ODW DOOR	W'S R/R A306 DOOR NOT WORKING	W'S R/R A306	3/14/2014		ADJUSTED INSIDE DOOR SWITCH. IT WAS STUCK IN THE CLOSED POSITION.	0.50
2014033469	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALLS 3 AND 4 CLOGGED	M'S R/R B309	3/14/2014		PLUNGED TWO COMMODES	0.50
2014033470	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHT FIXTURE NOT WORKING	SATELLITE CANTEEN	3/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS. OK.	1.25
2014033508	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A403 TOILET CLOGGED	M'S R/R A403	3/17/2014		PLUNGED THE COMMODE	0.50
2014033510	MAINTENANCE ODW INT. LIGHTING	W'S R/R A306 REPLACE LIGHTS/LENS AS NEEDED	W'S R/R A306	3/17/2014		REPLACED LAMPS	0.50
2014033513	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS BURNED OUT	MAG HALL	3/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	CHANGED LAMPS IN RMS 29, 30, 19, 18, 17 AND 33	2.50
2014033528	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 HANDICAP STALL IS STOPPED UP	W'S R/R A404 HANDICAP STALL	3/17/2014		CLEARED CLOG WITH PLUNGER	0.50
2014033539	MAINTENANCE ODW PLUMBING	M'S R/R A700i STALL 5 TOILET CONSTANTLY RUNNING	M'S R/R A700i STALL 5	3/17/2014	DIAPHRAGM-COV;DIAPHRAGM ;	REPLACED DIAPHRAGM. OK.	0.50
2014033540	MAINTENANCE ODW INT. LIGHTING	W'S R/R A404 6 LIGHTS OUT	W'S R/R A404	3/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 6 LAMPS	0.50
2014033555	MAINTENANCE ODW FLOOR TILE	AREA 3 HAS A WIRE COMING OUT OF THE FLOOR AND NEEDS A FLOOR TILE PUT IN PLACE	AREA 3	3/18/2014		REPLACED FLOOR TILE	0.50
2014033556	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 FLOOR TILE NEEDS REGLUED (TILE CAN BE FOUND ON THE COUNTER)	CHILDCARE RM 128	3/18/2014		REPLACED BROKEN FLOOR TILE	0.75
2014033589	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT SOUTH OF POLE 4J	AREA 3	3/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014033590	MAINTENANCE ODW INT. LIGHTING	MAG HALL 6 AND 6C LAMPS OUT	MAG HALL 6 AND 6C	3/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014033591	MAINTENANCE ODW INT. LIGHTING	AREA 13 BALLAST IS BAD AND LAMPS BURNED OUT	AREA 13	3/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST WITH NEW. REPLACED LAMPS WITH NEW.	1.50
2014033608	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 3RD STALL IS CLOGGED	M'S R/R B309	3/18/2014		UNCLOGGED WITH PLUNGER	0.50
2014033609	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 HANDICAP STALL #14 CLOGGED	W'S R/R B211	3/18/2014		UNCLOGGED WITH PLUNGER	0.50
2014033614	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE GARBAGE DISPOSAL BARELY DRAINING AND FOOD COMES UP WHEN TURNED ON	CHILDCARE KITCHEN	3/19/2014		REMOVED KNIFE FROM TRAP AND SNAKED DRAIN	2.00
2014033616	MAINTENANCE ODW INT. LIGHTING	W'S R/R A309 LIGHTS OUT	W'S R/R A309	3/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014033617	MAINTENANCE ODW INT. LIGHTING	M'S R/R A308 LIGHTS OUT	M'S R/R A308	3/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014033618	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL #8 TOILET CLOGGED	W'S R/R B211	3/19/2014		UNCLOGGED WITH PLUNGER	0.50
2014033619	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS OUT BETWEEN 49 AND 50	MAG HALL	3/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014033620	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 TOILET #14 CLOGGED	W'S R/R A404	3/19/2014		UNCLOGGED WITH PLUNGER	0.50
2014033635	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 1 THRESHOLD AT TOP OF RAMP IS RAISED AND LOOSE	AREA 1	3/19/2014		SECURED THRESHHOLD WITH 4 RIVETS	0.50
2014033675	MAINTENANCE ODW INT. LIGHTING	SCAMPS LIGHTS OUT	SCAMPS	3/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 3 LIGHT BULBS	0.50
2014033676	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT IN EXTRACTING	AREA 7	3/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 11 LIGHT BULBS AND VACUUMED 3 LIGHT FIXTURES	1.00
2014033677	MAINTENANCE ODW EXT. LIGHTING	DOOR 18 FLOOD LIGHTS BURNED OUT	DOOR 18	3/20/2014	FLOOD LIGHT-COV;FLOOD LIGHT 75W ;	REPLACED LAMPS	0.50
2014033678	MAINTENANCE ODW INT. LIGHTING	NW CORNER OF COURTYARD LIGHT BURNED OUT	NW CORNER OF COURTYARD	3/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND 4 T8F32 BULBS	0.50
2014033707	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #3 IS CLOGGED	M'S R/R B309 STALL #3	3/20/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014033734	MAINTENANCE ODW INT. LIGHTING	RM 27B WORKSPACE OVERHEAD LIGHTING NEEDS REPAIRED	RM 27B	3/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO T8 F323 BULBS	0.50
2014033736	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #6 AND HANDICAP SINK CLOGGED	W'S R/R A600	3/21/2014		PLUNGED COMMODE AND UNCLOGGED SINK	0.75
2014033737	MAINTENANCE ODW BLDG/EQUIP. REP	RM 7A, MAG HALL REHEAT VALVE LEAKING	RM 7A, MAG HALL	3/21/2014	CEILING TILE-COV;CEILING TILE ;	REBUILT REHEAT VALVE. CUT AND REPLACED STAINED CEILING TILE.	2.50
2014033739	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 STALL #3 IS CLOGGED	W'S R/R A600 STALL #3	3/21/2014		CHECKED ALL TOILETS. NO STALLS WERE CLOGGED AND ALL WERE FLUSHING. TIGHTENED SEAT BOLTS IN STALLS 3, 5 AND 9.	0.50
2014033742	MAINTENANCE ODW TEMPERATURE HOT	AREA 7 TOO HOT	AREA 7	3/21/2014		UNIT WAS OFF BRIEFLY DURING SMOKE DETECTOR TEST. BACK ON @ 0845.	0.25
2014033745	MAINTENANCE ODW ELECTRICAL	AREA 8 MSU ELECTRIC PLUGS HANGING FROM CEILING NEED REMOVED OR TIED UP	AREA 8 MSU	3/21/2014		REMOVED ONE CORD AND PUT THREE ABOVE CEILING	1.00
2014033760	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 TOILET CLOGGED	M'S R/R A810	3/21/2014		UNCLOGGED THE COMMODE	0.50
2014033761	MAINTENANCE ODW FLOOR TILE	MAG HALL RM 32 CARPET TILE COMING UP (TAPE IS ON THE CARPET TO INDICATE SPOT)	MAG HALL RM 32	3/21/2014		PULLED BACK CARPET AND APPLIED GLUE. REAPPLIED CARPET.	1.00
2014033771	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A602 COMMODE #2 CLOGGED	M'S R/R A602	3/24/2014		UNCLOGGED THE COMMODE	0.50
2014033772	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A5 HANDICAP STALL TOILET PAPER DISPENSER BROKEN	W'S R/R A5	3/24/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REPLACED WITH A NEW DISPENSER. ALL OTHER DISPENSERS WORKING PROPERLY.	0.50
2014033773	MAINTENANCE ODW DOOR	MAG HALL DOOR 22 DRAGGING AND WILL NOT LATCH	MAG HALL DOOR 22	3/24/2014		ADJUSTED LATCH COVER SO IT IS NOT DRAGGING. THIS PANIC BAR LATCH IS NOT USED. IT LATCHES AND LOCKS WITH MAGNET.	0.50
2014033774	MAINTENANCE ODW INT. LIGHTING	AREA 6 SEVERAL LAMPS OUT	AREA 6	3/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014033775	MAINTENANCE ODW INT. LIGHTING	AREA 5 SEVERAL LAMPS OUT	AREA 5	3/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.50
2014033776	MAINTENANCE ODW INT. LIGHTING	CHILDCARE LIGHTS BURNED OUT	CHILDCARE	3/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS IN RMS 109 AND 130; AND NORTH-SOUTH HALL	0.75
2014033779	MAINTENANCE ODW CEILING TILE	RMS 21/22 CEILING TILE STAINED DUE TO PREVIOUS LEAK	RMS 21/22	3/24/2014	CEILING TILE-COV;CEILING TILE ;	REPAIRED CEILING TILE	1.00

2014033780	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 9 RETURN VENTS ARE DIRTY	AREA 9	3/24/2014		VACUUMED VENTS	0.50
2014033781	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT AND LIGHT LENS IS SAGGING	AREA 9	3/24/2014		REPLACED 8 LIGHT BULBS AND REPAIRED SAGGING LENS	1.50
2014033782	MAINTENANCE ODW DOOR	CHILDCARE SHED DOOR DEAD-BOLT WILL NOT WORK	CHILDCARE	3/24/2014		THERE WAS MULCH IN THE KEY HOLE. I HAD TO TAKE THE DEAD-BOLT APART AND REBUILD IT.	0.50
2014033783	MAINTENANCE ODW INT. LIGHTING	MAG HALL 6B LAMPS OUT	MAG HALL 6B	3/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	SREPLACED BALLAST AND LAMPS	1.00
2014033784	MAINTENANCE ODW INT. LIGHTING	AREA 4 NORTH OF POLE 4P LIGHTS OUT AND LENS IS LOOSE	AREA 4	3/24/2014		REPLACED LAMPS AND REPAIRED COVER	0.50
2014033792	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A602 HANDICAP STALL CLOGGED	M'S R/R A602	3/24/2014		CHECKED ALL STALLS. ALL WERE WORKING PROPERLY UPON ARRIVAL.	0.50
2014033793	MAINTENANCE ODW BLDG/EQUIP. REP	DOCK - THE COMPACTOR IS LEAKING HYDRAULIC FLUID	DOCK	3/24/2014		HAD OHIO HYDRAULICS, INC. ON SITE TO MAKE NEW HYDRAULIC HOSES (TWO) FROM PUMP TO HARD LINE. CHECKED FOR LEAKS AFTER NEW HOSES WERE INSTALLED. NO LEAKS FOUND.	1.00
2014033807	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #3 IS CLOGGED AND THERE ARE 2 LIGHTS OUT	M'S R/R B309	3/24/2014		CLEARED CLOG WITH PLUNGER	0.50
2014033808	MAINTENANCE ODW INT. LIGHTING	M'S R/R B309 THERE ARE 2 LIGHTS OUT	M'S R/R B309	3/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BULB 18W-COV;18W LIGHT BULB ;	REPLACED LAMPS (5) F32T8TL735 ALTO AND (1) 18W2PINPLC	0.50
2014033891	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 MAG HALL TOILET OVERFLOWING	W'S R/R 34 MAG HALL	3/25/2014		UNCLOGGED WITH PLUNGER	0.50
2014033897	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT	AREA 3	3/26/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014033898	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT SOUTH OF POLE 4P	AREA 4	3/26/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014033899	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 THERE IS STANDING WATER AT CHILDREN'S SINK IN THE MORNING	CHILDCARE RM 130	3/26/2014		CHECKED ALL SINKS. NO LEAKS. AREAS UNDER SINKS WERE DRY. MUST HAVE BEEN A SPILL. POURED WATER DOWN FLOOR DRAIN AT MARKED LOCATION. DRAINS FINE.	0.50
2014033900	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 COMMODE #1 IS CLOGGED	M'S R/R B309	3/26/2014		UNCLOGGED THE COMMODE	0.50
2014033910	MAINTENANCE ODW PLUMBING CLOG	THE DRAIN FOR THE WASHER IS STOPPED UP	WASHER/DRYER AREA	3/26/2014		3-25-14 RAN CABLE DOWN DRAIN BUT NO LUCK. AG3-26-14 SNAKED, REMOVED STAPLES, PAPERCLIPS, RUBBERBANDS, STRINGS, ETC. STILL CLOGGED. MM3-27-14 SNAKED, REMOVED MORE OF ITEMS LISTED ABOVE. DRAINING SLOW. MM3-28-14 SNAKED FROM OUTSIDE, BACK TOWARD BUILDING AND JETTED TO REMOVE CLOG. MM AND MS	19.00
2014033911	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A700H BOTH HANDICAP BUTTONS NOT WORKING	W'S R/R A700H	3/26/2014		(TD) REPLACED FUSES(JM) DOOR CONTROLLER DEFECTIVE. PURCHASED REBUILT DOOR CONTROLLER AND INSTALLED. CHECKED FOR PROPER OPERATION. OK.	2.00
2014033978	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 FIRST STALL CLOGGED	M'S R/R A810	3/27/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014033989	MAINTENANCE ODW INT. LIGHTING	MSU HAS LIGHTS OUT	MSU	3/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014033991	MAINTENANCE ODW INT. LIGHTING	RM 816 LIGHTS OUT	RM 816	3/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014033992	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 7 INTAKE FILTER FOR EXHAUST FAN IS DIRTY (F27-036-07)	AREA 7	3/27/2014	24X24X1 FILTER-COV;24X24X1 FILTER ;	REPLACED FILTER WITH NEW	0.50
2014033994	MAINTENANCE ODW LEAKS	W'S R/R A1003 THERE ARE FOUR SINKS WHICH ARE LEAKING DUE TO ERODING COPPER	W'S R/R A1003	3/27/2014		REMOVED BLOCK IN WALL TO ACCESS DRAIN LINES. REMOVED DRAIN LINES ON SINKS 1, 2 AND 3. REMOVED DRAIN LINE FROM SINK 4 AND REPLACED DRAIN LINE SINK 1. REPLACED DRAINS IN SINKS 2, 3 AND 4 FROM TAILPIPE TO STACK. RAN CAMERA TO FIND LEAK IN WALL. MEASURED AND CUT PANELS.	38.00
2014033995	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE OUTSIDE PLAY AREA NEEDS RUBBER MAT REPAIRED	CHILDCARE OUTSIDE PLAY AREA	3/27/2014		REPAIRED EXISTING CRACKS.	4.00
2014033996	MAINTENANCE ODW CARPET	DOOR 2B NEEDS FRAYED CARPET SQUARES REPLACED. (EXTRA SQUARES ARE IN B BUILDING)	DOOR 2B	3/27/2014		SINCE GLUE WAS STILL GOOD AND HOLDING THE CARPET DOWN, I WENT AROUND THE WHOLE AREA AND CUT OUT THE FRAYED AREAS	1.00
2014034005	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A700i STALL #7 IS CLOGGED	M'S R/R A700i	3/27/2014		(ACTUAL LOCATION WAS W'S R/R 700H) UNCLOGGED THE COMMODE	0.50
2014034017	MAINTENANCE ODW DOOR	803A DOOR KNOB FELL OFF	803A	3/28/2014		REMOVED DOOR KNOB, DRILLED AND REMOVED BROKEN STUD FROM BOTH HALVES OF KNOB USING EAST OUT. REPLACED DOOR KNOB.	2.00
2014034018	MAINTENANCE ODW INT. LIGHTING	M'S R/R 700i LIGHTS OUT	M'S R/R 700i	3/28/2014	LIGHT BULB 18W-COV;18W LIGHT BULB ;	REPLACED ONE LIGHT BULB	0.50
2014034019	MAINTENANCE ODW INT. LIGHTING	AREA 9 SAGGING LIGHT LENS	AREA 9	3/28/2014		REPAIRED LIGHT LENS	0.50
2014034020	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS OUT IN FIXTURE OUTSIDE MH 7	MAG HALL	3/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014034076	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL #6 CLOGGED	M'S R/R A1005	3/31/2014		PLUNGED THE COMMODE	0.50
2014034077	MAINTENANCE ODW INT. LIGHTING	AREA 1 HALLWAY IN FRONT OF MAINTENANCE SHOP HAS LIGHTS OUT	AREA 1 HALLWAY	3/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014034078	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 5GG SMOKE HEAD ALARM	POLE 5GG	3/31/2014		CLEANED AND REINSTALLED. ALL CLEAR.	0.50
2014034079	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	3/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 26 LIGHT BULBS	1.50
2014034080	MAINTENANCE ODW DOOR	RM B211 AUTO DOOR HARD TO PUSH OPEN	RM B211	3/31/2014		TURND POWER BOOST OFF ON MOTOR OPERATOR. WORKS FINE.	0.50
2014034081	MAINTENANCE ODW INT. LIGHTING	AREA 4 SW LIGHTS OUT OVER SW RAMP TO AREA 4	AREA 4 SW	3/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014034082	MAINTENANCE ODW INT. LIGHTING	AREA 13 LIGHTS OUT	AREA 13	3/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	2.00
2014034116	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 TOILET CLOGGED	W'S R/R A34	3/31/2014		UNCLOGGED WITH PLUNGER	0.50
2014034117	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 SINK #2 DRAINING SLOWLY	W'S R/R A309	3/31/2014		SNAKED DRAIN	0.50
2014034121	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL #7 TOILET CLOGGED	W'S R/R B211	3/31/2014		UNCLOGGED WITH PLUNGER	0.50
2014034122	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #3 TOILET CLOGGED	W'S R/R A404	3/31/2014		UNCLOGGED WITH PLUNGER	0.50
2014041399	MAINTENANCE ODW PLUMBING	W'S R/R A700H TOILET CONTINUOUSLY FLUSHING	W'S R/R A700H	4/1/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH A REBUILT ONE (STALL #5)	0.50
2014041400	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILETS #13 AND #14 CLOGGED	W'S R/R B211	4/1/2014		UNCLOGGED WITH PLUNGER	0.50
2014041401	MAINTENANCE ODW INT. LIGHTING	B201 MDF LAMPS BURNED OUT	B201 MDF	4/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014041813	MAINTENANCE ODW PLUMBING	M'S R/R A700i TOILET CONTINUOUSLY FLUSHING	M'S R/R A700i	4/1/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH REBUILT ONE	0.50
2014041899	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R B309 STALL #4 TOILET SEAT IS BROKEN	M'S R/R B309	4/2/2014	TOILET SEAT-COV;TOILET SEAT ;	REPLACED SEAT WITH A NEW ONE	0.50
2014041900	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R A1005 STALL #2 TOILET WILL NOT FLUSH	M'S R/R A1005	4/2/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH A REBUILT ONE	0.50
2014042715	MAINTENANCE ODW TEMPERATURE HOT	AREA 10 BY RAISED RAMP AT 7V TOO HOT	AREA 10 7V	4/2/2014		BOILER OFF AT 10:30 AM. AHU DELIVERING 58 DEG. F SUPPLY AIR. SPACE SHOULD BE COOLING DOWN.	0.50

2014042717	MAINTENANCE ODW BLDG/EQUIP. REP	CONCRETE ON THE EXTERIOR OF DOOR B2 NEEDS REPAIRED	DOOR B2	4/2/2014		REMOVED OLD CONCRETE. REPLACED WITH NEW REPAIR MIX. MATERIAL USED: 150 LB OF WHITE SAND, 40 LB OF CEMENT, 3 GAL OF ACRYL 60.	20.00
2014042721	MAINTENANCE ODW EXT. LIGHTING	JOHNSON STREET LOT SIX POLE LIGHTS NOT WORKING	JOHNSON STREET LOT	4/2/2014	LIGHT BULB HPS 250W-COV;HP SODIUM LAMP 250W ;	REPLACED 24 LAMPS	10.00
2014042738	MAINTENANCE ODW INT. LIGHTING	POLE 6FF THE ENTIRE LIGHT FIXTURE IS OUT	POLE 6FF	4/3/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;; LIGHT BULB-COV;LIGHT BULB ;	REPLACED BALLAST AND 4-T8 BULBS	0.50
2014042739	MAINTENANCE ODW NOISE	AREA 1 - 8L THERE IS A CRACKLING SOUND COMING FROM THE CEILING	AREA 1 - 8L	4/3/2014		WENT TO AREA. LISTENED FOR A CRACKLING SOUND OF ANY KIND. DID NOT HEAR/SEE ANYTHING.	0.50
2014042741	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL #2 TOILET IS CLOGGED	W'S R/R B211 STALL #2	4/3/2014		UNCLOGGED WITH PLUNGER	0.50
2014042742	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL #2 TOILET IS CLOGGED	M'S R/R A1005 STALL #2	4/3/2014		UNCLOGGED WITH PLUNGER	0.50
2014042770	MAINTENANCE ODW BLDG/EQUIP. REP	RM 303, UNIT 12-3 KNOT OUT IS BROKEN OUT OF DISCONNECT AT MOTOR	RM 303, UNIT 12-3	4/3/2014		INSTALLED A SET OF 1-1/4" TO 3/4" REDUCING WASHERS IN DISCONNECT AT MOTOR	2.00
2014042804	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP COMMODOE IS CLOGGED	M'S R/R A810	4/4/2014		PLUNGED THE COMMODOE	0.50
2014042805	MAINTENANCE ODW RESTROOM FIXTURE	W'S B211 #7 TOILET SEAT IS BROKEN	W'S B211 #7	4/4/2014	TOILET SEAT-COV;TOILET SEAT ;	REPLACED TOILET SEAT	0.50
2014042806	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 SINKS #1 AND #2 CLOGGED	W'S R/R A1003	4/4/2014		CLOSED SINKS, OUT OF ORDER SIGNS PLACED ON SINKS. REMOVED TOWEL DISPENSER AND GARBAGE CAN FROM WALL AND SNAKED DRAINS THROUGH STACK. OK.	1.25
2014042807	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A1003 SINKS #1 AND #7 ARE NOT WORKING	W'S R/R A1003	4/4/2014	SOLENOID-COV;SOLENOID ;	REPLACED SOLENOIDS IN BOTH SINKS. OK.	1.00
2014042808	MAINTENANCE ODW LEAKS	RM 22 ROOF LEAK	RM 22	4/4/2014		4-5-14 PATCHED AND SEALED PORTIONS OF ROOF. 4-11-14 ROOFERS CAME AND REPAIRED 55' OF THE ROOF. DRAINS WERE CLEANED/CLEARED.	9.50
2014042809	MAINTENANCE ODW DOOR	W'S R/R B302 HANDICAP DOOR COMPLETELY OFF	W'S R/R B302	4/4/2014		REHUNG DOOR WITH NEW SPRING HINGE	5.00
2014042812	MAINTENANCE ODW ELECTRICAL	POLE 4J POD 012 POWER IS OUT	POLE 4J POD 012	4/4/2014		HEATER PLUGGED INTO POWERSTRIP TRIPPED BREAKER ON POWERSTRIP SO I RESET THE BREAKER. OK.	0.50
2014042825	MAINTENANCE ODW DOOR	CHILDCARE INTERIOR DOOR DRAGS ON THE RIGHT SIDE WHEN CLOSING	CHILDCARE INTERIOR DOOR	4/4/2014		ADJUSTED DOOR HEIGHT. CHECKED HARDWARE TO ENSURE IT WAS TIGHT AND LUBED HINGE. OK.	0.50
2014042838	MAINTENANCE ODW BLDG/EQUIP. REP	ROOF - HIGH TEMP IN MEAT WALK-IN BOX	ROOF	4/4/2014		FOUND OPEN CIRCUIT IN CONTACTOR COIL. REPLACED CONTACTOR IN CONDENSING UNIT. CHECKED FOR PROPER OPERATION. OK.	5.00
2014042849	MAINTENANCE ODW CEILING TILE	REPLACE STAINED TILES AT:□ HALL BY 117□ SOUTH OF 7Q□ SOUTH OF 7W□ SOUTH OF 7EE□ NORTH OF 6EE□ SOUTH OF 7HH□ NORTH OF 6HH□ SOUTH OF 1DD, BY B323C□ NORTH-EAST SIDE OF COURTYARD 5L-6L	THROUGHOUT BUILDING	4/4/2014	2x2 CEILING TILE-COV;2x2 CEILING TILE ;	TOTAL 8. SINCE SOME TILES WEREN'T THAT BAD THEY WERE PAINTED. CEILING TILES APPEARED TO BE WET. REPLACED TILES AND CLEANED UP AREA. MAY HAVE LOCATED LEAK AROUND POLE 7V DRAIN AREA. CAULKED ALL AROUND DRAIN AND AROUND SOME BOLTS.	6.00
2014042850	MAINTENANCE ODW INT. LIGHTING	POLE N-4J A LIGHT LENS HAS FALLEN	POLE N-4J	4/4/2014		REATTACHED LIGHT LENS LATCH TO CLOSE COVER	0.50
2014042852	MAINTENANCE ODW INT. LIGHTING	SHOP LIGHTS FLICKERING	SHOP	4/4/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;; LIGHT SOCKET-COV;LIGHT SOCKET ;	REPLACED BALLAST AND 1 LIGHT SOCKET	1.00
2014042868	MAINTENANCE ODW BLDG/EQUIP. REP	RM 34 (AHU) PNUEMATIC AIR LEAK IN CEILING ABOVE THERMOSTAT TO RIGHT OF ENTRANCE DOOR.	RM 34	4/7/2014	PNUEMATIC THERM0-COV;PNUEMATIC THERM0 ;	COPPER TUBING LEAKING IN WALL ABOVE DROP CEILING. CUT COPPER AND INSTALLED POLY-TUBING TO THERMOSTAT AND REPLACED.	2.00
2014042869	MAINTENANCE ODW INT. LIGHTING	CHILDCARE HAS BURNT OUT BULBS	CHILDCARE	4/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	1.00
2014042886	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #3 IS CLOGGED	M'S R/R B309	4/7/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014042890	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R A308 HANDICAP BUTTON ON THE INSIDE IS NOT WORKING	M'S R/R A308	4/7/2014		BUTTON WORKS. WAS KNOCKED OFF. PUT BUTTON BACK ON AND TESTED. OK (TD 4-7-14)ROTATED BUTTON 90 DEG. REPLACED BATTERY (DATED 2013) AND TIGHTENED MOUNTING SCREWS FOR BUTTON. (MM 4-8-14)	0.75
2014042905	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #3 IS CLOGGED	W'S R/R A404	4/8/2014		CLEARED CLOG WITH PLUNGER	0.50
2014042906	MAINTENANCE ODW INT. LIGHTING	DOOR 18 CEILING LIGHT IS SAGGING AND LIGHT IS OUT	DOOR 18	4/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP. REPAIRED SAGGING COVER.	1.00
2014042927	MAINTENANCE ODW INT. LIGHTING	CHILDCARE HIGH BAY AREA HAS SEVERAL LIGHTS OUT	CHILDCARE	4/8/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 5 BALLASTS AND 50 T8 LIGHTS	12.00
2014042971	MAINTENANCE ODW INT. LIGHTING	AREA 4 LAMPS OUT OVER CUBICLE GDI-01-04-390-C2	AREA 4	4/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014042972	MAINTENANCE ODW INT. LIGHTING	SCAMPS - LIGHT FIXTURE COMPLETELY OUT	SCAMPS	4/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2014043037	MAINTENANCE ODW SAFETY ISSUE	POLE 4X WFI BOX COVER COMPLETELY MISSING	POLE 4X	4/10/2014		REPLACED BROKEN BOX COVER	0.25
2014043045	MAINTENANCE ODW BLDG/EQUIP. REP	COURTYARD WINDOWS NEED RESEALED	COURTYARD	4/10/2014		CLEANED ALL WINDOWS IN THE AREA. APPLIED CLEAR SILICONE TO SEAL WINDOWS.	3.50
2014043046	MAINTENANCE ODW PLUMBING CLOG	41 - SINK CLOGGED	41	4/10/2014		TRIED TO PLUNGE SINK. SINK DRAINING SLOW SO I SNAKED SINK. IT'S OKAY NOW.	1.00
2014043047	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET #4 IS CLOGGED	M'S R/R A1005	4/10/2014		UNCLOGGED WITH PLUNGER	0.50
2014043048	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 TOILET #15 CLOGGED	W'S R/R A1003	4/10/2014		UNCLOGGED WITH PLUNGER	0.50
2014043049	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 TOILET #5 CLOGGED	W'S R/R A600	4/10/2014		UNCLOGGED WITH PLUNGER	0.50
2014043050	MAINTENANCE ODW TEMPERATURE HOT	AREA 11 3Y-4Y TOO HOT	AREA 11 3Y-4Y	4/10/2014		TOOK 3 READINGS FROM AREA 74 DEG, 74.5 DEG AND 74.8 DEG. METSYS READING 75 DEG. WITHIN CONTRACT. MADE NO ADJUSTMENTS.	0.50
2014043062	MAINTENANCE ODW PLUMBING	W'S R/R A1003 A TOILET IS CONTINUOUSLY FLUSHING	W'S R/R A1003	4/10/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH REBUILT	0.50
2014043065	MAINTENANCE ODW BLDG/EQUIP. REP	THERE IS A SINKHOLE BY LOBBY THAT NEEDS REPAIRED	OUTSIDE LOBBY	4/10/2014		HOLE WAS FILLED WITH TOP SOIL AND GRAVEL WAS REPLACED	0.50
2014043066	MAINTENANCE ODW BLDG/EQUIP. REP	COOLING TOWER - THERE IS A CRACK IN THE COPPER TUBING DRAIN LINE THAT NEEDS REPAIRED	COOLING TOWER	4/10/2014		REMOVED OLD TUBING. REPLACED WITH NEW COPPER TUBING.	1.00
2014043087	MAINTENANCE ODW ELECTRICAL	AREA 3 4J THE POWER IS OUT	AREA 3 4J	4/11/2014		UNPLUGGED POWER STRIP FROM A POWER STRIP AND PLUGGED IT DIRECTLY INTO A RECEPITAL UNDER THE DESK IN CUBICLE 03-39. THERE WAS ALSO AN ELECTRIC HEATER IN THE CUBICLE.	1.00
2014043090	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL #3 TOILET CLOGGED	M'S R/R A1005	4/11/2014		CLEARED CLOG WITH PLUNGER	0.50

2014043091	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A403 COMMODE IS CLOGGED	M'S R/R A403	4/11/2014		SNAKED COMMODE WITH TOILET AUGER	0.50
2014043092	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #1 IS CLOGGED	M'S R/R B309	4/11/2014		PLUNGED THE COMMODE	0.50
2014043094	MAINTENANCE ODW PLUMBING	W'S R/R B211 SINK #1 FAUCET DRIPS WATER AND SINK IS SLOW TO DRAIN	W'S R/R B211	4/11/2014	SOLENOID-COV;SOLENOID ;	REPLACED SOLENOID VALVE AND SNAKED OUT DRAIN LINE	1.25
2014043170	MAINTENANCE ODW CEILING TILE	MAG HALL CEILING TILES NEED REPLACED	MAG HALL	4/14/2014		REPLACED 1 TILE IN ROOM 11 AND 2 OUTSIDE IN SHORT HALL	1.00
2014043184	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A309 HANDICAP BUTTON ON THE INSIDE NOT WORKING	W'S R/R A309	4/14/2014		CHECKED INNER AND OUTER HANICAP BUTTONS ON A309. BOTH WORKING. ALSO CHECKED A308. BOTH BUTTONS WERE WORKING.	0.50
2014043185	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 SECOND HANDICAP STALL CLOGGED	W'S R/R A600	4/14/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014043237	MAINTENANCE ODW ROOF LEAK	ROOF LEAK IN AREA 10	AREA 10	4/15/2014		4-15-14 INSTALLED DRAIN PAN AND BUCKET. 4-17-14 PATCHED ROOF LEAK. 4-18-14 DISASSEMBED ROOF DRAIN, CLEANED, SEALED AND INSTALLED ROOF MEMBRANE.	9.50
2014043239	MAINTENANCE ODW TEMPERATURE HOT	TOO HOT	AREA 1 POLE 8D-8H	4/15/2014		CHECKED AREA 78.2 DEG, 77.8 DEG AND 77.9 DEG. ABOVE CONTRACT. TOOK TEMP DOWN A COUPLE OF DEGREES AND TURNED ON LIEBERT IN AREA THEY ARE WORKING	0.05
2014043241	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 4N WSI NEEDS TO BE FIXED	POLE 4N	4/15/2014		REPLACED BROKEN WSI COVER	0.25
2014043242	MAINTENANCE ODW CEILING TILE	POLE 5M DAMAGED CEILING TILE NEXT TO LIGHT FIXTURE	POLE 5M	4/15/2014	2x 2 CEILING TILES-COV;2x 2 CEILING TILES ;	REPLACED TWO TILES	0.50
2014043243	MAINTENANCE ODW CEILING TILE	POLE 5X HOLE IN TILE BY BLUE LIGHT	POLE 5X	4/15/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILING TILE	0.50
2014043244	MAINTENANCE ODW CEILING TILE	SATELLITE CAFETERIA ABOVE COKE MCHINE AND ABOVE THE 7-UP MACHINE DAMAGED TILES	SATELLITE CAFETERIA	4/15/2014		REPLACED TILES WITH 3 NEW ONES (2X2)	0.50
2014043245	MAINTENANCE ODW CEILING TILE	POLE 6O HOLE IN TILE	POLE 6O	4/15/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED FIVE 2X4 PANELS	0.50
2014043246	MAINTENANCE ODW DOOR	MSU SLIDING DOOR - SOMEONE RAN INTO IT AND KNOCKED OFF TRACK	MSU	4/15/2014		PUT DOOR BACK ON TRACK. OPENED AND SHUT DOOR A FEW TIMES. OK.	0.50
2014043247	MAINTENANCE ODW INT. LIGHTING	W'S R/R A600 LIGHTS OUT	W'S R/R A600	4/15/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014043248	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A309 WALLPAPER SEAM COMING LOOSE BEHIND ENTRY DOOR	W'S R/R A309	4/15/2014	ADHESIVE-COV;ADHESIVE ;	REGLUED SEAM	1.00
2014043274	MAINTENANCE ODW INT. LIGHTING	HALF WAY BETWEEN POLES 10W AND 10X, THERE IS A LIGHT OUT ABOVE COMPUTER	POLE 10W AND 10X	4/15/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR BULBS	0.50
2014043275	MAINTENANCE ODW BLDG/EQUIP. REP	MDF HAS A BAD ODOR	MDF	4/15/2014		CHECKED PIT, REFRESHED MAINTAINER, WHICH IS ALSO A DEODORIZER. OK.	0.50
2014043320	MAINTENANCE ODW BUILDING SIGNAGE	LOBBY PARKING LOT - THERE IS AN "RA" SIGN THAT IS BROKEN IN HALF. PLEASE REPLACE.	LOBBY PARKING LOT	4/15/2014		REMOVED OLD SIGN AND INSTALLED NEW ONE.	0.50
2014043337	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A403 TOILET CLOGGED	M'S R/R A403	4/16/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014043351	MAINTENANCE ODW INT. LIGHTING	8U DOCK HALLWAY LIGHTS OUT	8U DOCK HALLWAY	4/16/2014		REPLACED BALLAST AND FOUR BULBS	0.50
2014043362	MAINTENANCE ODW INT. LIGHTING	AREA 4W LIGHTS OUT NEAR POLE 5N	AREA 4W	4/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014043363	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R A602 INSIDE BUTTON IS NOT OPENING THE DOOR	M'S R/R A602	4/16/2014	9V BATTERY-COV;9V BATTERY ;	REPLACED BATTERY IN BUTTON	0.50
2014043364	MAINTENANCE ODW INT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	4/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS	0.50
2014043365	MAINTENANCE ODW INT. LIGHTING	AREA 8 (CAGE) OVERHEAD LIGHTS OUT	AREA 8 (CAGE)	4/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED SIX LIGHT BULBS	0.50
2014043366	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL #5 IS CLOGGED	M'S R/R A1005	4/16/2014		HAD TO SNAKE COMMODE WITH TOILET AUGER	0.50
2014043367	MAINTENANCE ODW POWER OUTAGE	AREA 7 - A FEW DESKS HAVE LOST POWER	AREA 7	4/16/2014		THE BREAKER HAD BEEN TRIPPED. RESET. ALL OK.	0.50
2014043389	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A602 TOILET CLOGGED	M'S R/R A602	4/17/2014		CLEARED CLOG WITH PLUNGER	0.50
2014043397	MAINTENANCE ODW INT. LIGHTING	MAG HALL LOBBY RECESSED LAMP OUT NEAR RM 13	MAG HALL LOBBY	4/17/2014			0.00
2014043398	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET CLOGGED	M'S R/R B309	4/17/2014			0.00
2014043414	MAINTENANCE ODW PLUMBING CLOG	MAG HALL 35 TOILET CLOGGED	MAG HALL 35	4/17/2014		UNCLOGGED WITH PLUNGER	0.50
2014043415	MAINTENANCE ODW BLDG/EQUIP. REP	CAFE BLDG A OVEN DOOR NOT CLOSING TIGHTLY	CAFE BLDG A	4/17/2014		ADJUSTED DOOR	0.50
2014043427	MAINTENANCE ODW BLDG/EQUIP. REP	UNIT 22-12 NEEDS A NEW FAN SHAFT BEARING INSTALLED	UNIT 22-12	4/17/2014		INSTALLED SHAFT SLEEVE AND NEW OVERSIZED FLANGED BEARING. ALIGNED SHEAVES, ADJUSTED BELT TENSION AND CHECKED UNIT FOR PROPER OPERATION. OK.	6.00
2014043428	MAINTENANCE ODW BLDG/EQUIP. REP	B200A HAS AN EXPOSED OUTLET THAT NEEDS COVERED. (BACK OF THE ROOM NEXT TO THE FAX MACHINE.)	B200A	4/17/2014		REPLACED OUTLET COVER	0.50
2014043429	MAINTENANCE ODW CEILING TILE	B203 (STOREROOM FOR THE PIN TEAM.) THERE IS A CEILING TILE THAT HAS FALLEN AND LAYING ON THE FLOOR.	B203	4/17/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED 2 TILES AND CLEANED UP.	1.00
2014043430	MAINTENANCE ODW INT. LIGHTING	MAG HALL LOBBY HAS A RECESSED LAMP OUT NEAR RM 13	MAG HALL LOBBY	4/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP	0.50
2014043431	MAINTENANCE ODW PLUMBING CLOG	B309 TOILET IS CLOGGED	B309	4/17/2014		UNCLOGGED WITH PLUNGER. ADJUSTED WATER SUPPLY TO ALLOW BETTER FLUSH.	0.50
2014043432	MAINTENANCE ODW PLUMBING CLOG	MH 34 TOILET CLOGGED	MH 34	4/17/2014		UNCLOGGED WITH PLUNGER	0.50
2014043512	MAINTENANCE ODW INT. LIGHTING	AREA 3 SOUTH OF POLE 5D LIGHTS OUT	AREA 3	4/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014043513	MAINTENANCE ODW BLDG/EQUIP. REP	GATEHOUSE #2 NEEDS FILTER IN HVAC REPLACED	GATEHOUSE #2	4/21/2014		RESUABLE FILTER. CLEANED AIR FILTER WITH WATER.	0.50
2014043514	MAINTENANCE ODW INT. LIGHTING	AREA 9 TWO LIGHT LENSES ARE SAGGING	AREA 9	4/21/2014		REPAIRED LIGHT LENSES	0.75
2014043515	MAINTENANCE ODW EXT. LIGHTING	CHILDCARE ROOF UV LIGHT OUT IN RTU3	CHILDCARE ROOF	4/21/2014	UV BALLAST-COV;UV BALLAST & SOCKET 110W ;	REPLACED UV EMITTER AND BALLAST	1.00
2014043517	MAINTENANCE ODW INT. LIGHTING	RM 815 OVERHEAD LIGHTS OUT	RM 815	4/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 10 LIGHT BULBS	0.50
2014043519	MAINTENANCE ODW INT. LIGHTING	RM 809 OVERHEAD LIGHTS OUT	RM 809	4/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014043520	MAINTENANCE ODW INT. LIGHTING	COURTYARD CAFE LIGHTS BURNED OUT	COURTYARD CAFE	4/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014043521	MAINTENANCE ODW PLUMBING	W'S R/R A1003 COMMODE #22 CONSTANTLY FLUSHING	W'S R/R A1003	4/21/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	RELACED FLUSH-HEAD	0.50
2014043522	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 COMMODE #4 CLOGGED	M'S R/R A1005	4/21/2014		PLUNGED THE COMMODE	0.50
2014043523	MAINTENANCE ODW INT. LIGHTING	POLE 6DD LIGHT FIXTURE NOT WORKING AND BALLAST IS BAD	POLE 6DD	4/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW BALLAST AND NEW LAMPS	1.00
2014043525	MAINTENANCE ODW INT. LIGHTING	MH LOBBY CANOPY RECESSED LIGHT OUT	MH LOBBY CANOPY	4/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP	0.50
2014043564	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #2 IS CLOGGED	M'S R/R B309	4/21/2014		UNCLOGGED WITH PLUNGER	0.50
2014043577	MAINTENANCE ODW BLDG/EQUIP. REP	RM 20 - HANG PICTURE CONTAINING 3 CALENDARS IN CINDY RILLING'S OFFICE. ENTER THROUGH THE SECRETARY'S OFFICE (RM 21).	RM 20	4/22/2014		HUNG PICTURE	0.50

2014043578	MAINTENANCE ODW PLUMBING	M'S R/R A35 TOILET WILL NOT FLUSH	M'S R/R A35	4/22/2014	AA BATTERIES-COV;AA BATTERIES ;; DIAPHRAGM-COV;DIAPHRAGM ;; O-RINGS-COV;O-RINGS ;	REPLACED BATTERIES (4 AA), DIAPHRAGM AND "O" RING	0.50
2014043581	MAINTENANCE ODW INT. LIGHTING	POLE 6HH LIGHT BULB ABOVE DESK NEEDS CHANGED	POLE 6HH	4/22/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;; LIGHT BULB-COV;LIGHT BULB ;	REPLACED LIGHT BALLAST AND 4 BULBS WITH THE WALK-BOARD.	1.00
2014043604	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP STALL CLOGGED	W'S R/R A34	4/22/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014043615	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A602 STALL #2 CLOGGED	M'S R/R A602	4/22/2014		UNCLOGGED WITH PLUNGER	0.50
2014043645	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE INFANT ROOM. THERE IS A BURNING SMELL.	CHILDCARE	4/23/2014		CHECKED ROOM. DID NOT NOTICE BURNING SMELL. CHECKED DRYER. OK.	0.50
2014043647	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 5 GATE WILL NOT CLOSE	GATEHOUSE 5	4/23/2014		CHECKED ALL CIRCUITS (CHECKED OUT). COMPUTER SYSTEM OUT OF SYNC. BACK ON LINE ATY 6:25 PM.	0.50
2014043648	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT CLOSE	GATEHOUSE 2	4/23/2014		CLOSED USING POSITION SWITCHES. COMPUTER SYSTEM OUT OF SYNC. BACK ON AT 6:25 PM. HAD TO KEEP GATE OPEN UNTIL 5:30 PM FOR TANK BUS TO PICK UP HANDICAP IRS EMPLOYEES.	1.00
2014043649	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT CLOSE	GATEHOUSE 2	4/23/2014		CLOSED GATES USING POSITION SWITCHES. SYSTEM BACK UP AT 4:45 PM. PUT SWITCHES BACK AND TESTED.	1.00
2014043650	MAINTENANCE ODW DOOR	B4 AUTO DOOR NOT SECURING TO MAGNET	B4	4/23/2014		ADJUSTED CLOSURE ARM TO WORK PROPERLY.	1.50
2014043651	MAINTENANCE ODW INT. LIGHTING	103F SEVERAL LAMPS BURNED OUT	103F	4/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014043664	MAINTENANCE ODW ROOF LEAK	BLDG A - ROOF LEAKS	BLDG A	4/23/2014		PATCHED AND WATER TESTED. SEE ATTACHED.	7.50
2014043665	MAINTENANCE ODW ROOF LEAK	BLDG A - ROOF LEAKS	BLDG A	4/23/2014		PATCHED ROOF AND WATER TESTED. SEE ATTACHED.	7.50
2014043670	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 STALL #3 IS CLOGGED AND THERE IS WATER ON THE FLOOR	W'S R/R A34	4/23/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014043688	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 STALL #11 CLOGGED	W'S R/R A600	4/23/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH REBUILT	1.00
2014043689	MAINTENANCE ODW PLUMBING	W'S R/R B302 STALL 6 LEAKING	W'S R/R B302	4/23/2014	BREAKER-COV;BREAKER ;	REPLACED VACUUM BREAKER. OK.	0.50
2014043711	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHT FIXTURE COMPLETELY BURNED OUT	AREA 9	4/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2014043732	MAINTENANCE ODW BLDG/EQUIP. REP	CANDLING RM HAS AN ODOR	CANDLING RM	4/24/2014		WALKED THROUGH AREA, DID NOT SMELL ANYTHING. CHECKED AHU 16 AND 17 AND DID NOT SMELL ANYTHING THERE EITHER.	0.50
2014043733	MAINTENANCE ODW CEILING TILE	RM 200 METRIC TILE IS IN A STANDARD GRID	RM 200	4/24/2014	2x2 CEILING TILE-COV;2x2 CEILING TILE ;	REPLACED METRIC TILE WITH STANDARD 2X2	0.50
2014043734	MAINTENANCE ODW DOOR	DOOR B313 AUTOMATIC SLIDING DOOR WILL NOT OPEN ALL THE WAY	DOOR B313	4/24/2014		DOOR OPENS ABOUT HALF-WAY, THEN CLOSES. A HOLD-OPEN COMMAND FROM SECURITY WILL KEEP DOOR OPEN. PROBLEM IS THE TIME DELAY SIGNAL FROM ADT IS NOT LONG ENOUGH. SECURITY WILL NOTIFY SUE W. TO HAVE DELAY CHANGED.	0.50
2014043749	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHT FIXTURE NOT WORKING	AREA 6	4/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.25
2014043756	MAINTENANCE ODW BLDG/EQUIP. REP	JOHNSON ST. NEEDS SINKHOLE REPAIRED	JOHNSON ST.	4/25/2014		COLD PATCHED JOHNSON STREET SINKHOLE	1.00
2014043757	MAINTENANCE ODW BLDG/EQUIP. REP	C LOT CATCH BASIN NEEDS PATCHED	C LOT	4/25/2014		COLD PATCHED CATCH BASIN SINKHOLE IN C LOT	1.00
2014043758	MAINTENANCE ODW BLDG/EQUIP. REP	D LOT NEEDS WHEEL STOPS REPAIRED/REPLACED	D LOT	4/25/2014		REPLACED TWO STOPS IN D LOT AND REPAIRED ONE STOP IN D LOT	3.00
2014043759	MAINTENANCE ODW BLDG/EQUIP. REP	A LOT NEEDS WHEEL STOP REPLACED	A LOT	4/25/2014		REPLACED 1 STOP IN A LOT	1.00
2014043777	MAINTENANCE ODW BLDG/EQUIP. REP	200F AHU 15-2 CHILLED WATER VALVE LEAKING AT VALVE STEM	200F	4/25/2014		TIGHTENED PACKING NUT ON VALVE. CLEANED VALVE STEM. CHECKED FOR LEAKS AFTER THREE HOURS OF OPERATION. NO LEAKS FOUND.	1.00
2014043793	MAINTENANCE ODW LEAKS	AREA 8 WAREHOUSE ROOF LEAK	AREA 8	4/28/2014		4-28 PLACED DUMP CART UNDER LEAK. 5-1 REMOVED DRAIN COLLAR, DRILLED AND TAPPED 3 BROKEN BOLTS, CLEANED, RESEALED AROUND BOTTOM FLANGE OF ROOF DRAIN. LEAK TESTED AND SAW NO VISIBLE LEAKS.	5.50
2014043798	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP COMMODE CLOGGED	M'S R/R A810	4/28/2014		UNCLOGGED THE COMMODE	0.50
2014043799	MAINTENANCE ODW INT. LIGHTING	AREA 7 SEVERAL LIGHTS OUT	AREA 7	4/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS AND VACUUMED TWO LIGHT FIXTURES	0.75
2014043800	MAINTENANCE ODW INT. LIGHTING	M'S R/R A602 LAMPS OUT	M'S R/R A602	4/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	2.00
2014043801	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS BURNED OUT	AREA 1	4/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014043802	MAINTENANCE ODW DOOR	B313 DOOR NOT OPENING	B313	4/28/2014		CHECKED SWITCH ON DOOR. DOOR WORKS PROPERLY NOW.	0.50
2014043804	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE WEST RED WALL NEEDS WALL PATCHED IN THE INDOOR GYM	CHILDCARE	4/28/2014		REMOVED BROKEN DRYWALL AND PATCHED WALL WITH DRYWALL COMPOUND. SANDED WALL AND PAINTED.	1.00
2014043805	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 (COMPUTER DOWN) AND CANNOT CONTROL GATES TO OPEN FOR MAIL TRUCK	GATEHOUSE 2	4/28/2014		OPENED AND CLOSED GATES MANUALLY FOR MAIL TRUCK	0.50
2014043806	MAINTENANCE ODW GLASS	MADISON AVE HAS BROKEN GLASS FROM A CAR WRECK	MADISON AVE	4/28/2014		BLOCKED SPACE WITH CONE FROM GATEHOUSE 3. SWEEPED UP GLASS.	0.50
2014043807	MAINTENANCE ODW CEILING TILE	CHILDCARE HAS TWO TILES THAT HAVE POPPED UP IN RM 128	CHILDCARE	4/28/2014		REHUNG TWO CEILING TILES	0.50
2014043827	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 126 HAS A CHROME PLATE ON THE NORTH WALL AND WATER IS COMING THROUGH IT.	CHILDCARE RM 126	4/28/2014		WATER LEAKING THROUGH CAP MOUNTING SCREW. APPLIED TEFLON TAPE TO SCREW AND PUT CAP BACK ON.	0.50
2014043828	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 123 SINK IS CLOGGED	CHILDCARE RM 123	4/28/2014		UNCLOGGED WITH PLUNGER AND FLUSHED	0.50
2014043832	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #3 IS STOPPED UP	M'S R/R B309	4/28/2014		CLEARED CLOG WITH PLUNGER	0.50
2014043838	MAINTENANCE ODW PLUMBING	W'S R/R A600 FIRST STALL IS DRIPPING	W'S R/R A600	4/28/2014		FLUSHED ALL TOILETS. NO LEAKS.	0.50
2014043894	MAINTENANCE ODW BLDG/EQUIP. REP	(PER JASON) LOBBY ENTRANCE, EXTERIOR STAIRS. THE METAL NOSING HAS POPPED UP AND NEEDS REPAIRED.	LOBBY ENTRANCE	4/29/2014		DRILLED OUT REMAINS OF OLD SCREWS IN MISSING SCREW HOLES IN NOSING. INSTALLED THREE TAPCON FLAT HEAD SCREWS IN LOOSE NOSING PIECES.	1.00
2014043911	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET CONSTANTLY RUNNING	W'S R/R A1003	4/29/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH REBUILT	0.50
2014043912	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B211 OUTSIDE HANDICAP BUTTON LAYING ON THE FLOOR	W'S R/R B211	4/29/2014		SOLDERED CONNECTIONS FROM BATTERY TO CIRCUIT BOARD AND REINSTALLED BUTTON	1.50
2014043949	MAINTENANCE ODW INT. LIGHTING	AREA 11 POLE 5V LIGHTS OUT	AREA 11	4/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50

2014043950	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE COMPLAINT OF AN ELECTRIC-PLASTIC SMELL	CHILDCARE	4/30/2014		CHECKED BREAKER PANELS AND KITCHEN EQUIPMENT. COULD NOT SMELL ANYTHING UNUSUAL. NO FURTHER ACTION TAKEN. WILL SPOT-CHECK WEDNESDAY EVENING AND THURSDAY. CUSTODIAN WILL CALL IF SHE SMELLS ANYTHING.	0.50
2014050004	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 TOILET WILL NOT STOP RUNNING	CHILDCARE	5/1/2014		TURNED WATER OFF TO TOILET AND WAITED A COUPLE OF MINUTES. TURNED BACK ON. FLUSHED A FEW TIMES. OK.	0.50
2014050005	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 FLOOR TILES MISSING	CHILDCARE	5/1/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REPLACED MISSING TILES WITH NEW	1.50
2014050006	MAINTENANCE ODW DOOR	SOUTH B313 DOORS WILL NOT OPEN WITH CARD READER	SOUTH B313	5/1/2014		MANUALLY OPENED DOORS AND PUSHED THE RESET BUTTON. TESTED DOORS A FEW TIMES. OK.	0.50
2014050591	MAINTENANCE ODW PLUMBING	W'S R/R A600 TOILET CONTINUOUSLY RUNNING	W'S R/R A600	5/1/2014			0.00
2014052493	MAINTENANCE ODW PLUMBING	W'S R/R A600 CONSTANTLY FLUSHING COMMODE	W'S R/R A600	5/1/2014		ADJUSTED SLUSH VALVE	0.50
2014052494	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET CLOGGED	M'S R/R A308	5/1/2014		CLEARED COMMODE	1.00
2014052784	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 CLOGGED	M'S R/R B309	5/2/2014		UNCLOGGED WITH PLUNGER	0.00
2014052785	MAINTENANCE ODW INT. LIGHTING	AREA 4 POLE 40 LAMPS OUT IN FIXTURE OVER SE CORNER OF CUBICLE	AREA 4 POLE 40	5/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014052786	MAINTENANCE ODW INT. LIGHTING	RM 200 LIGHTS FLICKERING IN BADGE ROOM	RM 200	5/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 6 T-8 BULBS AND REPLACED BALLAST	1.00
2014052799	MAINTENANCE ODW INT. LIGHTING	SCAMPS - TWO LIGHT FIXTURES COMPLETELY BURNED OUT	SCAMPS	5/5/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED TWO LIGHT BALLASTS AND EIGHT LIGHT BULBS	1.25
2014052800	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHT FIXTURE NOT WORKING	AREA 5	5/5/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND CHANGED LAMP. REWIRED FIXTURE.	1.50
2014052801	MAINTENANCE ODW INT. LIGHTING	AREA 11 BULBS BURNED OUT	AREA 11	5/5/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	1.50
2014052802	MAINTENANCE ODW INT. LIGHTING	HALLWAY 21 LIGHTS BURNED OUT	HALLWAY 21	5/5/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014052842	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 123 SINK CLOGGED	CHILDCARE RM 123	5/5/2014		COMMON DRAIN FOR SINKS 1 AND 2. SNAKED OUT TO CLEAR DRAINS.	0.50
2014052848	MAINTENANCE ODW INT. LIGHTING	W'S R/R A404 LIGHTS OVER TOILET #10 AND SINKS 8 AND 9	W'S R/R A404	5/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014052849	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHT FIXTURE NOT WORKING	AREA 5	5/6/2014		TOOK FIXTURE APART. FOUND IT TO BE A LOOSE CONNECTION.	0.50
2014052850	MAINTENANCE ODW INT. LIGHTING	B315 LIGHTS NOT WORKING	B315	5/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST IN BOTH FIXTURES. OK. BAD BALLASTS. EIGHT FLOURESCENT LAMPS REPLACED.	4.50
2014052851	MAINTENANCE ODW INT. LIGHTING	COURTYARD CAFE (200B) LIGHT FIXTURE NOT WORKING	COURTYARD CAFE	5/6/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.00
2014052919	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL #14 STOPPED UP	W'S R/R B211	5/6/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014052920	MAINTENANCE ODW TEMPERATURE COLD	POLES 4K, 5K, 4G, 5G TOO COLD. THERMOSTATS LOCATED ON POLES 4J-0209/4H-0208/5J-0206.	POLES 4K, 5K, 4G, 5G	5/6/2014		SPACE TEMP AT 5G 73.1, 28.6 RH. SPACE TEMP AT 4G IS ALSO 73.2, 4H IS 28.6. SPACE TEMP AT 5K IS 73.1, RH IS 28.6. SPACE TEMP AT 4K IS 73.1, RH IS 29.1. ALL TEMPS WITHIN CONTRACT LIMITS. MANAGER SAID SOME EMPLOYEES ARE COMPLAING ABOUT DIFFUSERS BLOWING ON THEM.	0.50
2014052924	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #14 STOPPED UP	W'S R/R A404	5/6/2014		STALL #3 WAS CLOGGED (NOT #14). CLEARED CLOG WITH PLUNGER.	0.50
2014052932	MAINTENANCE ODW TEMPERATURE COLD	RM 209G - SHUT OFF DIFFUSER. YOU WILL NEED THE LIFT OR A TALL LADDER.	RM 209G	5/6/2014		ONLY ONE DIFFUSER IN ROOM. DAMPERED IT A LITTLE MORE SHUT. THEY WILL NEED SOME AIR FLOW.	0.50
2014052935	MAINTENANCE ODW DOOR	W'S R/R A306 HANDICAP DOOR OPENER ON THE INSIDE OF THE RESTROOM IS NOT WORKING	W'S R/R A306	5/6/2014		REPAIRED BAD CONNECTION ON SWITCH ON INSIDE DOOR BUTTON	0.50
2014052943	MAINTENANCE ODW INT. LIGHTING	BADGE RM 200 NEEDS 3 LIGHTS REPLACED IN STORAGE ROOM	BADGE RM 200	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED THREE LAMPS (T8'S)	0.50
2014052944	MAINTENANCE ODW BLDG/EQUIP. REP	DOOR 17 HALLWAY COVE BASE CAME OFF OF WALL	DOOR 18 HALLWAY	5/7/2014		REATTACHED CORE BASE USING POWER GRIP	0.50
2014052945	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 7Q PROTECTOR CAME OFF THE CORNER OF POLE	POLE 7Q	5/7/2014		REATTACHED PROTECTOR WITH POWER GRIP	0.50
2014052946	MAINTENANCE ODW INT. LIGHTING	MDF LIGHTS BURNED OUT	MDF	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014052947	MAINTENANCE ODW INT. LIGHTING	B314 LIGHTS BURNED OUT	B314	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014052948	MAINTENANCE ODW INT. LIGHTING	AREA 13 LIGHTS BURNED OUT	AREA 13	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014052949	MAINTENANCE ODW INT. LIGHTING	AREA 14 LIGHTS BURNED OUT	AREA 14	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BULB-COV;LIGHT BULB ;	REPLACED LAMPS	1.00
2014052950	MAINTENANCE ODW INT. LIGHTING	AREA 12 LIGHTS BURNED OUT	AREA 12	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	3.00
2014052958	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 7 POLE 10M HAS AN ODOR	AREA 10 POLE 10M	5/7/2014		CHECKED AROUND 10M AND DID NOT NOTICE ODOR. CHECKED MEZZANINE, NO ODOR. AHU 16 AND 17 OK.	0.50
2014052999	MAINTENANCE ODW BLDG/EQUIP. REP	MAIN LOBBY FRONT STEPS NEED PATCHED	MAIN LOBBY	5/7/2014		PATCHED SEVERAL SMALL POPPED AREAS	4.00
2014053001	MAINTENANCE ODW INT. LIGHTING	RM 804 - CUSTODIAL RM HAS 3 LIGHTS OUT	RM 804 -CUSTODIAL RM	5/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053008	MAINTENANCE ODW BLDG/EQUIP. REP	NORTH OF NORTH SWITCH GEAR GARAGE - ACCESS PLATE NEEDS TO BE INSTALLED	NORTH SWITCH GEAR	5/8/2014		ORDERED PART. TRAVELED TO PICK UP PART. INSTALLED PART.	3.00
2014053009	MAINTENANCE ODW DOOR	DOOR B4 METAL PLATE THAT HOLDS THE MAG LOCK IS COMING OFF	DOOR B4	5/8/2014		TIGHTENED HEX SCREW TO SECURE METAL PLATE	0.50
2014053010	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 TOILET CLOGGED	W'S R/R A404	5/8/2014		UNCLOGGED WITH PLUNGER	0.50
2014053020	MAINTENANCE ODW INT. LIGHTING	LOCATED ALONG THE RAIL IN FRONT OF POLE 6S CEILING LIGHT IS FLICKERING	POLE 6S	5/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014053046	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS BURNED OUT OUTSIDE DOOR 22 AND DOOR A4	MAG HALL	5/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LIGHTS AT DOOR 22 AND DOOR A4	1.00
2014053047	MAINTENANCE ODW BLDG/EQUIP. REP	700 COMPS FAN NOT WORKING ON AIR DRYER (A1-004-07)	700 COMPS	5/8/2014		REMOVED AIR DRYER, BROUGHT UNIT BACK TO SHOP TO INSPECT. REMOVED BAD FAN AND REPLACED. CLEANED COILS. WASHED FAN BLADE. WENT TO A-1 TO GET REPLACEMENT FAN.	8.00
2014053055	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 STALL #1 CLOGGED	W'S R/R A306	5/9/2014		PLUNGED THE COMMODE	0.50
2014053056	MAINTENANCE ODW TEMPERATURE HOT	AREA 11 POLE 5Y TOO HOT	AREA 11	5/9/2014		METSYS READING 72.9. TOOK THREE READINGS 74.4, 74.8 AND 74.9. COOLING VALVE AT 100%. SUPPLY TEMP 60.7 DEG. TEMP WITHIN CONTRACT. MADE NO CHANGES.	0.50
2014053057	MAINTENANCE ODW INT. LIGHTING	B317 LIGHTS OUT	B317	5/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75

2014053058	MAINTENANCE ODW INT. LIGHTING	B 305A LIGHTS OUT	B 305A	5/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR LAMPS	1.50
2014053059	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHTS OUT	SATELLITE CANTEEN	5/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053109	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 CANASTER LIGHTS OUT ABOVE SINK	W'S R/R A1003	5/12/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 3 LIGHT BULBS. REPLACED 10 FLOURESCENT BULBS.	1.25
2014053111	MAINTENANCE ODW INT. LIGHTING	AREA 1, POLE 8L LIGHT IS MAKING A CRACKLING NOISE	AREA 1, POLE 8L	5/12/2014		REMOVED PAPER FROM AIR DIFFUSER BESIDE THE LIGHT FIXTURE. PAPER WAS MAKING THE CRACKLING NOISE.	0.50
2014053112	MAINTENANCE ODW UTILITY WORK	AREA 5 THREE FIXTURES' LENS COVERS SAGGING	AREA 5	5/12/2014		RESEATED THE LENS COVERS AND SILICONE TO HOLD IN PLACE.	1.00
2014053113	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	5/12/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS THAT WERE OUT	2.00
2014053114	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	5/12/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS THAT WERE OUT	0.75
2014053115	MAINTENANCE ODW UTILITY WORK	AREA 10 LIGHT LENS SAGGING	AREA 10	5/12/2014		REPAIRED FIX SAGGING LIGHT LENSES	1.00
2014053116	MAINTENANCE ODW INT. LIGHTING	AREA 10 SEVERAL OVERHEAD LIGHTS OUT	AREA 10	5/12/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 20 LIGHT BULBS	1.00
2014053149	MAINTENANCE ODW PLUMBING	M'S R/R A602 URINAL CONTINUOUSLY RUNNING	M'S R/R A602	5/12/2014		URINAL #2. CLEARED CLOGGED URINAL.	1.00
2014053152	MAINTENANCE ODW TEMPERATURE HOT	RM 700 TOO HOT	RM 700	5/12/2014		9:00 AM 74.4 DEGREES. 10:00 AM 72.0 DEGREES. ADJUSTED SPACE SET POINT ON ACU #16 AND ACU #17 ONE DEGREE. CHECKED AT 1:30 PM. 71.8 DEGREES.	1.00
2014053153	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE ROOF EXHAUST FAN 2 NOT WORKING	CHILDCARE ROOF	5/12/2014		FAN MOTOR BURNED OUT. REPLACED FAN MOTOR. OK.	6.00
2014053178	MAINTENANCE ODW SAFETY ISSUE	AREA 14 - 1CC LIGHT LENS IS HANGING	AREA 14	5/13/2014		PUT LIGHT LENS BACK IN PLACE	0.50
2014053195	MAINTENANCE ODW INT. LIGHTING	RM 21 HAS A LIGHT BULB OUT. PLEASE CHECK RMS 20 AND 22 AS WELL.	RM 21	5/13/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	CHANGED LAMPS IN 21 AND 22	0.50
2014053211	MAINTENANCE ODW PAINTING	GATE 1 DRIVE MOTOR BOX IS RUSTY AND FADED	GATE 1	5/13/2014		APPLIED TWO COATS OF OIL BASED PAINT	1.00
2014053212	MAINTENANCE ODW PAINTING	GATE 2 DRIVE MOTOR BOXES ARE RUSTY AND FADED	GATE 2	5/13/2014		SANDED, PRIMED AND PAINTED WITH TWO COATS OIL BASED PAINT	2.00
2014053213	MAINTENANCE ODW PAINTING	GATE 3 DRIVE MOTOR BOXES ARE RUSTY AND FADED	GATE 3	5/13/2014		SANDED, PRIMED AND PAINTED WITH TWO COATS OF OIL BASED PAINT	2.00
2014053214	MAINTENANCE ODW PAINTING	GATE 4 DRIVE MOTOR BOXES ARE RUSTY AND FADED	GATE 4	5/13/2014		SANDED, PRIMED AND PAINTED WITH TWO COATS OF OIL BASED PAINT	4.00
2014053259	MAINTENANCE ODW INT. LIGHTING	BADGE RM HALLWAY LIGHTS OUT	BADGE RM HALLWAY	5/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053281	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A700H CLOGGED SINKS	W'S R/R A700H	5/15/2014		CLEARED CLOG. SNAKED DRAIN AND REPAIRED DRAIN TRAP UNDER #6. PIPE WAS WORN THROUGH, LEAKING UNDER COUNTER.	4.00
2014053283	MAINTENANCE ODW SAFETY ISSUE	SOUTH SIDE OF COURTYARD THERE IS A LIGHT LENS HANGING	SOUTH SIDE OF COURTYARD	5/15/2014		RESET LIGHT LENS. OK.	0.50
2014053334	MAINTENANCE ODW UTILITY WORK	AREA 8 MOP SINK 800 DEBRIS GETTING INTO DRAIN LINE	AREA 8	5/16/2014		INSTALLED NEW DRAIN COVER	1.00
2014053335	MAINTENANCE ODW INT. LIGHTING	MAG HALL LOBBY CANISTER LIGHT OUT FACING FLAG ON NORTH WALL	MAG HALL LOBBY	5/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP	0.50
2014053337	MAINTENANCE ODW INT. LIGHTING	LOOSE LENSES - N OF 4H, IN FRONT OF 307, S OF 5M AND N OF 40. TILE FALL N OF 4K.	AREAS 3 AND 4	5/16/2014		REPAIRED LOOSE LENS COVERS AND PUT CEILING TILE AT 4K BACK ON TRACK.	1.00
2014053338	MAINTENANCE ODW TEMPERATURE HOT	AREA 11 4Y TOO HOT	AREA 11	5/16/2014		METSYS READING 73.3 AND A SUPPLY AIR TEMP 72. TOOK THREE READINGS IN AREA: 76.2, 76.3 AND 76.2. A LITTLE HIGH. DROPPED SET POINT ON 72.	0.50
2014053339	MAINTENANCE ODW EXT. LIGHTING	DOOR 18 OUTSIDE FLOOD LAMP BURNED OUT	DOOR 18	5/16/2014	FLOOD LIGHT-COV;FLOOD LIGHT 75W ;	REPLACED FLOOD LAMP	0.50
2014053361	MAINTENANCE ODW SAFETY ISSUE	POLE 6T HAS A BLACK ELECTRICAL OUTLET ON THE FLOOR THAT IS CRACKED (SOMEONE TRIPPED OVER IT)	POLE 6T	5/16/2014		REPLACED WSI COVER WITH 1/2" WOODEN PLATE	0.50
2014053362	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET STOPPED UP	M'S R/R B309	5/16/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014053363	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #13 IS STOPPED UP	W'S R/R B211	5/16/2014		CLEARED CLOG WITH PLUNGER. OK.	0.50
2014053381	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 COMMODOE #2 IS CLOGGED	M'S R/R A1005	5/19/2014		UNCLOGGED THE COMMODOE	0.50
2014053382	MAINTENANCE ODW UTILITY WORK	JOHNSON ST ENTRANCE GATE SIGNS NEED HUNG	JOHNSON ST	5/19/2014		HUNG SIX SIGNS. HARDWARE COST: HOME DEOPT 55.67; HOME DEPOT 51.04; FASTENAL 48.00.	3.00
2014053383	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS BURNED OUT	AREA 1	5/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053384	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHT FIXTURE NOT WORKING	AREA 11	5/19/2014		REPLACED BALLAST AND REWIRED FIXTURE. REPLACED LAMPS. OK.	1.50
2014053385	MAINTENANCE ODW CEILING TILE	RM 118 CEILING TILE IS FALLING IN THE CORNER	ROOM 118	5/19/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED MISSING T-BRACE FOR CEILING TILE. REPLACED ONE CEILING TILE. FIXED THE OTHER CEILING TILE.	0.50
2014053386	MAINTENANCE ODW CEILING TILE	MAG HALL EAST WALKWAY CEILING TILE HAS A BROKEN CORNER	MAG HALL	5/19/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILING TILE	0.50
2014053387	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 123 - THERE IS A HOLE IN THE WALL	CHILDCARE RM 123	5/19/2014		A HOLE WAS PUNCHED THROUGH THE WALL WITH THE HALF DOOR AT THE RESTROOM. APPLIED FIRST COAT OF MUD, LET DRY, APPLIED SECOND COAT OF MUD, LET DRY. SANDED THE AREA AND REPAINTED. TOUCHED UP SEVERAL AREAS IN THE SAME ROOM WITH PAINT.	2.00
2014053388	MAINTENANCE ODW INT. LIGHTING	RM 101 LIGHT OUT	RM 101	5/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014053389	MAINTENANCE ODW INT. LIGHTING	AREA 9 OVERHEAD LIGHTS OUT	AREA 9	5/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED NINE LIGHT BULBS. REPAIRED SIX SAGGING LIGHT LENSES AND VACUUMED LENSES.	1.50
2014053391	MAINTENANCE ODW INT. LIGHTING	CHILDCARE TEACHER'S R/R LIGHT OUT	CHILDCARE	5/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULB	0.50
2014053392	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 13 RUBBER BASE COMING LOOSE	AERA 13	5/19/2014	ADHESIVE-COV;ADHESIVE ;	REGLUED RUBBER BASE BACK TO WALL	1.00
2014053403	MAINTENANCE ODW PLUMBING CLOG	AREA 8 WASHER/DRYER SINK STOPPED UP	AREA 8	5/19/2014		SAW STELLA IN HALLWAY AND ASKED HER ABOUT SINK. SHE TOLD ME SOMEONE CLEANED WAX BUCKET OUT. SHE CLEANED DRAIN COVER AND SINK. WAS OK. I CHECKED DRAIN AND IT'S FINE.	0.50
2014053408	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE SINK IN CAFETERIA IS BACKED UP	CHILDCARE	5/19/2014		CLEARED CLOG WITH PLUNGER	0.50
2014053409	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 128 SINK STOPPED	CHILDCARE RM 128	5/19/2014		CLEARED CLOG, REMOVED PENCIL FROM SINK. DRAINS OK NOW.	0.50
2014053410	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A35 TOILET CLOGGED	M'S R/R A35	5/19/2014		CLEARED CLOG WITH PLUNGER	0.50
2014053414	MAINTENANCE ODW PLUMBING	W'S R/R B302 FIRST STALL'S PIPE LEAKING. W'S R/R B302 HANDICAP STALL LIGHT IS OUT.	W'S R/R B302	5/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	ADJUSTED NUT BELOW FLUSHHEAD ON TOILET #1 TO STOP LEAK. REPLACED LAMPS OVER TOILETS 4 AND 5.	0.50
2014053432	MAINTENANCE ODW INT. LIGHTING	M'S R/R A1005 LIGHTS OUT OVER URINAL	M'S R/R A1005	5/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50

2014053442	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 STALL 21 STOPPED UP	W'S R/R A1003	5/20/2014		THERE WAS ALOT OF PAPER IN THE TOILET. FLUSHED TOILET AND PAPER WENT DOWN THE DRAIN. IT'S OK.	0.50
2014053471	MAINTENANCE ODW PLUMBING	M'S R/R A35 FAUCET CONTINUOUSLY RUNNING	M'S R/R A35	5/20/2014		REPLACED SINK SOLENOID. OK.	1.00
2014053472	MAINTENANCE ODW INT. LIGHTING	600 MEZZANINE LIGHT FIXTURE NOT WORKING NEXT TO 10-6 AHU	MEZZANINE	5/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.50
2014053473	MAINTENANCE ODW INT. LIGHTING	AREA 14 BALLAST IS BAD AND LIGHT NOT WORKING	AREA 14	5/20/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.50
2014053476	MAINTENANCE ODW PLUMBING	W'S R/R A34 TOILET CLOGGED	W'S R/R A34	5/20/2014		UNCLOGGED WITH PLUNGER	0.50
2014053542	MAINTENANCE ODW INT. LIGHTING	MAG HALL HALLWAY LIGHTS OUT IN FIXTURES OUTSIDE 15 AND 20	MAG HALL HALLWAY	5/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053553	MAINTENANCE ODW PLUMBING	M'S R/R A700i SINK RUNNING	M'S R/R A700i	5/21/2014	C BATTERIES-COV;C BATTERIES ;; SOLENOID-COV;SOLENOID ;	REPLACED BATTERIES (4 C'S) AND REPLACED SOLENOID WITH A NEW ONE.	0.50
2014053566	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL #14 STOPPED UP	W'S R/R B211	5/21/2014		CLEARED CLOG WITH PLUNGER	0.50
2014053602	MAINTENANCE ODW INT. LIGHTING	AREA 3 BETWEEN POLES 4E AND 4F	AREA 3	5/22/2014			0.00
2014053603	MAINTENANCE ODW BLDG/EQUIP. REP	700K LIGHT LENS HANGING	700K	5/22/2014		PROPERLY INSTALLED LIGHT LENS. OK.	0.50
2014053604	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 602 #2 URINAL STOPPED UP	M'S R/R 602	5/22/2014		REMOVED CHEWING GUM AND TOILET PAPER (SAME AS LAST WEEK)	0.50
2014053605	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 404 STALL #3 STOPPED UP	W'S R/R 404	5/22/2014		UNCLOGGED WITH PLUNGER	0.50
2014053606	MAINTENANCE ODW INT. LIGHTING	W'S R/R B211 CEILING LIGHT OUT	W'S R/R B211	5/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS IN FOYER FIXTURE	0.50
2014053607	MAINTENANCE ODW INT. LIGHTING	M'S R/R 403 CEILING LIGHT OUT	M'S R/R 403	5/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053609	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 FOUR TOILETS ARE CLOGGED	W'S R/R A404	5/22/2014		SNAKED MAIN DRAIN THROUGH TOILET, CLEARED CLOG. RAN WATER THROUGH MAIN FOR ABOUT 5 MINUTES TO ENSURE OBSTRUCTION WAS GONE.	2.00
2014053618	MAINTENANCE ODW INT. LIGHTING	RCO POLE 8G BY COURYARD WALL - LIGHTS OUT ABOVE JUDY MONDAY'S DESK	RCO POLE 8G	5/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	COMPLETE. REPLACED BALLAST AND LAMPS.	1.25
2014053657	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 SINKS 1 AND 2 ARE SLOW	W'S R/R A1003	5/23/2014		CLOG CLEAR. FLUSHED WITH WATER. TESTED ALL SINKS. ALL DRAINS FUNCTIONING NORMALLY.	0.50
2014053708	MAINTENANCE ODW TEMPERATURE HOT	POLE 7V TOO HOT/HUMID	7V	5/27/2014		UNITS AT MAXIMUM COOLING CAPACITY	0.50
2014053709	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 126 FOUR FLOOR TILES COMING UNGLUED	CHILDCARE RM 126	5/27/2014		CLEANED AND REGLUED FOUR TILES TO FLOOR. 5-28-14 REMOVED GLUE IN SEVERAL AREAS.	1.25
2014053710	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 110 BAD BALLAST	CHILDCARE RM 110	5/27/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED FIXTURE	1.00
2014053711	MAINTENANCE ODW DOOR	AREA 14 DOOR B3 NORTH DOOR NOT CLOSING ALL THE WAY	AREA 14 DOOR B3	5/27/2014		LUBED ALL MOVING PARTS AND TESTED. FUNCTIONING NORMALLY.	0.50
2014053728	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 BOTH TOILETS CLOGGED	M'S R/R A810	5/27/2014		HANDICAPPED TOILET FLUSHED OKAY AND WAS NOT CLOGGED. CLEARED SECOND TOILET CLOG WITH PLUNGER.	0.50
2014053739	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 7GG TELEVISION IS TILTED AND NEEDS TO BE SECURED	POLE 7GG	5/27/2014		ADJUSTED AND SECURED TV	0.50
2014053783	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A700H TOILET WILL NOT FLUSH	W'S R/R A700H	5/28/2014		REPLACED BATTERIES. STILL WOULD NOT FLUSH. PUT IN REBUILT FLUSH HEAD FROM STOCK.	0.50
2014053784	MAINTENANCE ODW INT. LIGHTING	AREA 11 SOUTH OF POLE 4T	AREA 11 SOUTH	5/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014053797	MAINTENANCE ODW RESTROOM FIXTURE	M'S R/R A35 HANDICAP DOOR OPENER NEEDS BATTERIES	M'S R/R A35	5/28/2014	9V BATTERIES-COV;9V BATTERIES ;	OUTSIDE BUTTON IS WORKING. INSIDE BUTTON NOT WORKING SO I REPLACED 9V BATTERY. OK.	0.50
2014053809	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 FIRST 2 SINKS ARE RUNNING AND BEGINNING TO CLOG	W'S R/R A1003	5/28/2014		REMOVED TOWEL DISPENSER AND GARBAGE CAN ENCLOSURE TO ACCESS STACK AND SNAKED THRONG "TEE." DRAINS ARE BOTH DRAINING OK.	1.00
2014053835	MAINTENANCE ODW BLDG/EQUIP. REP	WATER IS LEAKING OUT OF AHU 2-3 IN RM 303	RM 303	5/29/2014		VACUUMED UP WATER WITH WET VAC. LEFT STAINLESS STEEL WET VAC IN ROOM FOR FUTURE USE.	0.50
2014053836	MAINTENANCE ODW UTILITY WORK	RM 307 NEEDS 2 RETURN VENTS INSTALLED	RM 307	5/29/2014		CUT AND INSTALLED RETURN VENTS IN CEILING	0.75
2014053861	MAINTENANCE ODW BLDG/EQUIP. REP	B101 EXTERIOR DOOR THRESHOLD IS LOOSE	B101	5/29/2014		REPLACED 1 ANCHOR AND INSTALLED NEW SCREWS	0.50
2014053862	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #3 IS CLOGGED	W'S R/R A404	5/29/2014		CLEARED CLOG WITH PLUNGER	0.50
2014053869	MAINTENANCE ODW PLUMBING CLOG	AREA 7 TOILET CLOGGED	AREA 7	5/29/2014		CHECKED MEN'S ROOM, TOILET FLUSHES OK. CHECKED WOMEN'S ROOM, ALL TOILETS FLUSH OK.	0.50
2014053883	MAINTENANCE ODW INT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	5/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 12 LIGHT BULBS	0.50
2014053884	MAINTENANCE ODW INT. LIGHTING	RM 903 BALLAST AND LIGHTS OUT	RM 903	5/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND 4 LIGHT BULBS	1.00
2014053885	MAINTENANCE ODW INT. LIGHTING	POLE 4C LIGHT GOING OUT OVER DESK	POLE 4C	5/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS IN FIXTURE. THE FIXTURE IS IN AN AREA THAT WAS HARD TO GET TO DUE TO DESK AND CABINETS.	1.00
2014053886	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHTS OUT	SATELLITE CANTEEN	5/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014053894	MAINTENANCE ODW DOOR	AREA 7 DOOR TO RM 700 HAS A LOCK THAT WILL NOT ENGAGE. MECHANISM DOES NOT COME OUT FAR ENOUGH TO LATCH.	AREA 7	5/30/2014		AUTO-DOOR D4-023-07 INSTALLED KEY CYLINDER AND THUMB KNOB CORRECTLY (THEY WERE UPSIDE DOWN, MAY BE TO KEEP DOOR FROM BEING LOCKED). ALSO LUBED LOCK LINKAGES.	0.75
2014060537	MAINTENANCE ODW BLDG/EQUIP. REP	200F AREA OF THE FLOOR NEEDS PAINTED	200F	6/2/2014		PAINTED AREA THAT NEEDED IT	2.50
2014060538	MAINTENANCE ODW UTILITY WORK	200F 15-2 AHU NEEDS PAINTED	200F	6/2/2014		PAINTED AREAS IN QUESTION	1.50
2014060539	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHT FIXTURE NOT WORKING	AREA 1	6/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS. OK.	1.00
2014060541	MAINTENANCE ODW INT. LIGHTING	CHILDCARE HALL BATH LIGHT BURNED OUT	CHILDCARE	6/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULB	0.50
2014060542	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 10 RUBBER GOING UP THE RAMP IS COMING LOOSE	AREA 10	6/2/2014		INSTALLED A METAL TAPER EDGE MOLDING ALONG THE AREA	0.50
2014060543	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 FLOOR TILES HAVE POPPED UP	CHILDCARE	6/2/2014		FLOOR TILES POPPED UP WHEN THE FLOOR WAS BUFFED. CLEANED AND PREPPED THE FLOOR (GLUE) THEN MADE SEVERAL TRIPS BACK TO MAKE SURE GLUE WAS READY.	1.50
2014060544	MAINTENANCE ODW BLDG/EQUIP. REP	RM 34 ROOF EXHAUST FAN MOTOR PULLEY AND FAN SHAFT NOT ALIGNED	RM 34	6/2/2014		LOWERED FAN SHAFT PULLEY SO IT WOULD ALIGN	1.00
2014060545	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	6/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 20 LIGHT BULBS, 1 LIGHT BALLAST AND VACUUMED 5 LIGHT LENSES	1.50
2014061237	MAINTENANCE ODW INT. LIGHTING	AREA 4 NEAR POLE 4N LIGHTS OUT	AREA 4	6/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014061238	MAINTENANCE ODW INT. LIGHTING	AREA 11 NEAR POLE 4X LIGHTS OUT	AREA 11	6/2/2014		REPLACED LAMPS	0.50
2014061239	MAINTENANCE ODW INT. LIGHTING	B315 BALLAST IS BAD	B315	6/2/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST WITH NEW	1.00
2014061240	MAINTENANCE ODW INT. LIGHTING	AREA 13 BALLAST IS BAD	AREA 13	6/2/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST WITH NEW	1.00

2014061254	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 3 TOILETS ARE CLOGGED	M'S R/R B309	6/2/2014		ONLY 2 TOILETS WERE CLOGGED. CLEARED BOTH OF THEM. OK.	0.50
2014061255	MAINTENANCE ODW INDOOR AIR QUAL	POLE 4H POD 01-03-029 BLACK SUBSTANCE APPEARING ON DESK AND APPEARS TO BE COMING FROM AIR VENT	POLE 4H	6/2/2014		VACUUMED DIFFUSER AND AFFECTED CEILING TILES.	0.50
2014062321	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL #4 CLOGGED. THERE ARE LIGHTS OUT AS WELL.	W'S R/R B211	6/3/2014		CLEARED STALL #4 AND CLEARED STALL #12	0.50
2014062322	MAINTENANCE ODW INT. LIGHTING	W'S R/R B211 LIGHTS OUT	W'S R/R B211	6/3/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 6 F17T8, 3 PL-C-18W AND 12 F323T8 LIGHTS	1.00
2014062325	MAINTENANCE ODW INT. LIGHTING	AREA 14 LIGHT COVER LOOSE ON CEILING NEXT TO CLOCK AT DOOR B4	AREA 14	6/3/2014		SECURED COVER	0.50
2014062326	MAINTENANCE ODW PLUMBING	MAG HALL 28 ODOR OF TUNA IN DRAIN	MAG HALL 28	6/3/2014		FLUSHED WITH HOT WATER. NO ODOR DETECTED.	0.50
2014062328	MAINTENANCE ODW INT. LIGHTING	MAG HALL 41E LAMPS OUT INSIDE OFFICE.	MAG HALL 41E	6/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	0.50
2014062331	MAINTENANCE ODW RESTROOM FIXTURE	R/R B312 TOILET PAPER DISPENSER BROKEN IN STALL #1	R/R B312	6/3/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REPLACED DISPENSER	0.50
2014062332	MAINTENANCE ODW PLUMBING	W'S A600 SOUNDS LIKE WATER IS RUNNING BEHIND WALL	W'S A600	6/3/2014	DIAPHRAGM-COV;DIAPHRAGM ;	NO WATER RUNNING BEHIND WALL. WATER IS BLEEDING PAST DIAPHRAGM AND INTO TOILET (TOILET CONSTANTLY HAS WATER RUNNING). REBUILT AND REPLACED DIAPHRAGM.	1.00
2014062725	MAINTENANCE ODW UTILITY WORK	POLE 7GG AND WEST OF 7GG TV'S NEED REMOVED AND REPLACED WITH NEW	POLE 7GG	6/4/2014		REMOVED TV'S AND REPLACED WITH THE TWO IN SHOP	4.00
2014062726	MAINTENANCE ODW UTILITY WORK	AREA 12 VENTS APPEAR TO HAVE TOILET PAPER/STREAMERS IN THEM AND NEED TO BE REMOVED.	AREA 12	6/4/2014		LOOKED AT ALL VENTS IN AREA 12. DID NOT SEE ANY TOILET PAPER. REMOVED STREAMERS OFF OF VENTS THAT HAD THEM.	2.00
2014062760	MAINTENANCE ODW ELECTRICAL	AREA 12 7DD NO POWER	AREA 12 7DD	6/4/2014		RESET BREAKER IS B-015	0.50
2014062767	MAINTENANCE ODW PLUMBING	W'S R/R A600 COMMODE #14 FLUSHES TOO MUCH WATER AND GOES OVER THE SIDE OF THE BOWL	W'S R/R A600	6/5/2014		ADJUSTED FLUSH SO IT USES LESS WATER	0.50
2014062770	MAINTENANCE ODW EXT. LIGHTING	OUTSIDE FRONT LOBBY COMPACT FLUORESCENT IS FLICKERING	OUTSIDE FRONT LOBBY	6/5/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED FLUORESCENT AND COMPACT BALLAST	0.50
2014062775	MAINTENANCE ODW UTILITY WORK	DOORS 18 AND 21 - AWNING BASES NEED TREATED FOR RUST	DOORS 18 AND 21	6/5/2014		SANDED AND APPLIED BEDLINER TO BASES	2.00
2014062776	MAINTENANCE ODW UTILITY WORK	GATE 5 TURNSTILE BASE AND BOTTOM OF GATE NEEDS TREATED FOR RUST	GATE 5	6/5/2014		APPLIED RHINO-LINER TO BOTTOM OF TURNSTILE AND GATES FOR ADDED PROTECTION FROM RUST AND WATER	2.00
2014062777	MAINTENANCE ODW UTILITY WORK	LOBBY EXTERIOR COLUMNS NEED TREATED FOR RUST	LOBBY EXIT COLUMNS	6/5/2014		AFTER SANDING, APPLIED EXTERIOR GRADE MARINE OIL BASED PAINT.	2.00
2014062787	MAINTENANCE ODW CEILING TILE	AREA 7 CANDLING RM NEEDS DIRTY CEILING TILE REPLACED	AREA 7	6/5/2014	CEILING TILE-COV;CEILING TILE ;	CUT AND REPLACED TWO DIRTY CEILING TILES	0.75
2014062788	MAINTENANCE ODW CEILING TILE	N BREEZEWAY NEEDS VERTICAL TILE REPLACED	N BREEZEWAY	6/5/2014		REPLACED WITH A NEW ONE THAT I CUT TO FIT	0.75
2014062789	MAINTENANCE ODW CEILING TILE	B313 REPLACE STAINED TILES (UP FRONT AND TO THE LEFT)	B313	6/5/2014	CEILING TILE-COV;CEILING TILE ;	MIKE ROBINSON REPLACED 5 CEILING TILES: 3 AT SMOKE HEADS, 1 AT SPRINKLER DEVICE AND 1 AT TORNADO DEVICE. STEVE HUTSON AND JACKIE WACHTER REPLACED 19 CEILING TILES.	5.50
2014062791	MAINTENANCE ODW ELECTRICAL	POLE 5EE NO ELECTRICITY TO THE TELEVISION SET	POLE 5EE	6/5/2014		110 VOLTS IS AT TV OUTLET. TV DOES NOT WORK.	0.50
2014062810	MAINTENANCE ODW UTILITY WORK	POLE 4H POD 01-03-029 HAS A BLACK SUBSTANCE APPEARING ON DESK AND APPEARS TO BE COMING FROM AIR VENT	POLE 4H	6/5/2014		BLOCKED DIFFUSERS OVER CUBICLES AND TWO OTHERS WITH 5/8" INSULATION (CUBICLES 01-03-018 AND 01-03-003)	1.00
2014062813	MAINTENANCE ODW PLUMBING CLOG	MAG HALL R/R 5 STALL #2 STOPPED UP	MAG HALL R/R 5	6/5/2014		CLEARED CLOG WITH PLUNGER	0.50
2014062839	MAINTENANCE ODW KITCHEN EQUIP	CHILDCARE KITCHEN HOSE LEAKING	CHILDCARE KITCHEN	6/6/2014		REPLACED SPRAYER AND HOSE	1.50
2014062841	MAINTENANCE ODW UTILITY WORK	A PLANT COOLING TOWER OVERFLOW AT SE CORNER	A PLANT COOLING TOWER	6/6/2014		REMOVED SCALE	0.50
2014062854	MAINTENANCE ODW INT. LIGHTING	POLE 6S LIGHT (STARTING TO GO) OUT	POLE 6S	6/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014062855	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RTU #1 COMBUSTION AIR BLOWER RUNNING CONSTANTLY. INTERNAL SHORT IN BLOWER MOTOR. NEW BLOWER ASSEMBLY ORDERED.	CHILDCARE	6/6/2014		INSTALLED NEW COMBUSTION AIR BLOWER ASSEMBLY AND TESTED FOR PROPER OPERATION	4.00
2014062889	MAINTENANCE ODW INT. LIGHTING	AREA 9 SEVERAL LIGHTS OUT	AREA 9	6/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 12 LIGHT BULBS AND REPAIRED 2 SAGGING LIGHT LENSES	1.00
2014062931	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 123 SINK CLOGGED	CHILDCARE RM 123	6/9/2014		UNCLOGGED WITH SNAKE. (SAME TWO SINKS ON LEFT AS USUAL.)	0.50
2014062971	MAINTENANCE ODW PLUMBING	W'S R/R B211 TOILET #6 WILL NOT FLUSH	W'S R/R B211	6/10/2014	AA BATTERIES-COV;AA BATTERIES ;	REPLACED BATTERIES	0.50
2014062979	MAINTENANCE ODW PLUMBING CLOG	MH 5 TOILET #2 TOILET CLOGGED	MH 5	6/10/2014		UNCLOGGED WITH PLUNGER	0.50
2014063010	MAINTENANCE ODW INT. LIGHTING	HALL OUTSIDE A303 LIGHT OUT	HALL OUTSIDE A303	6/11/2014		REPLACED LAMPS	0.50
2014063011	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 COMMODE #2 IS CLOGGED	W'S R/R A5	6/11/2014		PLUNGED COMMODE	0.50
2014063013	MAINTENANCE ODW INT. LIGHTING	MAG HALL OUTSIDE 5 LIGHTS OUT	MAG HALL OUTSIDE 5	6/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014063014	MAINTENANCE ODW UTILITY WORK	RM 33 LIGHT SWITCH BROKEN	RM 33	6/11/2014		REPLACED FOURTH SWITCH ON THE LEFT (3-WAY SWITCH)	2.00
2014063018	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 BY FIRE DOOR DRYWALL IS WET	CHILDCARE RM 130	6/11/2014		6-10-14 CHECKED WALL. CUT ACCESS HOLES IN WALL. FOUND THAT TRAP PRIMER WAS LEAKING. 6-11-14 REMOVED TRAP PRIMER, CAPPED SUPPLY LINE AND PRIMED LINES. INSTALLED TEMPORARY PATCHES ON DRYWALL.	7.00
2014063033	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 5G EMPLOYEES REPORTING A SMELL OF RAW SEWAGE	POLE 5G	6/11/2014		ONLY ODOR DETECTED WAS CUSTODIAL CLEANING PRODUCT. SAME COMPLAINT OCCURRED ABOUT FOUR MONTHS AGO AT SAME LOCATION.	0.50
2014063080	MAINTENANCE ODW INT. LIGHTING	GLACE FROM CEILING LIGHTS OBSCURING COMPUTER SCREEN. REMOVE A COUPLE OF BULBS.	POLE 5FF	6/12/2014		REMOVED TWO MIDDLE LAMPS AND DISCARDED CARDBOARD.	0.50
2014063081	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B211 TOILET SEAT IS ON THE FLOOR	W'S R/R B211	6/12/2014		RE MOUNTED SEAT, TIGHTENED NUTS.	0.50
2014063161	MAINTENANCE ODW INT. LIGHTING	RM 806 LIGHTS OUT	RM 806	6/13/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014063162	MAINTENANCE ODW INT. LIGHTING	HALLWAY IN FRONT OF RM 804 LIGHTS OUT	HALLWAY IN FRONT OF RM 804	6/13/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014063163	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 COMMODE #2 CLOGGED	W'S R/R A5	6/13/2014		SNAKED OUT COMMODE WITH TOILET AUGER AND CHECKED COMMODE SEVERAL TIMES WITH TOILET PAPER. FLUSHES GOOD.	0.50

2014063164	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 5P ELECTRICAL OUTLET DOES NOT WORK	POLE 5P	6/13/2014		RESET BREAKER ON POLE 4P (E26-066-04 #17)	1.00
2014063165	MAINTENANCE ODW INT. LIGHTING	RM B317 (SECURED RM) NEAR POLE 2GG CEILING LIGHT NEEDS REPLACED	RM B317	6/13/2014		PROBLEM COULD NOT BE REPEATED DURING SERVICE. CHECKED ALL COMPONENTS FOR PROPER OPERATION. OK. REPLACED IGNITION CONTROL MODULE AS ALL OTHER COMPONENTS CHECK OUT. TESTED OVEN OPERATION AFTER CONTROL REPLACEMENT. OK.	2.00
2014063181	MAINTENANCE ODW BLDG/EQUIP. REP	COURTYARD CAFE MAIN BURNER IN OVEN WILL NOT STAY ON.	COURTYARD CAFE	6/13/2014		PROBLEM COULD NOT BE REPEATED DURING SERVICE. CHECKED ALL COMPONENTS FOR PROPER OPERATION. OK. REPLACED IGNITION CONTROL MODULE AS ALL OTHER COMPONENTS CHECK OUT. TESTED OVEN OPERATION AFTER CONTROL REPLACEMENT. OK.	2.00
2014063216	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 HANDICAP COMMODE IS CLOGGED	M'S R/R A810	6/16/2014		PLUNGED COMMODE	0.50
2014063217	MAINTENANCE ODW PLUMBING	M'S R/R A1005 URINAL #1 NOT FLUSHING PROPERLY	M'S R/R A1005	6/16/2014		ADJUSTED WATER TO FLUSH MORE WATER (STRONGER FLUSH)	0.50
2014063218	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE KITCHEN BETWEEN RMS 103 AND 107 FRONT OF DRAWER IS COMING OFF	CHILDCARE	6/16/2014		REPAIRED DRAWER	0.50
2014063220	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE COURTYARD HAS RUSTY NAILS PROTRUDING FROM CONCRETE RETAINING WALL	CHILDCARE COURTYARD	6/16/2014		REMOVED RUSTY NAILS	0.50
2014063222	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE WINDOW FACING PLAYGROUND NEEDS SCREEN INSTALLED	CHILDCARE	6/16/2014		INSTALLED SCREEN	0.50
2014063223	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 126 HAS BURNED OUT BULBS	CHILDCARE RM 126	6/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014063225	MAINTENANCE ODW BLDG/EQUIP. REP	LOADING DOCK MAN DOOR NEEDS HOLE PATCHED ON WALL	LOADING DOCK	6/16/2014		PATCHED HOLE	0.50
2014063227	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 TWO FLOOR TILES HAVE POPPED UP	CHILDCARE RM 128	6/16/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	CLEANED AND PREPPED TWO NEW TILES, GLUED THEM, LET THEM SIT AND INSTALLED.	1.00
2014063336	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS BURNED OUT	AREA 7	6/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 9 LIGHT BULBS ANAD VACUUMED 3 LIGHT FIXTURES	1.00
2014063337	MAINTENANCE ODW INDOOR AIR QUAL	CHILDCARE RM 123 DETECTING AN ODOR	CHILDCARE RM 123	6/18/2014		CHECKED HALL AND ROOMS TO 123 AND NO ODOR DETECTED	0.50
2014063338	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE - KITCHEN DRAWER FRONT NEEDS TIGHTENED	CHILDCARE	6/18/2014		RETIGHTENED DRAWER HANDLE SCREWS	0.50
2014063367	MAINTENANCE ODW DOOR	AREA 7 THERE IS A PROBLEM WITH THE SWINGING DOOR	AREA 7	6/19/2014		RESET DOOR. IT IS WORKING PROPERLY.	0.50
2014063369	MAINTENANCE ODW UTILITY WORK	POLE 10-O DROP CEILING PANEL WITH SPEAKER IS NOT SECURE	POLE 10-O	6/19/2014		TIGHTENED SCREWS IN SPEAKER	0.50
2014063374	MAINTENANCE ODW CEILING TILE	RM 33 HAS A STAINED CEILING TILE	RM 33	6/19/2014		CUT AND REINSTALLED CEILING TILE. HAD TO VACUUM CEILING TILE BEFORE IT COULD BE REMOVED BECAUSE OF DEBRIS.	1.00
2014063375	MAINTENANCE ODW BLDG/EQUIP. REP	M'S R/R A700I OUTSIDE DOOR BUTTON IS LOOSE AND FALLING OFF OF WALL	M'S R/R A700I	6/19/2014		TIGHTENED DOOR BUTTON WITH ALLEN SCREWS	0.50
2014063376	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHT FIXTURE NOT WORKING	AREA 5	6/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST, 4 LAMPS AND REWIRED FIXTURE	1.25
2014063377	MAINTENANCE ODW DOOR	RM 903 SLIDING DOOR WILL NOT OPEN	RM 903	6/19/2014		OPENED DOOR MANUALLY, THEN RESET SWITCH. IT WAS IN THE WRONG POSITION.	0.50
2014063380	MAINTENANCE ODW UTILITY WORK	A601 WATER IS DRIPPING FROM CEILING	A601	6/19/2014		FOUND BELLY LEAK UNDER 11-6-5 AHU AT SOUTH WALL. GOT 2 ABSORBANT SOCKS FROM TAX 4 AND PLACED BETWEEN WALL AND UNDER AHU'S SOUTH SIDE UNDER EXTERIOR FAN DUCT WORK.	1.00
2014063387	MAINTENANCE ODW UTILITY WORK	CANDLING RM NEEDS THE WALL EXHAUST FAN COVERED	CANDLING RM	6/19/2014		REMOVED FAN AND INSTALLED PANEL OVER HOLE	1.50
2014063414	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT IN VARIOUS FIXTURES	AREA 3	6/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014063476	MAINTENANCE ODW INT. LIGHTING	GLARE FROM CEILING LIGHT OBSCURING COMPUTER SCREEN. NEEDS AN ADDITIONAL BULB RELOCATED.	POLE 5FF	6/20/2014		REMOVED LAMP. ONE LEFT IN FIXTURE.	0.50
2014063502	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 35 COMMODE IS CLOGGED	M'S R/R 35	6/23/2014		PLUNGED THE COMMODE	0.50
2014063504	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHT FIXTURE AND BALLAST IS OUT	AREA 10	6/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2014063506	MAINTENANCE ODW INT. LIGHTING	AREA 1 HAS LIGHTS OUT	AREA 1	6/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014063507	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	6/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014063508	MAINTENANCE ODW UTILITY WORK	RM 300A OVERHEAD VENT HAS A BLACK SUBSTANCE COMING FROM IT	RM 300A	6/23/2014		INSERTED PIE MEDIA FILTER IN DIFFUSER	1.00
2014063511	MAINTENANCE ODW BLDG/EQUIP. REP	TERRY'S CAFETERIA OVEN WILL NOT STAY LIT. KEEPS TRYING TO RE-LIGHT.	TERRY'S CAFETERIA	6/23/2014		FOUND MAIN GAS VALVE SOLENOID COIL FAULTY, EXCESSIVE RESISTANCE. REPLACED MAIN GAS VALVE AND SOLENOID. TESTED FOR LEAKS (NONE FOUND) AND TESTED OVEN FOR PROPER OPERATION. OK.	2.00
2014063534	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET CLOGGED	M'S R/R A1005	6/24/2014		REMOVED LARGE AMOUNT OF TOILET PAPER AND PAPER TOWELS. TOILET FUNCTIONING NORMALLY.	0.50
2014063535	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R B211 HANDICAP BUTTON NOT WORKING	W'S R/R B211	6/24/2014		OPERATED EXTERIOR AND INTERIOR BUTTONS. BOTH FUNCTIONING NORMALLY.	0.50
2014063536	MAINTENANCE ODW PLUMBING CLOG	A305 SLOP SINK DRAIN IS CLOGGED	A305	6/24/2014		UNCLOGGED WITH PLUNGER AND FLUSHED.	0.50
2014063607	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT SOUTH OF POLE 4H	AREA 3	6/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014063608	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT SOUTH OF POLE 5O	AREA 4	6/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014063609	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	6/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 20 LIGHT BULBS AND VACUUMED FIVE LIGHT LENSES	1.25
2014063652	MAINTENANCE ODW INT. LIGHTING	MAG HALL OUTSIDE RM 41 LIGHTS OUT	MAG HALL OUTSIDE RM 41	6/26/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014063661	MAINTENANCE ODW INT. LIGHTING	SE OF POLE 4M REPLACE BROKEN 2X4 LIGHT LENS	SE OF POLE 4M	6/26/2014		REPLACED LENS (1) 2'X4' CLEAR PLASTIC. CUT TO FIT.	0.50
2014063662	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RTU-1 SUPPLY FAN NOT RUNNING.	CHILDCARE	6/26/2014		FOUND LOW SUPPLY VOLTAGE TO SUPPLY FAN RELAY. BAD OUTPUT ON RTRM BOARD. REPLACED RTRM BOARD AND CHECKED UNIT. OPERATION OK.	4.00
2014063689	MAINTENANCE ODW PLUMBING	W'S R/R A306 SINK #3'S FAUCET CONSTANTLY RUNNING	W'S R/R A306	6/27/2014	C BATTERIES-COV;C BATTERIES ;; SOLENOID REBUILT-COV;REBUILT SOLENOID ;	REPLACED BATTERIES. REPLACED SOLENOID VALVE.	1.00
2014063690	MAINTENANCE ODW INT. LIGHTING	AREA 13 BALLAST IS BAD	AREA 13	6/27/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW	1.00
2014063691	MAINTENANCE ODW INT. LIGHTING	AREA 12 BALLAST IS BAD	AREA 12	6/27/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW	1.00

2014063693	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 TOILET NEXT TO HANDICAP STALL IS STOPPED UP	W'S R/R A5	6/27/2014		ALL TOILETS CLEAR UPON ARRIVAL. CHECKED ALL TOILETS FOR PROPER OPERATION, ALL OK. CHECKED MEN'S ROOM 4 AS WELL, ALL OK.	0.50
2014063734	MAINTENANCE ODW BLDG/EQUIP. REP	AIR COMPRESSOR FOR TWO SCAMPS MACHINES ARE FILING UP WITH WATER TO THE AIR HOSES	SCAMPS	6/27/2014		RAN AIR THROUGH LINE FOR FIVE MINUTES. ABSOLUTELY NO WATER/MOISTURE FOUND IN LINE. MACHINES ARE OK TO RUN.	0.50
2014063787	MAINTENANCE ODW TEMPERATURE HOT	POLE 8G IN R/C ARE TOO WARM	POLE 8G	6/30/2014		TEMP IN SPACE IS 72.8 DEG F. THIS IS WITHIN CONTRACT REQUIREMENTS - NO CHANGE MADE.	0.50
2014063789	MAINTENANCE ODW INT. LIGHTING	MSU LIGHTS OUT	MSU	6/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014063790	MAINTENANCE ODW INT. LIGHTING	AREA 8 "CAGE" SEVERAL LIGHTS OUT	AREA 8	6/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS	0.75
2014063795	MAINTENANCE ODW BLDG/EQUIP. REP	RM 700J CONDENSER FAN CARDBOARD SHROUD HITTING FAN BLADE	RM 700J	6/30/2014		ADJUSTED CARDBOARD SHROUD TO ALLOW FAN BLADE CLEARANCE	1.00
2014063797	MAINTENANCE ODW UTILITY WORK	VALVE OUTSIDE OF COMPUTER ROOM NEEDS CORROSION REMOVED AND PAINTED RED	COMPUTER RM	6/30/2014		CLEANED, PREPPED AND PAINTED SPRINKLER VALVE. 7-15-14: CLEANED LEAKAGE BUILD UP SINCE ORIGINAL PAINT JOB. REMOVED TAPE FROM HANDLE AND TOUCHED UP PAINT JOB.	2.50
2014063798	MAINTENANCE ODW BLDG/EQUIP. REP	SCAMPS - WATER IS COMING OUT OF THE AIR LINE.	SCAMPS	6/30/2014		LEFT-HAND AIR DRYER FAULTY. REPLACED WITH NEW JOHNSON CONTROLS A-4412-2 AIR DRYER. TESTED OPERATION. OK.	6.00
2014063806	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 #4 TOILET SEAT IS ON THE FLOOR	W'S R/R B211	6/30/2014		REMOUNTED SEAT. TOILET PULLED LOOSE.	0.50
2014063807	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 TOILET IS STOPPED UP	W'S R/R B211	6/30/2014		UNCLOGGED WITH PLUNGER	0.50
2014072736	MAINTENANCE ODW INT. LIGHTING	AREA 4W LAMPS SOUTH OF POLE 4M	AREA 4W	7/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014072737	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT NEAR POLE 4E	AREA 3	7/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014072746	MAINTENANCE ODW INT. LIGHTING	AREA 4 SW LAMPS OUT IN FIXTURES S OF POLE 4N	AREA 4 SW	7/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS.	1.00
2014072747	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 128 MIDDLE SINK ON LEFT IS CLOGGED	CHILDCARE RM 128	7/2/2014		PLUNGED THE SINK	0.50
2014072840	MAINTENANCE ODW PLUMBING CLOG	MAG HALL'S R/R A34 HANDICAP STALL STOPPED UP	MAG HALL W'S R/R A34	7/2/2014		CLEARED CLOGGED COMMODE	1.00
2014072921	MAINTENANCE ODW UTILITY WORK	RM 902G NEEDS EGG CRATE PLACED AWAY FROM THE SUPPLY DIFFUSER	RM 902G	7/3/2014		INSTALLED EGG CRATE IN CEILING IN FAR LEFT CORNER AWAY FROM DIFFUSER	0.50
2014072922	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 123 TEACHER SINK CLOGGED	CHILDCARE RM 123	7/3/2014		UNCLOGGED WITH PLUNGER	0.50
2014072923	MAINTENANCE ODW INT. LIGHTING	AREA 4 SE OF POLE 4N HAS A CRACKED LENS	AREA 4	7/3/2014		REPLACED LENS COVER	0.50
2014072944	MAINTENANCE ODW PLUMBING	M'S R/R A810 A TOILET CONTINUES TO RUN	M'S R/R A810	7/7/2014		ALL TOILETS WORKING PROPERLY	0.50
2014072947	MAINTENANCE ODW PLUMBING	W'S R/R A600 TOILET RUNNING	W'S R/R A600	7/7/2014		ALL TOILETS WORKING PROPERLY	0.50
2014072963	MAINTENANCE ODW INT. LIGHTING	AREA 4 BROKEN LENS COVER S OF POLE 4M	AREA 4	7/7/2014		REPLACED LENS	0.50
2014072964	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 OVERHEAD LIGHTS OUT	W'S R/R A1003	7/7/2014		REPLACED FOUR LIGHT BULBS	0.50
2014072965	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHT OUT OVER NE RAMP GOING TO AREA 10	AREA 10	7/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014072966	MAINTENANCE ODW UTILITY WORK	AREA 11 PNEUMATIC DIAPHRAGM FOR AHU 5-11 IS RUPTURED AND LEAKING AIR	AREA 11	7/7/2014	DIAPHRAGM-COV;DIAPHRAGM ;	REPLACED RUPTURED DIAPHRAGM AND VACUUMED	1.00
2014072967	MAINTENANCE ODW INT. LIGHTING	AREA 12 POLE 7FF LIGHT FIXTURE NOT WORKING	AREA 12	7/7/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR LAMPS. OK.	1.50
2014072969	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 130 LIGHTS OUT	CHILDCARE RM 130	7/7/2014	LIGHT BULB-COV;LIGHT BULB ;	REPLACED 2 BULBS	0.50
2014072972	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 TWO FLOOR TILES MISSING	CHILDCARE RM 128	7/7/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REPLACED TWO BROKEN FLOOR TILES	0.50
2014073024	MAINTENANCE ODW PLUMBING	CHILDCARE TOILET BETWEEN RMS 126 AND 128 IS LEAKING	CHILDCARE	7/8/2014		REPLACED HANDLE SEAL AND GASKET	0.50
2014073033	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE PLAYGROUND SCREW IS MISSING ON THE RAILING OF THE LARGE CLIMBER AS YOU GO UP THE STEPS	CHILDCARE PLAYGROUND	7/8/2014		SCREW WAS MISSING DUE TO THE HOLE BEING STRIPPED. INSTALLED A DOWELL ROD AND NEW SCREW.	1.00
2014073049	MAINTENANCE ODW PLUMBING	M'S R/R A4 URINAL OVERFLOWING	M'S R/R A4	7/8/2014		CLEARED CLOG IN URINAL. OK.	0.50
2014073050	MAINTENANCE ODW DOOR	AREA 1 MAIN GLASS DOOR	AREA 1 RM 603	7/8/2014		DOOR NOT CLOSING DUE TO TRIM THAT HAS BEEN BENT. STRAIGHTENED TRIM AND REATTACHED. OK.	0.50
2014073073	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	7/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED SIX LIGHT BULBS AND ONE LIGHT BALLAST. VACUUMED TWO LIGHT FIXTURES.	1.25
2014073074	MAINTENANCE ODW INT. LIGHTING	RM 118 HALLWAY LIGHTS OUT	RM 118	7/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073111	MAINTENANCE ODW PLUMBING	HEALTH UNIT HAS A LEAKY FAUCET	HEALTH UNIT	7/9/2014	O-RINGS-COV;O-RINGS ;	REPLACED "O" RING. OK.	1.00
2014073150	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE - BURNING SMELL COMING FROM DRYER	CHILDCARE	7/10/2014		STARTED DRYER. SMELLED BURNING SMELL. BROUGHT BACK TO SHOP TO INSPECT. CLEANED AND CHECKD DRYER. REMOVED LINT. OK. CLEANED DRYER VENT STACK AND RESET DYER INTO PLACE. RAN DRYER TO CHECK. OK.	9.00
2014073224	MAINTENANCE ODW PLUMBING	M'S R/R 700I SECOND URINAL NOT WORKING	M'S R/R 700I	7/10/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED BATTERIES BUT FLUSH HEAD STILL WOULDN'T WORK. REPLACED COMPLETE FLUSH HEAD ASSEMBLY.	0.50
2014073246	MAINTENANCE ODW INT. LIGHTING	B317 LIGHT FIXTURE NOT WORKING	B317	7/11/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST. OK.	1.00
2014073247	MAINTENANCE ODW INT. LIGHTING	DOOR 18 HALLWAY HAS LAMPS BURNED OUT	DOOR 18	7/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073260	MAINTENANCE ODW PAINTING	AREA 1 - DOORWAY 603. REMOVE BOARD CONTAINING BADGES AND PAINT ENTIRE WALL. RETURN BOARD TO JASON.	AREA 1	7/11/2014		REMOVED BADGE BOARD AND PAINTED ENTIRE WALL.	1.00
2014073292	MAINTENANCE ODW INT. LIGHTING	BADGE ROOM NEEDS ONE OF FOUR LIGHTS REMOVED	BADGE ROOM	7/14/2014		BADGE ROOM WANTED TO RELOCATE LUMINAIRE TO AN AERA WHERE IT WOULD NOT FIT. AFTER DISCUSSING ISSUE, WE MOVED CAMERA TO AN ALTERATE LOCATION. TESTED, AND PICTURES WERE OK.	0.75
2014073295	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 5K, POD O HAS AIR BLOWING DIRECTLY ON HER. PER JAY, PUT SOME FILTER MEDIA UP IN THE DIFFUSER.	POLE 5K, POD O	7/14/2014		CLOSED DIFFUSER	0.50
2014073311	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 LIGHT OUT	W'S R/R A1003	7/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LIGHT BULBS	0.50
2014073312	MAINTENANCE ODW INT. LIGHTING	AREA 1- 8J LIGHT NOT WORKING	AREA 1 - 8J	7/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.25
2014073313	MAINTENANCE ODW UTILITY WORK	NUMEROUS RESTROOMS NEED OLD TOILET PAPER DISPENSERS REMOVED AND REPLACED WITH NEW ONES LOCATED ON CART OUTSIDE OF JAY'S OFFICE	RESTROOMS	7/14/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REMOVED OLD DISPENSERS AND REPLACED WITH NEW	6.00
2014073332	MAINTENANCE ODW DOOR	B1 HANDICAP DOOR BETWEEN AREAS 12 AND 13 MAKING A LOUD, SQUEAKING NOISE	DOOR B1	7/15/2014		ADJUSTED AND LUBED HINGE. OK.	0.50
2014073379	MAINTENANCE ODW INT. LIGHTING	LIGHTS FLICKERING AT DATA CONVERSION FLOOR, 3 ROWS IN FROM POLE 5P	DATA CONVERSION FLOOR	7/15/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	TWO LAMPS LOOSE. TIGHTENED AND REPLACED ONE BURNED OUT LAMP.	0.50

2014073380	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A1003 STAINLESS SANITARY NAPKIN TRASH BIN NEEDS RELOCATED	W'S R/R A1003	7/15/2014		MOVED STAINLESS TRASH BIN 2 INCHES LEFT OF TOILET PAPER DISPENSER	0.50
2014073381	MAINTENANCE ODW CEILING TILE	AREA 7 HAS A CEILING TILE WITH WHAT LOOKS LIKE MOLD THE SIZE OF A BASEBALL ON THE LEFT AS YOU ENTER THE CANDLING ROOM	AREA 7	7/15/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED TWO CEILING TILES	0.50
2014073402	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #2 OR #3 CLOGGED. MARKED WITH A WET FLOOR SIGN.	W'S R/R A404	7/16/2014		STALL #2, FLUSHED TOILET 3 TIMES. WORKS OK.	0.50
2014073403	MAINTENANCE ODW BLDG/EQUIP. REP	RM 903 LIEBERT #46 FAN BELT SQUEAKING	RM 903	7/16/2014		CLEANED GREASE OFF FAN PULLIES	0.75
2014073404	MAINTENANCE ODW WATER FOUNTAIN	RM B201C DRINKING FOUNTAIN LEAKING WATER	RM B201C	7/16/2014		WATER WAS LEAKING OUT OF WATER FILTER. BELIEVE PRESSURE RELIEVE BUTTON WASN'T SEATED.	0.50
2014073405	MAINTENANCE ODW BLDG/EQUIP. REP	RM B302 STALL #5 TOILET SEAT BROKEN	RM B302	7/16/2014		REPLACED ONE BROKEN COMMODE HINGE	0.50
2014073435	MAINTENANCE ODW UTILITY WORK	HALLWAY BY CAFETERIA NEEDS METAL PIECE SANDED	HALLWAY BY CAFETERIA	7/16/2014		SANDED EXPOSED METAL PIECE	0.50
2014073468	MAINTENANCE ODW BLDG/EQUIP. REP	RM 603 HAS A BLACK STRIP STICKING UP FROM THE FLOOR	RM 603	7/17/2014		REPLACED BROKEN WSI BOX WITH A SOLID TILE	0.50
2014073473	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 8 DOCK LIFT NOT WORKING	AREA 8	7/17/2014		OPERATED LIFT. NO MALFUNCTION FOUND.	0.50
2014073474	MAINTENANCE ODW JINT. LIGHTING	AREA 4 LAMPS OUT NEAR POLE 5M	AREA 4	7/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073475	MAINTENANCE ODW JINT. LIGHTING	MAG HALL LAMPS OUT IN CENTER FIXTURE SOUTH WALL	MAG HALL 15	7/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073492	MAINTENANCE ODW JINT. LIGHTING	RM 603 LIGHT OUT ABOVE COMPUTER	RM 603	7/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LIGHT BALLAST AND THREE LIGHT BULBS	1.00
2014073496	MAINTENANCE ODW JINT. LIGHTING	SOUTH AHU B307 NEEDS BULBS IN FILTER SECTION	SOUTH AHU B307	7/18/2014	LIGHT BULB-COV;LIGHT BULB ;	REPLACED BURNED OUT BULBS. PUT 2 TABS IN SOUTH AND NORTH AHU CONDENSATE PANS.	0.50
2014073497	MAINTENANCE ODW JINT. LIGHTING	AREA 13-POLE 5EE LIGHT FIXTURE NOT WORKING	AREA 13-POLE 5EE	7/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS. OK.	1.50
2014073546	MAINTENANCE ODW JINT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	7/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED SEVEN LIGHT BULBS	0.50
2014073547	MAINTENANCE ODW JINT. LIGHTING	SHOP HALLWAY LIGHTS OUT	SHOP HALLWAY	7/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS AND CLEANED FIXTURE	0.50
2014073548	MAINTENANCE ODW JINT. LIGHTING	W'S R/R A600 LIGHTS OUT	W'S R/R A600	7/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014073549	MAINTENANCE ODW JINT. LIGHTING	M'S R/R A602 LIGHTS OUT	M'S R/R A602	7/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073550	MAINTENANCE ODW CEILING TILE	RM 604 STAINED CEILING TILES	RM 604	7/21/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILNG TILES	1.00
2014073551	MAINTENANCE ODW BLDG/EQUIP. REP	NEAR RM 1006 - THREE PIECES OF COVEBASE FELL OFF THE CORNER COLUMN	NEAR RM 1006	7/21/2014	COVEBASE-COV;COVEBASE ;	REPAIRED COVE BASE. (REPLACED ONE CORNER, REUSED ONE CORNER, CUT MIDDLE SECTION TO FIT.)	1.00
2014073562	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 STALL #4 CLOGGED	M'S R/R A1005	7/21/2014		UNCLOGGED WITH PLUNGER.	0.50
2014073593	MAINTENANCE ODW TEMPERATURE COLD	POLE 7FF AND 8JJ TOO COLD	POLE 7FF AND 8JJ	7/22/2014		RAISED SPACE TEMP SET POINT FROM 71 DEG. TO 73 DEG.	0.50
2014073594	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILETS 1, 2, 3 AND 4 CLOGGED	W'S R/R B211	7/22/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD ON #4. SNAKED AND PLUNGED TO CLEAR DRAINS.	4.25
2014073708	MAINTENANCE ODW JINT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	7/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 20 LIGHT BULBS AND VACUUMED FIVE LIGHT LENSES.	1.00
2014073709	MAINTENANCE ODW PLUMBING	SATELLITE CANTEEN - WATER ON FLOOR	SATELLITE CANTEEN	7/23/2014		SUPPLY LINE LEAKING ON FAUCET. UNHOOKED SUPPLY AND WASTE CONNECTIONS TO MOVE STAINLESS STEEL SINK IN ORDER TO ACCESS COMPRESSION FITTINGS ON FAUCET. TIGHTENED COMPRESSION FITTINGS. RESET SINK AND TIGHTENED ALL CONNECTIONS. LEAK CHECKED. OK. CLEARED CLOG IN HAND SINK ADJACENT TO STAINLESS SINK.	1.00
2014073735	MAINTENANCE ODW PLUMBING CLOG	SLOP SINK BY WASHER IS STOPPED UP	SLOP SINK	7/23/2014		COULD NOT FIND A CLOG. RAN WATER FOR 10 MINUTES, DRAINED FINE.	0.50
2014073736	MAINTENANCE ODW JINT. LIGHTING	HEALTH UNIT HAS A LIGHT OUT	HEALTH UNIT	7/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND TWO LIGHT BULBS	0.75
2014073737	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 HAS A TOILET THAT'S RUNNING	CHILDCARE RM 130	7/23/2014	DIAPHRAGM-COV;DIAPHRAGM ;	REBUILT MANUAL FLUSH VALVE.	0.50
2014073767	MAINTENANCE ODW LEAKS	CLOSET 601 CEILING IS LEAKING	CLOSET 601	7/24/2014		6-5 BELLY LEAK. CONDENSATE LINE CLOGGED. CLEARED LINE SO IT WOULD DRAIN.	0.75
2014073768	MAINTENANCE ODW PLUMBING	CHILDCARE RMS 126 AND 128 MIDDLE COMMODE LEAKING WATER THROUGH STOP VALVE	CHILDCARE RMS 126 AND 128	7/24/2014	STOP REPAIR KIT-COV;STOP REPAIR KIT ;	REBUILT STOP VALVE	0.50
2014073800	MAINTENANCE ODW PLUMBING	M'S R/R A810 TOILET OVERFLOWING	M'S R/R A810	7/24/2014		CLEARED CLOG WITH PLUNGER	0.50
2014073821	MAINTENANCE ODW JINT. LIGHTING	AREA 4 LAMPS OUT IN VARIOUS FIXTURES BETWEEN POLES 4M AND 4T	AREA 4	7/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014073822	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A4 COMMODE IS CLOGGED	M'S R/R A4	7/25/2014		PLUNGED THE COMMODE	0.50
2014073823	MAINTENANCE ODW PLUMBING	SECURITY'S RESTROOM FAUCET CAME OFF FROM SINK	SECURITY'S RESTROOM	7/25/2014		REATTACHED HANDLE WITH THE ALLEN SETSCREW	0.50
2014073824	MAINTENANCE ODW DOOR	MAG HALL DOOR A4 MAGNET IS NOT HOLDING DOOR	MAG HALL DOOR A4	7/25/2014		SHIMMED THE BACK OFF THE METAL PLATE SO THE MAGNET WILL CATCH IT. NOW OK.	0.50
2014073825	MAINTENANCE ODW BLDG/EQUIP. REP	A STRIP OF COVE BASE FELL FROM WALL AND IS LAYING ON THE FLOOR	HALLWAY 18 - POLE 7G	7/25/2014		REATTACHED TO THE WALL	0.50
2014073870	MAINTENANCE ODW JINT. LIGHTING	SCAMPS - LIGHTS OUT	SCAMPS	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHT BULBS	0.50
2014073872	MAINTENANCE ODW JINT. LIGHTING	RM 903 LIGHTS OUT	RM 903	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHT BULBS	0.50
2014073874	MAINTENANCE ODW JINT. LIGHTING	MSU - ONE LIGHT FIXTURE COMPLETELY BURNED OUT	MSU	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED ONE LIGHT BALLAST AND FOUR LIGHT BULBS	1.00
2014073876	MAINTENANCE ODW JINT. LIGHTING	RM 804 LIGHTS OUT	RM 804	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014073878	MAINTENANCE ODW BLDG/EQUIP. REP	HALLWAY 18 - POLE 7G COVEBASE CAME OFF	HALLWAY 18 - POLE 7G	7/28/2014		REPLACED	0.50
2014073880	MAINTENANCE ODW JINT. LIGHTING	CHILDCARE LIGHTS OUT IN RMS 130, 109, TEACHER'S LOUNGE, N HALLWAY, HALL POWDER RM	CHILDCARE	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 1 IN RM 130, 2 IN RM 109, 1 IN TEACHER'S LOUNGE, 1 IN NORTH HALLWAY AND 1 IN THE HALL POWDER ROOM	1.00
2014073881	MAINTENANCE ODW JINT. LIGHTING	RM 604 LIGHTS OUT	RM 604	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073883	MAINTENANCE ODW JINT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014073884	MAINTENANCE ODW BUILDING SIGNAGE	BETWEEN MDF AND B1 - SIGN NEEDS RELOCATED	BETWEEN MDF AND B1	7/28/2014		RELOCATED SIGN. PATCHED AND PAINTED WALL WHERE SIGN WAS.	2.00
2014073885	MAINTENANCE ODW JINT. LIGHTING	AREA 1 LAMP IN LIGHT FIXTURE NOT WORKING	AREA 1	7/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;; LIGHT SOCKET- COV;LIGHT SOCKET ;	REPLACED BALLAST AND A LIGHT SOCKET THAT WAS BROKEN ON FIXTURE THAT WAS FOR ANOTHER LAMP AND REWIRED IT.	1.50
2014073886	MAINTENANCE ODW GLASS	4TH ST - LOT H BROKEN BEER BOTTLE WAS THROWN OVER FENCE	4TH ST - LOT H	7/28/2014		SWEPT UP BROKEN GLASS	0.50

2014073887	MAINTENANCE ODW JINT. LIGHTING	W'S R/R A600 LIGHTS OUT	W'S R/R A600	7/28/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;	REPLACED LAMP	0.50
2014073889	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A600 SMOKEHEAD DAMAGED DUE TO WATER	W'S R/R A600	7/28/2014	SMOKE HEAD-COV;SMOKE HEAD ;	INSTALLED NEW SMOKEHEAD	0.50
2014073894	MAINTENANCE ODW TEMPERATURE HOT	POLE 6EE AND THE ENTIRE AREA IS COMPLAINING OF BEING TOO HOT	POLE 6EE	7/28/2014		STARTED NORTH AIR HANDLER	0.50
2014073912	MAINTENANCE ODW NOISE	RM 903 - HVAC UNITS 45, 46 AND 47 ARE VERY NOISY AND DISRUPTING EMPLOYEES	RM 903	7/28/2014		TURNED OFF UNIT PER JAY WITHROW	0.50
2014073956	MAINTENANCE ODW DOOR	B315 SLIDING DOOR WILL NOT LOCK SHUT	B315	7/29/2014		THE SWITCHES ON DOOR WERE IN THE WRONG POSITION. PUT SWITCHES WHERE THEY NEEDED TO BE. DOOR IS NOW WORKING PROPERLY.	0.50
2014073957	MAINTENANCE ODW CARPET	B314 - DOOR 2B CARPET SQUARES LOOSE AT TRANSITION STRIP	B314 - DOOR 2B	7/29/2014		GLUED CARPET SQUARES	1.00
2014073973	MAINTENANCE ODW TEMPERATURE COLD	TOO COLD AT 8F-8J	8F-8J	7/29/2014		RAISED SPACE SET POINT FROM 72 DEG TO 74 DEG. ACTUAL TEMP RANGED FROM 70.5 TO 72.	0.50
2014073993	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 SINKS 1 THROUGH 8 ARE CLOGGED	W'S R/R A306	7/29/2014		SNAKED MAIN LINE THROUGH "CROSS." ALL SINKS DRAINING.	1.00
2014073994	MAINTENANCE ODW PA SYSTEM	SKYLIGHT CAFE NEEDS PA CHECKED BECAUSE THEY WERE NOT ABLE TO HEAR THE TEST EVACUATION DRILL	SKYLIGHT CAFE	7/29/2014		AG & TD: ALL SPEAKERS WORKED FINE EXCEPT THE NORTH BREEZEWAY SPEAKER WHICH DIDN'T MAKE A SOUND. JM: SPEAKER WORKS. LINE IS DEAD. RAN NEW SPEAKER WIRE FROM SPEAKER IN MECHANICAL ROOM. TESTED OPERATION. OK.	2.00
2014074010	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A700H STALL #6 TOILET PAPER DISPENSER IS BROKEN	W'S R/R A700H	7/30/2014		REPLACED WITH A NEW DISPENSER	0.50
2014074011	MAINTENANCE ODW DOOR	603B - SECURITY ABLE TO PULL SLIDING DOORS OPEN	603B	7/30/2014		WIPED OFF SENSOR AND WORKED THE DOOR A FEW TIMES. UNABLE TO PULL DOORS OPEN.	0.50
2014074015	MAINTENANCE ODW JINT. LIGHTING	AREA 7 - 3 LIGHTS ABOVE TINGLE TABLE #49 NOT WORKING	AREA 7	7/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND THREE LIGHT BULBS. VACUUMED LIGHT FIXTURE.	1.00
2014074042	MAINTENANCE ODW TEMPERATURE HOT	HEALTH UNIT - TOO HOT	HEALTH UNIT	7/31/2014		SPACE TEMP 74.5 DEG. LOWERED TO 72 DEG.	0.50
2014074057	MAINTENANCE ODW JINT. LIGHTING	W'S R/R A811 LIGHTS OUT	W'S R/R A811	7/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014074059	MAINTENANCE ODW JINT. LIGHTING	RM 809 LIGHTS OUT IN STORAGE ROOM	RM 809	7/31/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014074072	MAINTENANCE ODW JINT. LIGHTING	CHILDCARE HALL RESTROOM LIGHTS OUT	CHILDCARE HALL RESTROOM	7/31/2014		COMPLETE	0.50
2014074073	MAINTENANCE ODW JINT. LIGHTING	CHILDCARE LIGHTS OUT IN HALL IN FRONT OF RM 123	CHILDCARE HALL RM 123	7/31/2014		COMPLETE	0.50
2014074074	MAINTENANCE ODW PAINTING	CHILDCARE RM 123 HAS AREAS OF RAISED PAINT BEHIND FRONT DOOR	CHILDCARE RM 123	7/31/2014		PATCHED WALL WHERE PAINT IS RAISED. SANDED PATCHES AND APPLIED TWO COATS OF PAINT.	1.50
2014074075	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE IN RM 128 TEACHER CABINET HAS A BROKEN HINGE	CHILDCARE RM 128	7/31/2014			0.00
2014074076	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE - HANDLE ON CABINET UNDER CHILDREN'S SINK IS LOOSE	CHILDCARE CHILDREN'S SINK	7/31/2014		SCREWS HAVE BEEN REPLACED. HANDLE IS IN GOOD WORKING CONDITION.	0.50
2014074077	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 CHILDREN'S SINK BY BACKDOOR SPIGOT IS LEAKING	CHILDCARE RM 130	7/31/2014		TIGHTENED LOOSE NUTS. EVERYTHING IS IN GOOD WORKING CONDITION.	0.50
2014074078	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 130 CABINET LOCK IS BROKEN (MARKED WITH BLUE TAPE) IN CUBBY AREA BY COURTYARD DOOR	CHILDCARE RM 130	7/31/2014		LOCK HAS BEEN TIGHTENED. IS IN GOOD WORKING CONDITION.	0.50
2014074079	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE BETWEEN RMS 109 AND 110 HAS A HOLE IN THE WALL	CHILDCARE BETWEEN RMS 109 AND 110	7/31/2014		PATCHED WALL. SANDED WALL AND PAINTED TWO COATS.	1.50
2014074080	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE KITCHEN HANDWASHING BASIN IS DETERIORATING IN BASIN AND AROUND DRAIN AREA	CHILDCARE KITCHEN	7/31/2014		JW: GROUTED THE BASIN AND DRAIN AREA. SC: USED HEAT GUN TO DRY GROUT. SILICONED AREA BETWEEN GASKET AND GROUT.	3.50
2014074081	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE OUTSIDE - SCREWS ON EASELS NEED TIGHTENED	CHILDCARE OUTSIDE	7/31/2014		TIGHTENED SCREWS THAT WERE LOOSE	0.50
2014074084	MAINTENANCE ODW BLDG/EQUIP. REP	8F VENT FLOOR TILE NEEDS MOVED AWAY FROM DESK (THERE ARE 2 RED MAIL TUBS MARKING SPOT)	8F	7/31/2014		COMPLETE. MOVED FLOOR TILE.	0.50
2014080001	MAINTENANCE ODW TEMPERATURE HOT	8P TOO HOT	8P	8/1/2014		CHECKED SPACE TEMP 72 DEG. LOWERED L-5 1 DEG. SPACE TEMP OK.	0.50
2014080002	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 - 8K STUFFY	AREA 1 - 8K	8/1/2014		TOOK READINGS IN AREA. A LITTLE WARM. CHANGED SET POINT TO BRING TEMP DOWN.	0.50
2014080003	MAINTENANCE ODW JINT. LIGHTING	COURTYARD STORE LIGHTS BURNED OUT	COURTYARD STORE	8/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014080604	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 STALL 14 STOPPED UP	W'S R/R B211 STALL 14	8/1/2014		CLEARED CLOGGED COMMODE #14	1.00
2014081841	MAINTENANCE ODW PLUMBING	W'S R/R A306 FIRST SINK - WATER COMING OUT TOO FORCEFUL	W'S R/R A306	8/4/2014		ADJUSTED WATER SUPPLY.	0.50
2014081851	MAINTENANCE ODW JINT. LIGHTING	POLE 5P LAMPS FLICKERING IN FIXTURE OVER WATER FOUNTAIN	POLE 5P	8/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	0.50
2014082530	MAINTENANCE ODW TEMPERATURE COLD	AREA 1 - 8K TOO COLD	AREA 1 - 8K	8/5/2014		TOOK THREE TEMPS OF AREA: 74.7, 74.8 AND 74.6. ALL WITHIN CONTRACT. NO ADJUSTMENTS.	0.50
2014082531	MAINTENANCE ODW CEILING TILE	AREA 6 - RM 603 NEEDS 6 TO 7 DIRTY CEILING TILES REPLACED AND CEILING GRID NEEDS CLEANED.	AREA 6 - RM 603	8/5/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED 7 CEILING TILES AND CLEANED GRID.	1.00
2014082557	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 10 BETWEEN POLES 5U AND 5V - BLACK SOOT IS COMING OUT OF THE VENT (REPLACE FILTER?)	POLE 5U AND 5V	8/6/2014		AREA 11, THE FIRST VENT SOUTH OF POLES 5U AND 5V. VACUUMED OUT VENT (DIFFUSER) AND REPLACED FILTER MEDIA.	0.75
2014082567	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #1 IS CLOGGED	M'S R/R B309	8/6/2014		PLUNGED THE COMMODE	0.50
2014082592	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE KITCHEN - FLOOR DRAIN COVER NEEDS REPLACED	CHILDCARE KITCHEN	8/6/2014		INSTALLED NEW DRAIN COVER	0.50
2014082593	MAINTENANCE ODW FLOOR TILE	CHILDCARE KITCHEN TILES AROUND FLOOR DRAIN NEED REPLACED	CHILDCARE KITCHEN	8/6/2014		OLD TILE HAS BEEN REMOVED AND REPLACED.	1.00
2014082594	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE PLAY AREA SHED NEEDS A HASP INSTALLED	CHILDCARE PLAY AREA	8/6/2014		ADDED A PIECE OF COMPOSITE BOARD TO DOOR AND INSTALLED HASP.	2.00
2014082595	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE BASKETBALL AREA - WHERE THE TURF MEETS THE CONCRETE ON LEFT SIDE, BOARD NEEDS REPLACED AND LOWERED (SEE DIAGRAM)	CHILDCARE BASKETBALL AREA	8/6/2014		ALL COMPLETE	1.00
2014082597	MAINTENANCE ODW CEILING TILE	NEAR DOOR B3 LIGHT FELL FROM CEILING, TEARING DOWN CEILING GRID AND BREAKING 2 CEILING TILES	DOOR B3	8/6/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILING GRID AND REPLACED CEILING TILE AND REHUNG LIGHT	1.50

2014082617	MAINTENANCE ODW TEMPERATURE HOT	MAG HALL - COMPLAINTS OF TEMPS BEING HIGHER THAN NORMAL. DID TURNING VANE GET BUMPED WHEN THE DUCT WAS BEING CLEANED? (SEE ATTACHED.)	MAG HALL	8/6/2014		(TD) 8/6/14: TOOK TEMP READINGS IN ROOMS: 3-77.1 DEG; 7-76.5 DEG; 18-75.2 DEG; 22-74.1 DEG. (JM) 8/7/14: FOUND INTERNAL BALANCING DAMPER FULLY CLOSED TO THE WEST-END DUCT RUN AT AIR HANDLER. OPENED DAMPER TO PROVIDE EQUAL AIR DELIVERY TO EAST AND WEST DUCT RUNS.	2.00
2014082632	MAINTENANCE ODW TEMPERATURE COLD	AREA 1 - 8J TOO COLD	AREA 1 - 8J	8/7/2014		SPACE TEMP 74 DEG. NO ACTION TAKE.	0.50
2014082636	MAINTENANCE ODW DOOR	#18 INTERIOR DOOR SOUTH IS SQUEAKING	#18 INTERIOR DOOR SOUTH	8/7/2014		LUBED ALL HINGES AND PIVOTS	0.50
2014082637	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	8/7/2014		REPLACED 12 LIGHT BULBS AND VACUUMED 3 LIGHT LENSES.	0.75
2014082648	MAINTENANCE ODW PLUMBING	W'S R/R A600 FAUCET LOOSE	W'S R/R A600	8/7/2014		TIGHTENED WING NUTS ON FAUCET AND REPLACED LEAKING SUPPLY LINE	1.00
2014082678	MAINTENANCE ODW PLUMBING	W'S R/R A600 STALL #14 TOILET WILL NOT FLUSH	W'S R/R A600 STALL #14	8/8/2014	DIAPHRAGM-COV;DIAPHRAGM ;	REPLACED DIAPHRAGM	0.50
2014082682	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 TOILET #3 CLOGGED	W'S R/R A306	8/8/2014		FLUSHED ALL TOILETS. NO CLOGS.	0.50
2014082683	MAINTENANCE ODW PLUMBING	W'S R/R B211 TOILET #4 SEAT LOOSE	W'S R/R B211	8/8/2014		TIGHTENED MOUNTING NUTS	0.50
2014082684	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 5 CORNER SECTION OF COVEBASE CAME OFF NE CORNER OF POLE 6P	AREA 5	8/8/2014		REAPPLIED COVEBASE TO POLE USING BLACK SILICONE	0.50
2014082685	MAINTENANCE ODW INT. LIGHTING	AREA 14 POLE ICC LIGHT FIXTURE NOT WORKING	AREA 14 POLE 1CC	8/8/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.25
2014082686	MAINTENANCE ODW INT. LIGHTING	B317 LIGHT FIXTURE NOT WORKING	B317	8/8/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.25
2014082705	MAINTENANCE ODW TEMPERATURE COLD	SOUTHWEST SECTION OF MAG HALL TOO COLD	SW SECTION OF MAG HALL	8/8/2014		RAISED SET-POINT TO 76 DEG.	0.50
2014082709	MAINTENANCE ODW INT. LIGHTING	AERA 14 BROKEN LIGHT LENS	AREA 14	8/8/2014		REPLACED LIGHT WITH ONE IN STOCK	2.00
2014082710	MAINTENANCE ODW INT. LIGHTING	SHOP HALLWAY LIGHTS OUT	SHOP HALLWAY	8/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED THREE BULBS	0.50
2014082732	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R 600 WOMENS RESTROOM SEMELS BAD.	W'S R/R 600	8/11/2014		FLUSHED ALL FLOOR DRAINS	0.50
2014082733	MAINTENANCE ODW GATE/FENCE	GATE 5 TOWARDS B304 LOOSE FENCE POST	GATE 5 TOWARDS B304	8/11/2014			1.00
2014082736	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	8/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	AREA 11 REPLACED 22 BULBS	2.00
2014082749	MAINTENANCE ODW INT. LIGHTING	POLE 4G CEILING LIGHT IS OUT	POLE 4G	8/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 1 BALLAST AND 4 T-8 BULBS	0.50
2014082750	MAINTENANCE ODW WATER FOUNTAIN	WATER FOUNTAIN OUTSIDE OF MDF HAS BLUE WATER	OUTSIDE MDF	8/11/2014	BODY ASSEMBLY-CO;BODY ASSEMBLY ;; STOP VALVE-COV;STOP VALVE ;	REPLACED STOP VALVE AND BODY	1.00
2014082770	MAINTENANCE ODW PLUMBING	W'SR/R STALL 14 A600 TOILET CONTINUOUS FLUSHING	W'SR/R A600	8/12/2014	AA BATTERIES-COV;AA BATTERIES ;; DIAPHRAGM-COV;DIAPHRAGM ;	REPLACED BATTERIES AND FLUSH HEAD DIAPHRAGM	0.50
2014082774	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHT NOT WORKING		8/12/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	AREA 6 LIGHT NOT WORKING REPLACED 1 BALLAST	1.00
2014082841	MAINTENANCE ODW DOOR	CHILDCARE RM 109 LOWER DOOR IS DRAGGING WHEN OPENING/CLOSING.	CHILDCARE RM 109	8/13/2014		REPLACED HINGES ON LOWER DOOR	1.50
2014082842	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE - TOP HINGE ON THE RESTROOM GATE NEEDS REPAIRED	CHILDCARE	8/13/2014		INSTALLED SPACERS AND NEW SCREWS, GATE IS WORKING PROPERLY	1.00
2014082844	MAINTENANCE ODW BLDG/EQUIP. REP	GATEHOUSE 6 (Dog House) OUTSIDE GROUNDS - K9 EXTERIOR GUARD POST STEPS NEED REPLACED. LATCH LOCK ON K9 POST DOOR NEEDS REPAIRED/REPLACED.	GATEHOUSE 6 (Dog House) OUTSIDE GROUNDS	8/13/2014		TIGHTENED MOUNTING HARDWARE ON LATCH. LUBRICATED ROLLERS. BUILT NEW STEP FOR DOGHOUSE.	4.00
2014082851	MAINTENANCE ODW PLUMBING	W'S R/R A5 SINK IS RUNNING	W'S R/R A5	8/13/2014		SNAKED SINK. OK. TIGHTENED SEAT BOLTS ON TOILETS.	1.00
2014082855	MAINTENANCE ODW TEMPERATURE HOT	MAG HALL - RM 18 TOO HOT	MAG HALL - RM 18	8/13/2014		MEASURED 73.5 DEG F IN OFFICE. WITHIN CONTRAACT REQUIREMENTS. NO CHANGE MADE.	0.50
2014082856	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 SECOND STALL CLOGGED	M'S R/R A1005	8/13/2014		FLUSHED ALL TOILETS AND URINALS. ALL WORKED PROPERLY.	0.50
2014082864	MAINTENANCE ODW INT. LIGHTING	W'S R/R A5 LIGHTS OUT	W'S R/R A5	8/13/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BURNED OUT BULBS	0.75
2014082866	MAINTENANCE ODW EXT. LIGHTING	EXECUTIVE PARKING LOT - LIGHT NEEDS FIXED BETWEEN PARKING SPACES 28 AND 29	EXECUTIVE PARKING LOT	8/13/2014	LIGHT BALLAST HPS-COV;HPS LIGHT BALLAST ;; LIGHT BULB HID 750W-COV;HALIDE LIGHT 750 WATT ;	REPLACED BALLAST AND LAMP	2.00
2014082895	MAINTENANCE ODW PLUMBING	W'S R/R A306 WATER TOO HOT AT FIRST SINK	W'S R/R A306	8/14/2014		ADJUSTED HOT AND COLD WATER VALVES. OK.	0.50
2014082896	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 126 ADULT SINK IS CLOGGED	CHILDCARE RM 126	8/14/2014		UNCLOGGED SINK	1.00
2014082897	MAINTENANCE ODW DOOR	CHILDCARE RM 126 - DOOR LATCH HOLDING SPLIT DOORS NEEDS REPAIRED AND DOOR HINGES NEED OILED	CHILDCARE RM 126	8/14/2014		TIGHTEN LATCH AND LUB HINGES	1.00
2014082911	MAINTENANCE ODW TEMPERATURE HOT	RM 307C TOO HOT	RM 307C	8/14/2014		CHECKED TEMP. 72.3F AND 61.8%RH NO ACTION TAKEN	0.50
2014082939	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 3 NEAR POLE 4JA - BLACK SUBSTANCE COMING OUT OF AIR VENTS	AREA 3 NEAR POLE 4J	8/14/2014	24X24X1 FILTER-COV;24X24X1 FILTER ;	INSTALLED FILTER MEDIA IN VENT	1.00
2014082941	MAINTENANCE ODW INT. LIGHTING	RM 405 DEPT MANAGER OFFICE NEEDS LIGHT REPLACED	RM 405	8/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 5 LAMPS	0.50
2014082942	MAINTENANCE ODW TEMPERATURE HOT	RMS 17, 18 AND 19 TOO HOT	RMS 17, 18, 19	8/14/2014		FOUND DAMPER HAD MOVED IN MAIN DISCHARGE DUCT. SECURED DAMPER IN POSITION. AIRFLOW IS NOW AUDIBLE IN ROMS 17, 18 AND 19.	1.00
2014082943	MAINTENANCE ODW DOOR	MAG HALL EAST SIDE FRONT ENTRANCE DOOR WILL NOT LOCK. PANIC BAR WILL NOT RAISE TO LOCK DOOR.	MAG HALL	8/14/2014		TD: LUBED TOP AND BOTTOM LATCHES. TOP WORKS BUT CANNOT GET BOTTOM PIN TO DROP. MM: UNLOCKED PANIC BAR. OK.	1.50
2014082944	MAINTENANCE ODW BLDG/EQUIP. REP	303, BLDG A, AREA 3 UNIT 2-3 NOT RUNNING.	303, BLDG A, AREA 3	8/14/2014		REPLACED BAD CONTACTOR COIL. FOUND OPEN RELAY CIRCUIT ON NOTIFIER CMX-2 MODULE. BURNT CONTACTS. REPLACED CMX-2 WITH A NEW UNIT FROM STOCK. CHECKED MOTOR STARTER FOR PROPER OPERATION. OK.	3.00
2014082950	MAINTENANCE ODW BLDG/EQUIP. REP	SATELLITE CANTEEN ICE MACHINE DRAIN CLOG	SATELLITE CANTEEN	8/14/2014		UNCLOG DRAIN	0.50
2014083062	MAINTENANCE ODW DOOR	CHILDCARE RM 110 LOWER HAFT OF DOOR RUBBING FLOOR		8/18/2014		TIGHTEN AND ADJUSTED HINDGES STOP RUBBING FLOOR	0.50
2014083069	MAINTENANCE ODW INT. LIGHTING	SCAMPS LITE OUT		8/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 4 BULBS	0.50
2014083070	MAINTENANCE ODW INT. LIGHTING	RM 903 LITE FIXTURE COMPLETELY OUT		8/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND 4 BLUBS	1.00
2014083085	MAINTENANCE ODW DOOR	RM 903 DOOR NOT CLOSING		8/19/2014		DOOR WAS OFF TRACK PUT DOR BACK ON TRACK DOOR FUNCTION NORMAL	0.50
2014083088	MAINTENANCE ODW GATE/FENCE	GATE 3 RIGHT SIDE WOULD NOT CLOSE ALL THE WAY		8/19/2014		GATE WAS TRIPED RESET, GATE IS CLOSING	0.50
2014083095	MAINTENANCE ODW PAINTING	DOOR 17 BOTTOM OF DOOR FRAME AND PIPE PENETRATIONS RUSTED		8/19/2014	PAINT-COV;PAINT ;; PAINT-COV;PAINT ;	TOUCHED UP DOORS AND PAINTED PIPE PENETRATIONS	2.00
2014083096	MAINTENANCE ODW PAINTING	A VAULT DOOR AND STAIR TREADS NEEDS PAINTED		8/19/2014	PAINT-COV;PAINT ;	PAINTED STAIR TREADS AND TOUCHED UP DOORS	2.00

2014083097	MAINTENANCE ODW PAINTING	A AND B BUILDING EXTERIOR ELECTRIC BOXES NEED PAINTED		8/19/2014	PAINT-COV;PAINT ;	PAINTED EXXTERIOR ELECTRIC BOXES	2.00
2014083098	MAINTENANCE ODW PAINTING	B101 PIPES ON THE OUT SIDE WALL NEED PAINTED		8/19/2014	PAINT-COV;PAINT ;	SCRAPED AND PAINTED PIPES	2.50
2014083111	MAINTENANCE ODW BLDG/EQUIP. REP	MENS R/R 1005 ENTRY DOOR IS SLAMMING SHUT		8/19/2014		REMOVED DOOR CLOSER TO REPAIR REPLACED WORM GEAR WITH NEW ONE	4.00
2014083147	MAINTENANCE ODW PLUMBING CLOG	WRR 34 HANDICAP COMMODE OVERFLOWING		8/20/2014		UNCLOGGED AND CHECKED COMMODE	0.50
2014083152	MAINTENANCE ODW BLDG/EQUIP. REP	WRR 34 STALL 1 TOILET PAPER DISPENSER FALLING OFF WALL		8/20/2014		REMOUNTED DISPENSER TO WALL	0.50
2014083154	MAINTENANCE ODW LEAKS	COURT YARD DOORS RAIN BLEW IN ON FLOOR		8/20/2014		MOPPED UP WATER AND PUT OUT WET FLOOR SIGNS	0.50
2014083204	MAINTENANCE ODW DOOR	MRR B309 HANDICAP BUTTON NOT WORKING		8/21/2014	MICRO SWITCH-COV;MICRO SWITCH ;	REPLACED MICRO SWITCH IN THE PUSH BUTTON	1.00
2014083235	MAINTENANCE ODW INT. LIGHTING	AREA 9 REPLACED BURNED OUT LAMPS		8/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHTEEN LITE BULBS AND VACUUMED FOUR LITE LENS	1.00
2014083236	MAINTENANCE ODW INT. LIGHTING	MAG. HALL HALLWAY WEST END REPLACE BURNED OUT LAMPS		8/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED SX LAMPS IN LITE FIXTURES IN FRONT OF ROOMS 42,43 AND 50	0.50
2014083237	MAINTENANCE ODW DOOR	ROOM 903 AUTO DOOR WILLNOT CLOSE		8/22/2014		DOOR WAS KNOCK OFF TRACK PUT LEFT SIDE BACK ON TRACK WORKING FINE NOTE:DOOR WAS KNOCK TRACK ON 08/18/14 SEE W/O #2014083085	0.50
2014083240	MAINTENANCE ODW PLUMBING CLOG	WRR B211 TOILET NOT FLUSHING		8/22/2014		CLEARED CLOG WITH PLUNGER STALL 5	0.50
2014083268	MAINTENANCE ODW CEILING TILE	RM 30 CEILING TILE IS HANGING	RM 30	8/25/2014		RESET CEILING TILE	0.50
2014083271	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 TOILET CLOGGED	W'S R/R A34	8/25/2014		CLEARED CLOG WITH PLUNGER	0.50
2014083272	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	8/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 32 LIGHT BULBS AND VACUUMED 7 LIGHT LENSES	2.00
2014083273	MAINTENANCE ODW RESTROOM FIXTURE	RM B22 STALL #7 TOILET PAPER DISPENSER BROKEN	RM B22 #7	8/25/2014		REPLACED TISSUE DISPENSER	0.50
2014083274	MAINTENANCE ODW INT. LIGHTING	M'S R/R A602 LIGHTS OUT	M'S R/R A602	8/25/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;	REPLACED LAMPS	0.50
2014083275	MAINTENANCE ODW INT. LIGHTING	LOCKER RM LIGHTS BURNED OUT	LOCKER RM	8/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014083276	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 LIGHTS OUT	W'S R/R A1003	8/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED SIX LIGHT BULBS	0.50
2014083277	MAINTENANCE ODW CEILING TILE	W'S R/R A1003 STAINED CEILING TILE	W'S R/R A1003	8/25/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILING TILE	0.50
2014083278	MAINTENANCE ODW INT. LIGHTING	M'S R/R A1005 LIGHTS OUT	M'S R/R A1005	8/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHTH BULBS	0.50
2014083279	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST LIGHTS OUT SOUTH OF POLE 4H	AREA 3 EAST	8/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014083280	MAINTENANCE ODW INT. LIGHTING	POLE 10M LIGHT FIXTURE HANGING OUT OF CEILING	POLE 10M	8/25/2014		WIRED FIXTURE BACK IN	0.50
2014083300	MAINTENANCE ODW INT. LIGHTING	POLE 6S - HAS TO FLIP THE LIGHT SWITCH SEVERAL TIMES TO GET LIGHTS TO TURN ON	POLE 6S	8/25/2014		CANCELED. THIS IS A WORK STATION LIGHT.	0.00
2014083309	MAINTENANCE ODW DOOR	COMPACTOR AREA DOOR OUTSIDE BY CANINE SHACK - DOOR IS HARD TO OPEN/CLOSE (PROBLEM WITH FRAME?).	COMPACTOR AREA DOOR	8/25/2014		ADJUSTED DOOR FRAME TO ALLOW DOOR TO OPEN AND CLOSE MORE EASILY. DOOR AND FRAME ARE IN BAD SHAPE. BADLY RUSTED. REPLACEMENT IS RECOMMENDED.	2.00
2014083329	MAINTENANCE ODW BLDG/EQUIP. REP	JANITORIAL CLOSET 601 CEILING IS LEAKING	RM 601	8/26/2014		INSTALLED ADDITIONAL PAN. ADDED 1-1/2' OFPIPE TO DRAIN PAN AND VACUUMED FLOOR IN MECH. ROOM. INSTALLED NEW DETECTOR. SYSTEM BACK TO NORMAL.	3.00
2014083336	MAINTENANCE ODW BLDG/EQUIP. REP	EXTRACTING - BLACK PLATES COVERING ELECTRICAL OUTLETS ARE MISSING AND NEED REPLACED	EXTRACTING	8/26/2014		REPLACED EIGHT BLACK OUTLET COVERS AND REALIGNED THE COVERS ON MANY MORE.	1.00
2014083352	MAINTENANCE ODW BLDG/EQUIP. REP	RM 307C - CHECK TO SEE IF EGG CRATE RETURNS CAN BE INSTALLED.	RM 307C	8/26/2014		WALLS GO ALL THE WAY TO CEILING. NO OPEN AREA FOR RETURN AIR. THERE IS AN EXISTIG 2' X 2' EGG CRATE IN CENTER OF ROOM.	0.50
2014083353	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST LAMPS OUT IN FIXTURE EAST OF POLE 4K	AREA 3 EAST	8/26/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS.	0.50
2014083367	MAINTENANCE ODW TEMPERATURE HOT	RM 48 TOO HOT	RM 48	8/27/2014		LOWERED SETPOINT ON UNIT 12-3 TO 70 DEG.	0.50
2014083425	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 STALL #13 CLOGGED	W'S R/R A1003	8/28/2014		CLEARED CLOG WITH PLUNGER	0.50
2014083431	MAINTENANCE ODW BLDG/EQUIP. REP	RM 404 LEFT-HAND CABINET DOOR UNDER SINK #1 IS OFF ITS HINGE	RM 404	8/28/2014		REHUNG DOOR	0.50
2014083432	MAINTENANCE ODW BLDG/EQUIP. REP	RM 1002 AHU 11-9 NEEDS NEW ROLL FILTER INSTALLED	RM 1002	8/28/2014		REPLACED ROLL FILTER, VACUUMED FILTER COMPARTMENT, LUBED ALL BEARINGS, ROLLERS AND SPRING HINGES	1.25
2014083448	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A600 HANDICAP PUSH BUTTON ON EXTERIOR IS NOT WORKING	W'S R/R A600	8/29/2014		WIRE HAD COME OFF TERMINAL TO SWITCH. RE-CRIMPED CONNECTION AND CHECKED FOR PROPER OPERATION. OK.	0.50
2014083449	MAINTENANCE ODW INT. LIGHTING	EXTRACTING - OVERHEAD LIGHTS OUT	EXTRACTING	8/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 12 LIGHT BULBS. REPLACED 1 LIGHT BALLAST. VACUUMED 4 LIGHT FIXTURES.	1.50
2014083450	MAINTENANCE ODW BLDG/EQUIP. REP	RM 700J AIR - COMPRESSOR ROOM HAS A BUILD UP OF DUST ON HORIZONTAL SURFACES	RM 700J	8/29/2014		VACUUMED SURFACES IN ROOM	0.75
2014083479	MAINTENANCE ODW BLDG/EQUIP. REP	MEZZ RM 1003 - EXHAUST FAN 44-10 IS TRIPPING. NEEDS CHECKED.	MEZ RM 1003	8/29/2014		REPAIRED CONNECTION ON SWITCH (AT FAN). CHECKED BELT, OK. TRIED FAN FOUR TIMES ON ROOF AND IT WORKED FINE. DRAWS 12.62 RA FOR ABOUT FIVE SECONDS THEN DROPS DOWN TO 3.4 RA. NAMEPLATE 5.0 RA.	1.25
2014083481	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 STALL #4 SEAT IS BROKEN	W'S R/R B211	8/29/2014		REALIGNED TOILET SEAT AND THEN TIGHTENED DOWN BOLTS.	0.50
2014083482	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 SINKS #2 AND #3 ARE CLOGGED	W'S R/R B211	8/29/2014		SNAKED DRAINS FROM ACCESS PANEL IN RM B201.	1.25
2014090686	MAINTENANCE ODW INT. LIGHTING	AREA 5 LAMPS OUT	AREA 5	9/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014090687	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LIGHT OUT AT NE CORNER OF POLE 4L	AREA 4 WEST	9/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	0.50
2014090688	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 126 FIRE DOOR IS CHIRPING	TREASURE HOUSE RM 126	9/2/2014		REPLACED 9V BATTERY	0.50
2014090689	MAINTENANCE ODW WATER FOUNTAIN	CHILDCARE EXTERIOR WATER FOUNTAIN CLOGGED	TREASURE HOUSE	9/2/2014		CLEANED SAND OUT OF DRAIN AGAIN	0.50
2014090691	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE LOCK ON SHED ON THE WEST SIDE OF PLAYGROUND IS DRAGGING	TREASURE HOUSE SHED	9/2/2014		ADJUSTED DOOR SO THAT IT WOULD NOT RUB. OK.	1.00
2014091693	MAINTENANCE ODW BLDG/EQUIP. REP	RM 126 EXTERIOR WALL (NEAR CLEAN OUT DRAIN). WALL APPEARS TO BE DAMP, SOFT AND PAINT IS PEELING.	RM 126	9/2/2014		REMOVED CAP (BRASS) FROM CLEAN OUT, REINSTATELD USING TEFLON TAPE. INSTALLED COVER PLATE BOLT ALSO USING TEFLON TAPE. FOUND A COLONY OF WHAT LOOKED LIKE TERMITES.	1.00

2014092495	MAINTENANCE ODW INT. LIGHTING	POLE 5DD LIGHTS IN CEILING ARE FLICKERING	POLE 5DD	9/3/2014		STOOD IN THE AREA AND LOOKED AND NO LIGHTS WERE FLICKERING ANYWHERE.	0.50
2014092497	MAINTENANCE ODW BLDG/EQUIP. REP	RM 49 IS MISSING A DOOR KNOB	RM 49	9/3/2014		HOLE FOR DOOR HAD TO BE ENLARGED BASED ON THE NEW HANDLE. THE BEAUTY RING HAD TO BE GROUND DOWN. WORKS PROPERLY.	1.00
2014092498	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A404 INSIDE HANDICAP BUTTON NOT WORKING	W'S A404	9/3/2014		REPLACED BATTERY. OK.	0.50
2014092500	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A1003 STALL #23 TOILET SEAT BROKEN	W'S R/R A1003	9/3/2014	TOILET SEAT-COV;TOILET SEAT ;	REPLACED TOILET SEAT	0.50
2014092562	MAINTENANCE ODW PLUMBING	M'S R/R A308 URINAL OVERFLOWING AND FAUCET RUNNING TOO LONG	M'S R/R A308	9/3/2014		ADJUSTED WATER PRESSURE AT SINK. URINAL IS OK.	0.50
2014092676	MAINTENANCE ODW INT. LIGHTING	CENTRAL PLANT BY SINK - LIGHTS OUT	CENTRAL PLANT	9/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.50
2014092700	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #3 CLOGGED	M'S R/R B309	9/4/2014		UNCLOGGED WITH PLUNGER	0.50
2014092701	MAINTENANCE ODW INT. LIGHTING	AREA 13 LAMPS BURNED OUT	AREA 13	9/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	1.00
2014092702	MAINTENANCE ODW INT. LIGHTING	B315 SEVERAL LAMPS OUT	B315	9/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014092736	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT NEAR POLE 5E	AREA 3	9/5/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014092737	MAINTENANCE ODW INT. LIGHTING	AREA 3W LAMPS OUT IN FIXTURE OUTSIDE RM 310	AREA 3W	9/5/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014092738	MAINTENANCE ODW DOOR	AREA 8 AUTO DOOR LEADING TO LOADING DOCK IS MAKING A SQUEAKING NOISE	AREA 8	9/5/2014		LUBED ROLLERS ON BOTH DOOR BOTTOMS	0.50
2014092752	MAINTENANCE ODW TEMPERATURE HOT	POLE 8O - TOO HOT	POLE 8O	9/8/2014		SPACE TEMP 73.6. NO ACTION TAKEN.	0.50
2014092757	MAINTENANCE ODW DOOR	AREA 1 - DOOR 1 WILL NOT OPERATE	AREA 1 - DOOR 1	9/8/2014		DOOR WAS INSPECTED BY SOUTHERN OHIO DOOR CONTROLS. SECURITY SYSTEM WAS JUMPED-OUT AND DOOR OPERATED. PROBLEM IS IN ACCESS CONTROL CIRCUIT/SYSTEM. SECURITY WAS NOTIFIED THAT THEY NEED SOMEONE TO SERVICE ACCESS CONTROLS FOR THIS DOOR.	1.00
2014092762	MAINTENANCE ODW DOOR	DOOR 18 EXTERIOR SOUTH - DOOR MAKES NOISE WHEN OPENING	DOOR 18	9/8/2014		RAISED DOOR SLIGHTLY BECAUSE IT WAS DRAGGING AT BOTTOM NEAR HINGE SIDE. LUBED ALL HINGES AND PIVOTS.	0.50
2014092764	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	9/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 12 LIGHT BULBS AND ONE LIGHT BALLAST. VACUUMED THREE LIGHT LENSES.	1.50
2014092765	MAINTENANCE ODW BLDG/EQUIP. REP	HANDRAILS AT B1 AND B2 - CLEAN OUT GAPS AROUND THE BASE	B1 AND B2	9/8/2014		CLEANED OUT GAPS. SOAKED UP WATER AND APPLIED NP-1 CAULK AROUND THE BASES TO SEAL AGAINST THE WEATHER.	1.00
2014092766	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 126 LIGHTS OUT	CHILDCARE RM 126	9/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULB	0.50
2014092767	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	9/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	1.00
2014092768	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT EAST OF POLE 5E	AREA 3	9/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	RELACED BALLAST AND LAMPS	0.50
2014092769	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT SOUTH OF POLE 5S	AREA 4	9/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014092840	MAINTENANCE ODW INT. LIGHTING	THIRD ROW OVER FROM POLE 5R - CEILING LIGHT IS FLICKERING	POLE 5R	9/9/2014		LAMP WAS LOOSE. TIGHTENED INTO SOCKET.	0.50
2014092853	MAINTENANCE ODW DOOR	AERA 4 SOUTH DOOR 402 SLAMS SHUT	AREA 4 SOUTH	9/9/2014		ADJUSTED CLOSER	0.50
2014092858	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 STALL #2 IS STOPPED UP	W'S R/R A309	9/9/2014		FLUSHED TOILET	0.50
2014092863	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 HANDICAP STALL CLOGGED	M'S R/R A1005	9/9/2014		PLUNGED TOILET TO CLEAR CLOG	0.50
2014092888	MAINTENANCE ODW INT. LIGHTING	AREA 4 NEAR POLE 5M LIGHTS OUT	AREA 4	9/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014092890	MAINTENANCE ODW INT. LIGHTING	M'S R/R B309 LIGHTS OUT	M'S R/R B309	9/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014092892	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 SINK #4 ON RIGHT IS CLOGGED	W'S R/R A404	9/10/2014		SNAKED DRAIN FROM BELOW SINK AND CLEANED OUT EXCESSIVE CRUD FROM TRAP	1.50
2014092894	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 6 AHU 11-6 NEEDS CLEANED	AREA 6	9/10/2014		CLEANED, INSPECTED AND OPERATED. WORKING PROPERLY.	0.75
2014092898	MAINTENANCE ODW PLUMBING	M'S R/R A308 WATER WILL NOT COME ON AT SINK	M'S R/R A308	9/10/2014		WATER WORKING UPON ARRIVAL. FAUCET WORKED. TURNED ON MULTIPLE TIMES.	0.50
2014092906	MAINTENANCE ODW INT. LIGHTING	CENTRAL PLANT - LIGHTS NEEDED (9/16/14) FOR UNION LABOR REC DAY	CENTRAL PLANT	9/10/2014		HUNG LIGHTS IN BREAK AREA AT CENTRAL PLANT	1.00
2014093072	MAINTENANCE ODW INT. LIGHTING	B100 LIGHT LENS IS FALLING	B100	9/11/2014		RESET LIGHT LENS. OK.	0.50
2014093083	MAINTENANCE ODW PLUMBING	M'S R/R A308 FAUCET TO SINK IS RUNNING SLOWLY AND IS MAKING A NOISE	M'S R/R A308	9/11/2014		REPLACED BATTERIES. OK.	0.50
2014093086	MAINTENANCE ODW BUILDING SIGNAGE	GATE 1 STOP SIGN IS FADED AND NEEDS REPLACED	GATE 1	9/11/2014		REMOVED AND REPLACED "STOP" SIGN. TIGHTENED BOLTS ON "NO LEFT TURN" SIGN.	1.00
2014093109	MAINTENANCE ODW INT. LIGHTING	B308 LIGHTS OUT	B308	9/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 T8 BULBS	0.50
2014093138	MAINTENANCE ODW TEMPERATURE HOT	POLE 8O TO WARM	POLE 8O	9/12/2014		CHILLER WAS OFF UNTIL 10 AM. SPACE TEMP NOW NORMAL AT 74 DEG F.	0.50
2014093174	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R RM A1003 #19 TOILET SEAT IS BROKEN	W'S R/R RM A1003	9/15/2014	TOILET SEAT-COV;TOILET SEAT ;	REPLACED WITH NEW TOILET SEAT	0.50
2014093175	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 5 CORNERS AT POLE 7Q ARE GETTING BANGED UP FROM CARTS	AREA 5 POLE 7Q	9/15/2014	CORNER GUARDS-COV;CORNER GUARDS ;	PUT TWO CORNER PROTECTORS ON	1.00
2014093177	MAINTENANCE ODW BLDG/EQUIP. REP	MAG HALL HAS A BLOWER MOTOR THAT IS SQUEAKING AND GRINDING	MAG HALL	9/15/2014		CHECKED CEILING BETWEEN FAN COIL 1 AND 2. NO NOISE.	0.50
2014093193	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 STALL #2 TOILET SEAT IS BROKEN	W'S R/R B211	9/15/2014		SEAT IN STALL #3 ON THE FLOOR. REINSTALLED. DOUBLED UP ON MOUNTINGNUTS TO MAKE SEAT MORE SECURE.	0.50
2014093224	MAINTENANCE ODW TEMPERATURE COLD	POLE 8JJ TOO COLD	POLE 8JJ	9/16/2014		SPACE TEMP 72.8 AND IS WITHIN CONTRACT LIMITS. NO ACTION TAKEN.	0.50
2014093231	MAINTENANCE ODW DOOR	AREA 6 SECOND SET OF GLASS DOORS WILL NOT CLOSE	AREA 6	9/16/2014		ADJUSTED DOOR ROLLERS. DOOR OPERATES PROPERLY NOW.	1.00
2014093241	MAINTENANCE ODW BLDG/EQUIP. REP	W'S A1003 TOILET SEAT OFF (DID NOT INDICATE WHICH STALL)	W'S A1003	9/16/2014		CHECKED ALL TOILETS. ALL SEATS OK.	0.50
2014093249	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHT OUT SOUTH OF POLE 4P	AREA 4	9/16/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093263	MAINTENANCE ODW INT. LIGHTING	CHILDCARE KITCHEN LIGHTS OUT	CHILDCARE KITCHEN	9/17/2014		REPLACED LAMPS IN KITCHENETTE RM 103	0.50
2014093264	MAINTENANCE ODW PLUMBING	CHILDCARE KITCHEN FAUCET IS LEAKING. (PIPES VIBRATE AND MAKE LOUD NOISES.)	CHILDCARE KITCHEN	9/17/2014		TD: REPLACED STOP VALVE TO HOT WATER SUPPLY. FAUCET NEEDS NEW STEM. WATER OFF UNDER SINK. MM: REPLACED BOTH STEMS.	2.50
2014093265	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE CLIMBER ON LARGE PLAYGROUND, TOWARD THE DOUBLE SLIDE. THE RIGHT SIDE OF THE BRIDGE DECK HAS DROOPED.	CHILDCARE CLIMBER	9/17/2014		JACKED UP THE DECK. DRILLED NEW HOLES AND SCREWED BACK TOGETHER ON BOTH SIDES. REPLACED 4X4 RAILS WITH NEW.	7.00
2014093266	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 103 TRANSITION STRIP FROM TILE TO CARPET HAS BEEN KICKED LOOSE	CHILDCARE RM 103	9/17/2014		CAULKED STRIP AND ADHERED TO TILE	0.50

2014093269	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 3B - CORD RUNNING FROM HARD DRIVE TO ELECTRICAL OUTLET IS TAPED DOWN AND NEEDS A CORD COVER	POLE 3B	9/17/2014		MOVED WSR BOX UNDER DESK.	1.00
2014093280	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 25 CEILING LIGHTS OUT AND LIGHT LENS FELL	MAG HALL RM 25	9/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS AND REINSTALLED LIGHT LENS	0.50
2014093303	MAINTENANCE ODW INDOOR AIR QUAL	POLE 8F - NOTICING A GAS ODOR	POLE 8F	9/17/2014		AIR HANDLERS DRAWING FROM OUTSIDE AIR BRINGING IN PARKING LOT SEALING SMELL. TURNED ON CHILLER AND SHUT AIR INTAKE DAMPERS.	0.50
2014093322	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS OUT	MAG HALL 23	9/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093323	MAINTENANCE ODW INT. LIGHTING	RM 811 LIGHTS OUT	RM 811	9/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014093324	MAINTENANCE ODW INT. LIGHTING	RM 809 LIGHTS OUT	RM 809	9/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014093325	MAINTENANCE ODW INT. LIGHTING	MSU LIGHTS OUT	MSU	9/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED 12 LIGHT BULBS AND ONE LIGHT BALLAST	1.25
2014093326	MAINTENANCE ODW PAINTING	GARAGE - METAL STAIR TREADS ARE RUSTY	GARAGE	9/18/2014		SANDED, PRIMED AND PAINTED STAIR TREADS	1.50
2014093330	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 TOILET OVERFLOWING	M'S R/R A810	9/18/2014		CLEARED CLOG WITH PLUNGER	0.50
2014093378	MAINTENANCE ODW CEILING TILE	MAG HALL, RM 24 CEILING TILE IS HANGING DOWN	MAG HALL, RM 24	9/19/2014		REALIGNED CEILING TILE BACK IN TRACK OVER FRONT DOOR	0.50
2014093385	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	9/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS AND VACUUMED LIGHT LENSES	0.75
2014093386	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	9/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 12 LIGHT BUYLBS AND VACUUMED THREE LIGHT LENSES	0.75
2014093387	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 126 FIRE EXIT DOOR ALARM IS CHIRPING	CHILDCARE RM 126	9/19/2014	9V BATTERY-COV;9V BATTERY ;	REPLACED BATTERY IN DOOR ALARM	0.50
2014093411	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 2 RECEPTACLE NOT WORKING	AREA 2	9/19/2014		CHECKED RECEPTACLES AROUND COURTYARD AND REMOVED BROKEN GROUND PRONG. ALL RECEPTACLES HAD POWER.	1.00
2014093435	MAINTENANCE ODW INT. LIGHTING	AREA 7 OVERHEAD LIGHTS OUT	AREA 7	9/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FIVE LIGHT BULBS AND VACUUMED ONE LIGHT FIXTURE	0.75
2014093436	MAINTENANCE ODW INT. LIGHTING	AREA 8 LIGHTS OUT IN CAGE AREA	AREA 8	9/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.75
2014093437	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE TEACHER'S COMMODE IS LEAKING	CHILDCARE	9/22/2014		FOUND COMMODE STOP VALVE LEAKING. REPLACED WITH NEW.	1.00
2014093438	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHT FIXTURES NOT WORKING	AREA 1	9/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	2.50
2014093439	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	9/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHTS	1.00
2014093440	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 LOOSE TILE	CHILDCARE RM 128	9/22/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	CLEANED AREA AND APPLIED NEW TILE	1.00
2014093443	MAINTENANCE ODW DOOR	RM 604 SLIDING DOOR WILL NOT CLOSE ALL THE WAY	RM 604	9/22/2014		CYCLED DOOR FIVE TIMES. DOOR IS OPERATING FINE.	0.50
2014093449	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #3 STOPPED UP	W'S R/R A404	9/22/2014		CLEARED CLOG WITH PLUNGER	0.50
2014093460	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B309 FLUSHHEAD NOT WORKING	W'S R/R B309	9/22/2014	AA BATTERIES-COV;AA BATTERIES ;	M'S R/R B309 REPLACED FOUR "AA" BATTERIES	0.50
2014093466	MAINTENANCE ODW DOOR	JANITOR CLOSET 601 - UNABLE TO OPEN DOOR	JANITOR CLOSET 601	9/22/2014		9-22-14 (TD) KEY WON'T TURN IN LOCK. TAPED LATCH ASSEMBLY DOWN. 9-23-14 (JM) CLEANED AND LUBRICATED LOCK WITH GRAPHITE. LOCK NOW OPERATES PROPERLY.	1.50
2014093470	MAINTENANCE ODW PLUMBING	SHOP BATHROOM URINAL IS RUNNING SLOWLY	SHOP BATHROOM	9/23/2014	P TRAP/ FORNCO-COV;P TRAP/ FORNCO ;; TAIL PIECE-COV;TAIL PIECE ;	REPLACED P-TRAP AND TAILPIECE.	1.50
2014093471	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT SE OF POLE 5E	AREA 3	9/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093472	MAINTENANCE ODW INT. LIGHTING	AREA 4W LIGHTS OUT NEAR POLE 5M	AREA 4W	9/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS SOUTH SIDE OF POLE	0.50
2014093473	MAINTENANCE ODW BLDG/EQUIP. REP	A203 COMPLAINT OF GNATS IN FLOOR DRAINS IN SECURITY BREAK ROOM	A203	9/23/2014		PUT ZEP ORANGE BUOY IN FLOOR DRAINS	0.50
2014093589	MAINTENANCE ODW INT. LIGHTING	MAG HALL LAMPS OUT IN HALL OUTSIDE MH 40 AND MH 46	MAG HALL	9/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093600	MAINTENANCE ODW TEMPERATURE COLD	AREA 12 TOO COLD	AREA 12	9/25/2014		RAISED SETPOINT FROM 71 DEG TO 74 DEG	0.50
2014093601	MAINTENANCE ODW PLUMBING	W'S R/R A600 #14 WEAK FLUSH	W'S R/R A600	9/25/2014	DIAPHRAGM-COV;DIAPHRAGM ;	REPLACED DIAPHRAGM IN FLUSH HEAD	0.50
2014093602	MAINTENANCE ODW INT. LIGHTING	RM A307 LIGHTS OUT	RM A307	9/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093603	MAINTENANCE ODW KITCHEN EQUIP	KITCHEN STOVE WILL NOT HEAT UP	KITCHEN	9/25/2014		BOTTOM PANEL WAS KNOCKED LOOSE. REFASTENED PANEL. WORKS FINE.	0.50
2014093604	MAINTENANCE ODW INT. LIGHTING	W'S R/R A600 LIGHT COVER FELL OUT OVER A STALL	W'S R/R A600	9/25/2014		PUT COVER BACK IN PLACE.	0.50
2014093606	MAINTENANCE ODW INT. LIGHTING	UNION OFFICE BLDG A OVERHEAD LIGHTS OUT	UNION OFFICE BLDG A	9/25/2014		REPLACED BALLAST. OK.	0.50
2014093621	MAINTENANCE ODW DOOR	MAG HALL RM'S 49, 50, 51 FOLDING WALLS - LOCK WILL NOT OPEN OR CLOSE ON SOME DOORS	MAG HALL RM'S 49, 50, 51	9/25/2014		9-25-14: WALLS BETWEEN 50 AND 51 OK. CLOSED AND SECURED. SECOND PANEL BETWEEN 49 AND 50 HAS JAMMED LOCK (TD). 9-26-14: HAVE PANEL OFF WALL. NEED A PART (AG). 10-21-14: REPLACED PANEL LOCKING MECHANISM AND REASSEMBLED PANEL. (JM AND MM)	8.00
2014093648	MAINTENANCE ODW INT. LIGHTING	POLE 6S LIGHT OUT	POLE 6S	9/25/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	0.50
2014093670	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 TOILETS 2 AND 3 CLOGGED	W'S R/R A404	9/26/2014		REMOVED SANITARY SEAT COVERS FROM BOTH TOILETS. FLUSHED AND PLUNGED. OK.	0.50
2014093672	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 6 COMP RM TROUBLE SMOKEHEAD LOOSE	AREA 6	9/26/2014		RECONNECTED HEAD AND REPLACED THE HEAD THAT WAS DISABLED. ALL NORMAL.	0.50
2014093676	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP STALL IS CLOGGED	W'S R/R A34	9/26/2014		CLEARED CLOG WITH PLUNGER	0.50
2014093709	MAINTENANCE ODW PLUMBING	811 - WAREHOUSE, WATER RUNNING UNDER DOOR	811	9/29/2014		SINK WENT LOOSE. CLEANED AND SILICONED BACK IN PLACE.	0.75
2014093719	MAINTENANCE ODW DOOR	DOOR 18 EXTERIOR SOUTH MAKES NOISE WHEN OPENING	DOOR 18	9/29/2014		RAISED DOOR AT MIDDLE HINGE. IT WAS DRAGGING AT BOTTOM.	0.50
2014093720	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHTS OUT	AREA 1	9/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093721	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	9/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014093722	MAINTENANCE ODW TEMPERATURE HOT	POLES 8E AND 8J TOO WARM	POLES 8E AND 8J	9/29/2014		TEMP IN AREA IS 72.4 TO 73.4 DEGREES F, WHICH IS WITHIN CONTRACT REQUIREMENTS. NO CHANGES MADE.	0.50
2014093724	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 BOTH SINKS CLOGGED	M'S R/R A810	9/29/2014		REMOVED MIRROR. SNAKED DRAIN. OK.	1.00

2014093729	MAINTENANCE ODW BLDG/EQUIP. REP	GATEHOUSE 3 - REPAIR BOTH PEDESTALS FOR KEY CARD READER/PUSH BUTTON PROVIDING ACCESS TO TURNSTILES. THEY ARE LOOSE.	GATEHOUSE 3	9/29/2014		TD: SECURED PEDESTAL. ANCHOR BOLT BROKE OFF. JM AND MM: REMOVED EXISTING BOLT, ROTATED BASE 45 DEG, SET NEW ANCHORS AND REMOUNTED PEDESTAL.	3.50
2014093767	MAINTENANCE ODW TEMPERATURE HOT	RM 48 TOO HOT	RM 48	9/30/2014		UNIT 12-3 ON 100% OUTDOOR AIR, BUT SPACE TEMP STILL CLIMBING. TURNED ON "A" CHILLED WATER PLANT AT 1000.	0.50
2014093791	MAINTENANCE ODW INT. LIGHTING	AREA 14 TWO LIGHT FIXTURES ARE OUT. BALLASTS ARE BAD.	AREA 14	9/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW. REPLACED FOUR LAMPS.	2.00
2014093792	MAINTENANCE ODW INT. LIGHTING	AREA 13 LIGHT FIXTURE OUT. BALLAST IS BAD.	AREA 13	9/30/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW	1.00
2014100688	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 TWO TOILETS ARE CLOGGED	W'S R/R A34	10/1/2014		FLUSHED ALL TOILETS. ALL WERE OPERATIONAL.	0.50
2014101824	MAINTENANCE ODW BLDG/EQUIP. REP	RM 1002 AHU 11-9 SUPPLY FAN BELTS ARE SLAPPING	RM 1002	10/1/2014		ADJUSTED BELT TENSION TIGHTER	0.50
2014101826	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	10/1/2014		REPLACED 12 LIGHT BULBS AND ONE LIGHT BALLAST. VACUUMED THREE LIGHT LENSES.	1.50
2014101827	MAINTENANCE ODW BLDG/EQUIP. REP	GATEHOUSE 1 DOOR WILL NOT LOCK	GATEHOUSE 1	10/1/2014		REALIGNED THUMB WHEEL AND REPLACED MISSING SCREW	1.00
2014101902	MAINTENANCE ODW INT. LIGHTING	SHOP HALL LIGHTS OUT	SHOP HALL	10/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014101984	MAINTENANCE ODW GATE/FENCE	GATE 2 - GUARDS ARE REPORTING THAT THE SHACK AT GATE 2 IS HARD TO OPEN	GATE 2	10/2/2014		EAST SIDE DOOR - TIGHTENED UP LOCK ASSEMBLY. RAISED DOOR SLIGHTLY (1/8") AND CHECKED DOOR LEVEL. SWEEPED OUT DOOR TRACK.	0.75
2014101985	MAINTENANCE ODW GATE/FENCE	GATE 5 - GUARDS ARE REPORTING THAT THE SHACK AT GATE 5 IS HARD TO OPEN	GATE 5	10/2/2014		LUBED BOTH DOOR'S LATCHES, KEY CYLINDERS AND UPPER TRACK ROLLERS. VACUUMED OUT BOTH DOOR TRACKS.	0.75
2014101986	MAINTENANCE ODW DOOR	DOOR 2B SOUTH MAKING NOISE	DOOR 2B	10/2/2014		LUBRICATED DOORHINGES. DOORS ARE NOW QUIET.	0.50
2014101987	MAINTENANCE ODW INT. LIGHTING	RM 118 LIGHTS OUT	RM 118	10/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 17 T-8 BULBS	0.50
2014101990	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	10/2/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 12 LIGHT BULBS AND VACUUMED THREE LIGHT LENSES	0.50
2014101991	MAINTENANCE ODW PAINTING	GATEHOUSE 1 HAS RUST SPOTS	GATEHOUSE 1	10/2/2014		GROUND RUST OFF. SANDED AND TOUCHED UP PAINT.	2.00
2014101992	MAINTENANCE ODW PAINTING	GATEHOUSE 2 HAS RUST SPOTS	GATEHOUSE 2	10/2/2014		GROUND RUST OFF. SANDED AND TOUCHED UP PAINT.	2.00
2014101993	MAINTENANCE ODW PAINTING	GATEHOUSE 3 HAS RUST SPOTS	GATEHOUSE 3	10/2/2014		GROUND RUST OFF. SANDED AND TOUCHED UP PAINT.	2.00
2014101994	MAINTENANCE ODW PAINTING	GATEHOUSE 4 HAS RUST SPOTS	GATEHOUSE 4	10/2/2014		GROUND RUST OFF. SANDED AND TOUCHED UP PAINT.	2.00
2014101995	MAINTENANCE ODW PAINTING	GATEHOUSE 5 HAS RUST SPOTS	GATEHOUSE 5	10/2/2014		GROUND RUST OFF. SANDED AND TOUCHED UP PAINT.	2.00
2014101998	MAINTENANCE ODW PAINTING	OUTSIDE MAG HALL VARIOUS FACIA BLOCKS NEED PAINTED	OUTSIDE MAG HALL	10/2/2014		PATCHED AND PAINTED FACIA BLOCKS	4.00
2014102041	MAINTENANCE ODW INT. LIGHTING	AREA 2 LIGHTS OUT ABOVE SHIRLEY'S DESK	AREA 2	10/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	AREA 1 NOT 2. REPLACED THREE LIGHT BULBS.	0.50
2014102042	MAINTENANCE ODW INT. LIGHTING	POLE 6S LIGHT OUT	POLE 6S	10/3/2014		PER AG: LIGHT WAS FIXED LAST WEEK. TALKED TO IRS EMPLOYEE ABOUT IT.	0.50
2014102061	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A5 STALL #2 CLOGGED	W'S R/R A5	10/3/2014		PLUNGED THE COMMODE	0.50
2014102093	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 8T CORNER BROKEN ON BLUE RAILING	POLE 8T	10/6/2014		NORTH SIDE OF POLE 8T, REPLACED CORNER WITH NEW	0.50
2014102094	MAINTENANCE ODW INT. LIGHTING	RM 604 LIGHTS OUT	RM 604	10/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014102095	MAINTENANCE ODW INT. LIGHTING	CHILDCARE LIGHTS OUT IN RM 110 AND WEST HALLWAY	CHILDCARE	10/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FIVE BULBS	0.75
2014102097	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 LOOSE FLOOR TILE	CHILDCARE RM 128	10/6/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	CLEANED UP AREA. GLUED DOWN TILE. CHECKED SEVERAL TIMES TO MAKE SURE GLUE WAS DRY.	1.00
2014102099	MAINTENANCE ODW BLDG/EQUIP. REP	GUARDHOUSE 3 POSSIBLE ROOF LEAK	GUARDHOUSE 3	10/6/2014		CLEANED ROOF. RECOATED THE AREAS THAT LOOKED LIKE IT COULD BE POTENTIAL PROBLEM.	0.50
2014102773	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 130 SINK OVERFLOWING	CHILDCARE RM 130	10/7/2014		PLUNGED SINK. DRAINS OK.	0.50
2014102805	MAINTENANCE ODW INT. LIGHTING	MAG HALL W'S R/R 34 LIGHT OUT	MAG HALL W'S R/R 34	10/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 T32 T8 BULBS	0.50
2014102857	MAINTENANCE ODW INT. LIGHTING	MAG HALL RM 39 LIGHTS OUT	MAG HALL RM 39	10/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 4 LAMPS	0.50
2014102902	MAINTENANCE ODW DOOR	DOOR 18 IS MAKING A LOUD NOISE	DOOR 18	10/9/2014		RAISED DOOR SLIGHTLY BECAUSE IT WAS RUBBING AT THE BOTTOM.	0.75
2014102939	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LIGHTS OUT SOUTH OF POLE 4S	AREA 4 EAST	10/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	0.50
2014102989	MAINTENANCE ODW PLUMBING	W'S R/R A1003 STALL #9 WILL NOT FLUSH	W'S R/R A1003	10/14/2014	AA BATTERIES-COV;AA BATTERIES ;	REPLACED 4 "AA" BATTERIES	0.50
2014102998	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #2 COMMODE IS CLOGGED	M'S R/R B309	10/14/2014		UNCLOGGED COMMODE	0.50
2014102999	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 HAS TWO BROKEN FLOOR TILES	CHILDCARE RM 128	10/14/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REPLACED 2 BROKEN TILES	0.50
2014103000	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 LIGHTS OUT	W'S R/R A1003	10/14/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED SIX LIGHT BULBS	0.50
2014103001	MAINTENANCE ODW CEILING TILE	W'S R/R A1003 CEILING TILE STAINED	W'S R/R A1003	10/14/2014	CEILING TILE-COV;CEILING TILE ;	REPLACED CEILING TILE	0.50
2014103002	MAINTENANCE ODW DOOR	DOOR 13 BY THE DESTRUCTOR NEEDS SCRAPED, PAINTED, CAULKED AND BONDOED AT BOTTOM.	DOOR 13	10/14/2014		LT: USED GRINDER TO REMOVE ALL LOOSE PAINT AND RUST AND USED BONDO TO FIX MINOR DENTS. SH: CAULKED DOOR FRAME INSIDE AND OUT.	5.00
2014103035	MAINTENANCE ODW PLUMBING CLOG	MAG HALL RM 4 COMMODE IS CLOGGED	MAG HALL RM 4	10/15/2014		PLUNGED THE COMMODE AND REPAIRED WATER LEAK BELOW FLUSHHEAD.	0.50
2014103055	MAINTENANCE ODW INT. LIGHTING	M'S R/R B309 TWO LIGHTS OUT	M'S R/R B309	10/15/2014		REPLACED 2 LIGHT BULBS OVER RIGHT URINAL	0.50
2014103056	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET #3 STOPPED UP	M'S R/R B309	10/15/2014		PLUNGED THE COMMODE	0.50
2014103058	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET IS CLOGGED	M'S R/R A308	10/15/2014		PLUNGED THE COMMODE	0.50
2014103060	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 126 REPAIR LOOSE COVE BASE LOCATED TO THE RIGHT OF THE BATHROOM DOOR	CHILDCARE RM 126	10/15/2014		REGLUED LOOSE COVE BASE	0.50
2014103076	MAINTENANCE ODW INT. LIGHTING	COURTYARD KITCHEN LIGHT NOT WORKING	COURTYARD KITCHEN	10/16/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.00
2014103120	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A306 STALL #3 TOILET SEAT BROKEN	W'S R/R A306	10/17/2014		TIGHTENED SEAT BOLTS	0.50
2014103121	MAINTENANCE ODW INT. LIGHTING	W'S R/R A5 LIGHTS OUT	W'S R/R A5	10/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 T8 F32 BULBS	0.50
2014103122	MAINTENANCE ODW INT. LIGHTING	R/R A403 LIGHTS OUT	R/R A403	10/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BULB 18W-COV;18W LIGHT BULB ;	REPLACED 4 T8 F32 BULBS AND 1 18W BULB	0.50
2014103126	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LAMPS OUT	SATELLITE CANTEEN	10/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014103143	MAINTENANCE ODW BUILDING SIGNAGE	PARKING LOT F, 5TH SPOT WEST OF THE LOBBY ENTRANCE, RA SIGN NEEDS REPLACED.	PARKING LOT F	10/17/2014		REPLACED SIGN WITH NEW ONE	0.50
2014103159	MAINTENANCE ODW INT. LIGHTING	RM 103D OVERHEAD LIGHT ABOVE SINK IS FALLING OUT OF THE CEILING.	RM 103D	10/20/2014		LIGHT ONLY HAD THREE RAILS HOLDING IT IN PLACE. INSTALLED FOURTH RAIL ON NORTH SIDE OF LIGHT AND RIVETED IT IN PALCE.	1.00

2014103164	MAINTENANCE ODW RESTROOM FIXTURE	OLD TOILET PAPER DISPENSERS NEED REPLACED WITH NEW	R/R'S 810 AND 811	10/20/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REPLACED OLD DISPENSERS WITH NEW.	1.00
2014103187	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 MIDDLE STALL CLOGGED	W'S R/R 34	10/20/2014		FLUSHED ALL THREE TOILETS. ALL WORKED PROPERLY.	0.50
2014103205	MAINTENANCE ODW PLUMBING CLOG	CONTROL CENTER'S SINK WILL NOT DRAIN	CONTROL CENTER	10/20/2014		SNAKED DRAIN	1.00
2014103206	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET CLOGGED	M'S R/R A308	10/20/2014		TOILET WAS WORKING PROPERLY UPON ARRIVAL. FLUSHED SEVERAL TIMES. OK.	0.50
2014103225	MAINTENANCE ODW PLUMBING CLOG	MAG HALL R/R 35 TOILET CLOGGED	MAG HALL R/R 35	10/21/2014		UNCLOGGED WITH PLUNGER	0.50
2014103226	MAINTENANCE ODW INT. LIGHTING	DOOR 21 HALL LAMPS OUT IN FIXTURES BETWEEN POLES 5B AND 5L	DOOR 21 HALL	10/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014103242	MAINTENANCE ODW PA SYSTEM	POLE 10S LOUD SPEAKER NEEDS TO BE REMOVED	POLE 10S	10/21/2014		DISCONNECTED PA SPEAKERS AT POLES 10Q AND 10R PER KATHY FEDE.	1.00
2014103289	MAINTENANCE ODW INT. LIGHTING	LAMPS OUT IN FIXTURE OUTSIDE MAG HALL 22	MAG HALL HALLWAY EAST	10/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014103290	MAINTENANCE ODW INT. LIGHTING	RM 807 LIGHTS OUT	RM 807	10/22/2014	LIGHT BULB CFL-COV;CF LIGHT BULB ;	REPLACED TWO LIGHT BULBS AND WIPED OFF GLOBES	0.50
2014103291	MAINTENANCE ODW INT. LIGHTING	RM 805 LIGHTS OUT	RM 805	10/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014103293	MAINTENANCE ODW INT. LIGHTING	RM 816 LIGHTS OUT	RM 816	10/22/2014		REPLACED TWO LIGHT BULBS AND WIPED OFF LENS/COVER	0.50
2014103294	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 TOILET CLOGGED	W'S R/R B211	10/22/2014		UNCLOGGED THE COMMODORE	0.50
2014103296	MAINTENANCE ODW PAINTING	OUTSIDE LOBBY VALANCE IS PEELING AND NEEDS PAINTED	OUTSIDE LOBBY	10/22/2014		SCRAPED LOOSE PAINT AND PAINTED VALANCE	3.00
2014103303	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A404 10TH SINK'S CABINET DOOR IS OFF AND LAYING ON COUNTER	W'S R/R A404	10/22/2014		REPAIRED BOTTOM HINGE ONTO DOOR	1.00
2014103314	MAINTENANCE ODW INT. LIGHTING	POLES 4J AND 5J. TWO OF FOUR BULBS NEED TO BE REMOVED FROM THE SIDE FACING CUBICLE 01-03-047 FOR EMPLOYEE CELISSA NEWBILL.	POLES 4J AND 5J	10/22/2014		REMOVED 2 LAMPS SOUTH SIDE OF FIXTURE PER MISS NEWBILL	0.50
2014103356	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 126 - REPLACE TERMITE DAMAGED MASONITE ON THE NORTH WALL	CHILDCARE RM 126	10/23/2014		REMOVED DAMAGED MASONITE AND DRYWALL. VACUUMED UP TERMITES. REPLACED DRYWALL AND MASONITE AND REPAINTED WALL WITH TWO COATS. MATERIAL COST: \$100.00.	14.00
2014103369	MAINTENANCE ODW INT. LIGHTING	AREA 8 OVERHEAD LIGHTS OUT IN CAGE AND HALLWAY	AREA 8	10/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	RELACED FOUR LIGHT BULBS IN CAGE AND 12 LIGHTS IN HALLWAY	1.25
2014103420	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #3 CLOGGED	M'S R/R B309	10/24/2014		NO TOILETS WERE CLOGGED. ALL WERE WORKING PROPERLY.	0.50
2014103421	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 STALL #6 CLOGGED	W'S R/R A404	10/24/2014		ALL TOILETS ARE OPERATING PROPERLY. NONE ARE CLOGGED.	0.50
2014103425	MAINTENANCE ODW INT. LIGHTING	RM 903 LIGHTS OUT	RM 903	10/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS	0.50
2014103426	MAINTENANCE ODW INT. LIGHTING	AREA 3 EAST LIGHTS OUT BETWEEN POLES 5H AND 5K	AREA 3 EAST	10/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014103427	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	10/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014103428	MAINTENANCE ODW BLDG/EQUIP. REP	BOILER ROOM REHEAT PUMP #5 IS LEAKING	BOILER ROOM	10/24/2014	PUMP SEAL-COV;PUMP SEAL ;	PUMP LEAKING FROM DEFECTIVE MECHANICAL SEAL. REPLACED SEAL AND CHECKED FOR LEAKS AND PROPER OPERATION. OK. CLEANED UP WORK AREA.	10.00
2014103429	MAINTENANCE ODW BLDG/EQUIP. REP	R/R 700H #2 TOILET CONSTANTLY RUNNING	R/R 700H	10/24/2014	AA BATTERIES-COV;AA BATTERIES ;; BREAKER- COV;BREAKER ;	REPLACED BATTERIES AND VACUUM BREAKER (OLD ONE WAS LEAKING)	0.75
2014103430	MAINTENANCE ODW INT. LIGHTING	200F LIGHT FIXTURE NOT WORKING	200F	10/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS. WORKING FINE.	0.50
2014103431	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHTS OUT	AREA 5	10/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.50
2014103457	MAINTENANCE ODW BLDG/EQUIP. REP	Repair of dock loading ramp #4. Previous work ticket for this closed by mistake	DOCK	10/24/2014		FABRICATED NEW HINGE AND WELDED TO RESIZE BROW PLATE. MATERIAL COST: \$115.00	10.00
2014103499	MAINTENANCE ODW INT. LIGHTING	RM 25, DIRECTOR'S OFFICE, LIGHTS OUT	RM 25	10/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	0.50
2014103530	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHT FIXTURE NOT WORKING	AREA 1	10/27/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.50
2014103531	MAINTENANCE ODW DOOR	DOOR 18 DIFFUSER	DOOR 18	10/27/2014		WASHED DIFFUSERS AND VACUUMED CEILING TILE	0.50
2014103535	MAINTENANCE ODW BLDG/EQUIP. REP	MAG HALL - REHEAT VALVES LEAKING IN HALLWAY BETWEEN ROOMS 3 AND 4 AND IN HALLWAY TO THE RIGHT OF DOOR 7	MAG HALL	10/27/2014		REBUILT PACKING FOR EACH UNIT	3.00
2014103553	MAINTENANCE ODW EXT. LIGHTING	B1 DOOR ONE OF THE TWO FLOOD LIGHTS DO NOT WORK	B1 DOOR	10/27/2014	FLOOD LIGHT-COV;FLOOD LIGHT 75W ;; PHOTO CELL- COV;PHOTOCELL ;	10-24-14: REPLACED BAD BULB AND SCREW IN PHOTOCELL. LIGHT STILL DOES NOT WORK. ORDERED NEW FLOOD LIGHT WITH PHOTOCELL. 10-27-14: REMOVED AND REPLACED PHOTOCELL.	3.50
2014103554	MAINTENANCE ODW INT. LIGHTING	DOOR B1 HANDICAP HEAT LAMPS OUT	DOOR B1	10/27/2014		REPLACED 1 MISSING BULB AND 2 BURNED OUT BULBS. CURRENTLY, THERE IS NO PM FOR THESE LIGHTS.	2.00
2014103555	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE R/R CHILD FLUSHED TOY DOWN TOILET	CHILDCARE R/R	10/27/2014		THIS OCCURRED ON FRIDAY (PER TEACHER). NO CALL WAS MADE UNTIL MONDAY WHEN IT WAS CALLED IN 3 TIMES. PLUNGED TOILET AND SNAKED. TOY PASSED THROUGH.	1.00
2014103578	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 ALL TOILETS CLOGGED AND THERE'S A PRESENCE OF BLACK WATER	M'S R/R B309	10/28/2014		10-28: SNAKED DRAIN. CLOG IS IN THE MAIN LINE. 10- 29: SNAKED MAIN. REMOVED PAPER TOWELS AND MATERIAL. 10-30: SNAKED MAIN. REMOVED UNDERWEAR. DRAIN IS NOW CLEAR.	13.50
2014103612	MAINTENANCE ODW INT. LIGHTING	POLE 5E LIGHT FIXTURE IS LOOSE AND DROOPING	POLE 5E	10/28/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	SECURED LOOSE COVER ON TWO FIXTURES AND REPLACED LAMPS	0.50
2014103661	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A309 FLUSHHEAD NOT WORKING	W'S R/R A309	10/29/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	MANUAL FLUSH ONLY WORKING. REPLACED AUTO FLUSHHEAD.	0.50
2014103662	MAINTENANCE ODW BLDG/EQUIP. REP	MAG HALL OUTSIDE FRONT LEFT CORNER NEEDS CONCRETE PATCHED	MAG HALL	10/29/2014		TOUCHED UP CONCRETE PATCH ON FRONT LEFT CORNER OF BUILDING UP HIGH ON VALANCE	1.00
2014103663	MAINTENANCE ODW INT. LIGHTING	B313 LIGHT FIXTURE NOT WORKING	B313	10/29/2014		REPLACED BALLAST. OK.	1.00
2014103665	MAINTENANCE ODW INT. LIGHTING	AREA 14 BALLAST IS BAD AND LIGHT FIXTURE NOT WORKING	AREA 14	10/29/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST WITH NEW	1.00
2014103666	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	10/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED SIX LIGHT BULBS AND ONE LIGHT BALLAST. VACUUMED TWO LIGHT FIXTURES.	1.25
2014103675	MAINTENANCE ODW TEMPERATURE COLD	POLE 6EE TOO COLD	POLE 6EE	10/29/2014		TEMP IN SPACE IS 73 DEG F. WITHIN CONTRACT REQUIREMENTS. NO CHANGE MADE.	0.50
2014103726	MAINTENANCE ODW INT. LIGHTING	AREA 4 LAMPS OUT IN FIXTURE	AREA 4	10/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50

2014103727	MAINTENANCE ODW INT. LIGHTING	AREA 3 LAMPS OUT IN FIXTURE BETWEEN POLE 3B AND CUBICLE	AREA 3	10/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014103728	MAINTENANCE ODW BLDG/EQUIP. REP	A404 THREE FOOT OF COVE BASE IS OFF WALL EAST SIDE OF ENTRANCE	A404	10/30/2014		APPLIED SILICONE TO COVE BASE AND REATTACHED TO WALL.	2.50
2014103729	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE R/R 123 STALL #1 OVERFLOWING AND #2 CLOGGED	CHILDCARE R/R 123	10/30/2014		UNCLOGGED BOTH WITH PLUNGER	0.50
2014103730	MAINTENANCE ODW DOOR	AREA 9 DOOR TO 903 OFF TRACK AT TOP AND WILL NOT CLOSE	AREA 9	10/30/2014		PUT DOOR BACK ON TRACK. SECURED DOOR.	0.50
2014103766	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 COMMODE IS CLOGGED	W'S R/R B211	10/31/2014		UNCLOGGED THE COMMODE	0.50
2014103768	MAINTENANCE ODW DOOR	AREA 7 DOOR 700 - ALUMINUM ON THE TOP IS DRAGGING	AREA 7 DOOR 700	10/31/2014		CHECKED DOOR. FOUND THAT BOTTOM ROLLER WAS MAKING NOISE. LUBRICATED ROLLER. DOOR IS NOW QUIET.	1.00
2014103785	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 28 TOILET IS BACKED UP	CHILDCARE RM 28	10/31/2014		CHILDCARE RM 123-PLUNGED BOTH COMMODOES	0.50
2014103786	MAINTENANCE ODW PLUMBING	W'S R/R 600 SINK #2 TURNS ON/OFF BY ITSELF	W'S R/R 600	10/31/2014		WIPED OFF FAUCET SENSOR AND CHECKED RANGE ADJUSTMENT. OK.	0.50
2014110564	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 COMMODE #2 IS CLOGGED	M'S R/R A1005	11/3/2014		UNCLOGGED THE COMMODE AND TIGHTENED COMMODE SEAT	0.50
2014110565	MAINTENANCE ODW INT. LIGHTING	W'S R/R 600 LIGHTS OUT	W'S R/R 600	11/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014110604	MAINTENANCE ODW INT. LIGHTING	M'S R/R 602 LIGHTS OUT	M'S R/R 602	11/3/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014110639	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHTS OUT	AREA 6	11/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014110641	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	11/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	1.00
2014110642	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A404 SPACING BETWEEN BASEBOARD NEEDS TOUCHED UP	W'S R/R A404	11/3/2014		TOUCHED UP BASEBOARD AND OTHER SPOTS WITH BLACK CAULK	0.50
2014110643	MAINTENANCE ODW BLDG/EQUIP. REP	CAFETERIA ICE MACHINE IS LEAKING	CAFETERIA	11/3/2014		REMOVED PAN AND CLEANED. REPLACED PAN AND PUT PUMP BACK TOGETHER. IT WAS KNOCKED LOOSE BY A MOP.	0.50
2014110644	MAINTENANCE ODW PLUMBING	CHILDCARE RM 123 BOTH COMMODOES LEAK WATER AROUND HANDLES	CHILDCARE RM 123	11/3/2014		REBUILT BOTH FLUSH HANDLES WITH KITS	1.00
2014110645	MAINTENANCE ODW FLOOR TILE	CHILDCARE FLOOR TILE IS LOOSE IN THE HALLWAY	CHILDCARE	11/3/2014		REGLUED FLOOR TILE BACK IN PLACE	0.50
2014110646	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE RM 128 HOLES IN WALL NEED REPAIRED	CHILDCARE RM 128	11/3/2014		SANDED AND PAINTED PATCHES. REQUIRED TWO COATS OF LATEX PAINT.	1.50
2014110647	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHT LENS FELL FROM CEILING AND SHATTERED	AREA 3	11/3/2014		CLEANED UP AREA AND CUT AND INSTALLED A NEW LENS	0.75
2014110648	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 FLOOR TILES POPPING UP	CHILDCARE RM 128	11/3/2014		SCRAPED UP ALL RESIDUE AND CLEANED AND PREPPED AREA FOR GLUE AND NEW TILE.	1.00
2014110649	MAINTENANCE ODW INT. LIGHTING	AREA 3 LIGHTS OUT SOUTH OF POLE 4J	AREA 3	11/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014110650	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT AT POLE 5T	AREA 4	11/3/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014110782	MAINTENANCE ODW DOOR	AREA 7 - SWINGING DOOR WILL NOT CLOSE	AREA 7	11/3/2014		SOUTHERN OHIO DOOR REPLACED LH OPERATOR GEARBOX AND DOOR CONTROLLER. TESTED DOOR FOR PROPER OPERATION (PUSH-BUTTONS AND CARD READER). OK.	1.50
2014111372	MAINTENANCE ODW PLUMBING	HEALTH UNIT - TOILET BY SELF SERVE AREA WILL NOT FLUSH	HEALTH UNIT	11/3/2014	DIAPHRAGM-COV;DIAPHRAGM ;; FLUSH HEAD NEW-COV;FLUSH HEAD ;	FLUSHHEAD NOT WORKING. INSTALLED NEW FLUSHHEAD AND DIAPHRAGM.	1.50
2014112325	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 #4 TOILET SEAT OFF	W'S R/R B211	11/4/2014	TOILET SEAT-COV;TOILET SEAT ;	REPLACED SEAT AND BOLTS	0.50
2014112326	MAINTENANCE ODW INT. LIGHTING	AREA 5 NE POLE 6N LIGHT OUT AND LENS COVER IS CRACKED	AREA 5	11/4/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED COVER AND BALLAST	2.00
2014112375	MAINTENANCE ODW INT. LIGHTING	W'S R/R A309 HANDICAP STALL LIGHT IS OUT	W'S R/R A309	11/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED FOUR LIGHT BULBS AND ONE LIGHT BALLAST	1.00
2014112376	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE R/R 123	CHILDCARE R/R 123	11/4/2014		SNAKED BOTH COMMODOES. PULLED ONE WOODEN TOY OUT OF EACH COMMODE. THE LEFT COMMODE JAMMED SNAKE IN TRAP AGAINST WOODEN TOY. HAD TO CUT TOY THREE TIMES TO REMOVE.	1.50
2014112436	MAINTENANCE ODW TEMPERATURE COLD	AREA 4 TOO COLD	AREA 4	11/5/2014		CHECKED TEMPS IN AREA: 72.5, 72.5 AND 73. WITHIN CONTRACT. MADE NO ADJUSTMENTS.	0.50
2014112453	MAINTENANCE ODW PLUMBING	W'S R/R A1003 #21 WILL NOT FLUSH	W'S R/R A1003	11/5/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD AND DIAPHRAGM WITH NEW UNIT	0.50
2014112477	MAINTENANCE ODW INT. LIGHTING	AREA 3 - THERE ARE OVER 50 BULBS OUT	AREA 3	11/6/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	11-6-14: REPLACED 30 LAMPS. 11-9-14: REPLACED 15 LAMPS AND 1 BALLAST AND 2 LENS COVERS.	4.50
2014112490	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE R/R 123 BOTH TOILETS CLOGGED	CHILDCARE R/R 123	11/6/2014		MM: SHUT OFF WATER AND PLACED COVER OVER TOILET. AG: REMOVED WOODEN TOY FROM COMMODE. COMMODE BACK IN SERVICE.	1.50
2014112491	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #13 TOILET CLOGGED	W'S R/R B211	11/6/2014		UNCLOGGED WITH PLUNGER	0.50
2014112509	MAINTENANCE ODW PA SYSTEM	AREA 8, OUTSIDE OFFICE 817, POLE 10X PA SPEAKER CUTS IN AND OUT DURING ANNOUNCEMENTS	AREA 8 - 10X	11/6/2014		REPLACED SPEAKER WITH A SPARE FROM AREA 7	1.00
2014112534	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #10 CLOGGED	W'S R/R B211	11/6/2014		CLEARED CLOG WITH PLUNGER	0.50
2014112538	MAINTENANCE ODW PLUMBING	M'S R/R A308 FAUCET RUNNING	M'S R/R A308	11/6/2014		CHECKED FAUCET. CLEARED EYE. OK.	0.50
2014112541	MAINTENANCE ODW POWER OUTAGE	RM 200 BADGE RM BLOWN FUSE	RM 200 BADGE RM	11/6/2014		RESET BREAKER #16	0.50
2014112556	MAINTENANCE ODW INT. LIGHTING	AREA 13 LIGHT FIXTURE NOT WORKING	AREA 13	11/7/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST. OK.	1.00
2014112576	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 404 #5 CLOGGED	W'S R/R 404	11/7/2014		FLUSHED ALL TOILETS. ALL FUNCTIONING PROPERLY.	0.50
2014112577	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 34 HANDICAP STALL CLOGGED AND THERE'S STANDING WATER ON FLOOR	W'S R/R 34	11/7/2014		PLUNGED COMMODE. FLUSHED. FUNCTIONING PROPERLY.	0.50
2014112593	MAINTENANCE ODW DOOR	AREA 1 & AREA 7 SLIDING GLASS DOOR IS SLAMMING	AREA 1 & AREA 7	11/7/2014		OILED ROLLER AND ADJUSTED DOOR CLOSING SPEED	0.50
2014112594	MAINTENANCE ODW INT. LIGHTING	LOBBY ENTRANCE - LIGHT ILLUMINATING DECLARATION OF INDEPENDENCE HAS BURNED OUT	LOBBY ENTRANCE	11/7/2014	LIGHT BULB-COV;LIGHT BULB ;	REPLACED THREE LIGHT BULBS	0.75
2014112598	MAINTENANCE ODW ELECTRICAL	POLE 8 V NO POWER		11/7/2014		CHECKED WSI BOX NO POWER RESET BREAKER PANEL 8V #13	0.50
2014112606	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	11/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 12 LIGHT BULBS	0.50
2014112608	MAINTENANCE ODW INT. LIGHTING	AREA 1 LIGHT FIXTURE NOT WORKING	AREA 1	11/10/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST.	1.00
2014112609	MAINTENANCE ODW INT. LIGHTING	AREA 14 LIGHT FIXTURE NOT WORKING	AREA 14	11/10/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST. OK.	1.00
2014112610	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 110 BROKEN FLOOR TILE	CHILDCARE RM 110	11/10/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	CLEANED AREA AND REPLACED BROKEN FLOOR TILE	0.50

2014112613	MAINTENANCE ODW DOOR	DOOR 18 INTERIOR MIDDLE HINGE ON DOOR OUT TOO FAR	DOOR 18	11/10/2014		ADJUSTED MIDDLE HINGE. ALSO UNBOUND MIDDLE HINGE HEIGHT ADJUSTMENT PIN SO DOOR HEIGHT CAN NOW BE ADJUSTED.	1.00
2014112614	MAINTENANCE ODW INT. LIGHTING	AREA 4 WEST LAMPS OUT BETWEEN 5N AND 6N	AREA 4 WEST	11/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LAMPS AND BALLAST	1.50
2014112635	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 STALL #2 IS STOPPED UP	M'S R/R B309	11/10/2014		TOILET WOULD NOT FLUSH DUE TO DEAD BATTERIES. REPLACED BATTERIES AND TESTED. FLUSHES OK.	0.50
2014112640	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #4 STOPPED UP	W'S R/R B211	11/10/2014		PLUNGED TOILET. NOW CLEAR.	0.50
2014112641	MAINTENANCE ODW PLUMBING	M'S R/R B309 TOILET CONTINUES TO FLUSH (DID NOT INDICATE WHICH ONE)	M'S R/R B309	11/10/2014		BAD FLUSH HEAD. REPLACED ENTIRE HEAD. FLUSHES OK.	0.50
2014112677	MAINTENANCE ODW KITCHEN EQUIP	COURTYARD CANTEEN OVEN DOOR WILL NOT CLOSE	COURTYARD CANTEEN	11/12/2014		11-12-14: FOUND LEFT SIDE HINGE SUPPORT BROKEN. 11-13-14: REPAIRED OVEN DOOR.	4.00
2014112696	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 #5 CLOGGED	W'S R/R A1003	11/12/2014		UNCLOGGED WITH PLUNGER	0.50
2014112697	MAINTENANCE ODW DOOR	CHILDCARE DOOR NE TO PLAYGROUND WILL NOT LOCK	CHILDCARE	11/12/2014		LOCKED DOOR WITH THUMB LATCH. CUSTODIAN DID NOT HAVE LATCH PULLED IN ENOUGH.	0.50
2014112698	MAINTENANCE ODW INT. LIGHTING	AREA 4 EAST LIGHTS OUT IN FIXTURES SOUTH OF POLE 4P	AREA 4 EAST	11/12/2014		REPLACED LAMPS	0.50
2014112699	MAINTENANCE ODW WATER FOUNTAIN	RESTRICTED AREA 6, POLE 8P, WATER FOUNTAIN MAKING A NOISE	RESTRICTED AREA 6	11/12/2014		CHECKED FOUNTAIN. IT IS OK. EMPLOYEE STATED SUMP PUMP ALARM WAS ON AND WAS TURNED OFF. CHECKED SUMP PUMPS 1 AND 2. BOTH WORKING.	0.50
2014112715	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 TOO HOT	AREA 1	11/13/2014		LOWERED SET POINT FROM 75 DEG TO 72 DEG	0.50
2014112723	MAINTENANCE ODW PLUMBING	AREA 7 MEN'S R/R TOILET WILL NOT STOP RUNNING	AREA 7 MEN'S R/R	11/13/2014		URINAL #2 WAS OVERFLOWING. REPLACED FLUSH HEAD. OK.	0.50
2014112742	MAINTENANCE ODW INT. LIGHTING	AREA 3 POLE 4E AND 4F LIGHT COVER IS FALLING OFF	AREA 3 POLE 4E AND 4F	11/13/2014		REPLACED COVER	0.50
2014112772	MAINTENANCE ODW PLUMBING	W'S R/R A1003 #18 WILL NOT FLUSH	W'S R/R A1003	11/13/2014		CHANGED BATTERIES ON FLUSH HEAD. WORKS OK.	0.50
2014112780	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 #14 CLOGGED	W'S R/R B211	11/13/2014		UNCLOGGED TOILET WITH PLUNGER	0.50
2014112782	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 #1 CLOGGED	W'S R/R A404	11/13/2014		UNCLOGGED WITH PLUNGER	0.50
2014112783	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	11/13/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 16 LIGHT BULBS AND VACUUMED FOUR LIGHT LENSES	1.00
2014112784	MAINTENANCE ODW TEMPERATURE COLD	AREA 11 TOO COLD	AREA 11	11/13/2014		TOOK 3 TEMP READINGS OF AREA. 72.6, 72.5 AND 72.7. WITHIN RANGE. MADE NO ADJUSTMENTS.	0.50
2014112785	MAINTENANCE ODW INT. LIGHTING	AREA 5 TWO LIGHT FIXTURES NOT WORKING	AREA 5	11/13/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND REWIRED BOTH FIXTURES	2.50
2014112831	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE STAFF LOUNGE TOILET CLOGGED	CHILDCARE	11/14/2014		CLEARED CLOG WITH PLUNGER	0.50
2014112870	MAINTENANCE ODW PLUMBING	W'S R/R A404 #10 TOILET CONSTANTING RUNNING	W'S R/R A404	11/17/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	CHANGED FLUSH HEAD	0.50
2014112871	MAINTENANCE ODW DOOR	DOOR BETWEEN AREAS 1 AND 7 OFF TRACK	AREA 1 AND 7	11/17/2014		CART KNOCKED DOOR OFF TRACK. PUT DOOR BACK ON TRACK.	0.50
2014112874	MAINTENANCE ODW INT. LIGHTING	RM 307 LIGHT FIXTURE OUT	RM 307	11/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND THREE LIGHT BULBS	0.75
2014112876	MAINTENANCE ODW INT. LIGHTING	AREA 7 SCAMPS LIGHT FIXTURE COMPLETELY OUT	AREA 7 SCAMPS	11/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR LIGHT BULBS	0.75
2014112877	MAINTENANCE ODW INT. LIGHTING	AREA 7 EXTRACTING LIGHTS OUT	AREA 7	11/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS AND VACUUMED TWO LIGHT FIXTURES	0.75
2014112878	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHT FIXTURE COMPLETELY OUT	AREA 9	11/17/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR BULBS	0.75
2014112879	MAINTENANCE ODW BLDG/EQUIP. REP	LIGHT LENSES NEED CLEANED AND DUSTED	DOOR 18	11/17/2014		COMPLETE	0.50
2014112880	MAINTENANCE ODW PLUMBING CLOG	AREA 8 WOMEN'S R/R TOILET CLOGGED	AREA 8	11/17/2014		UNCLOGGED TOILET	0.50
2014112881	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 FLOOR TILES LOOSE	CHLDCARE RM 128	11/17/2014		CLEANED UP OLD SURFACES. PUT DOWN GLUE. LET GLUE DRY. REINSTALLED OLD TILE.	1.00
2014112882	MAINTENANCE ODW BLDG/EQUIP. REP	HANDICAP DOOR WEST SIDE OF LOBBY DOOR A4 AND 22 LIGHT LENSES NEED CLEANED AND DUSTED	HANDICAP DOOR	11/17/2014		WASHED BOTH LIGHT LENSES.	0.50
2014112925	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 #12 TOILET SEAT BROKEN	W'S R/R B211	11/17/2014		CERAMIC ANCHOR BOLTS FOR SEAT BROKEN. REPLACED BOTH MOUNTS.	0.50
2014112955	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 #1 CLOGGED	M'S R/R A1005	11/18/2014		UNCLOGGED WITH PLUNGER	0.50
2014112956	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #2 CLOGGED	M'S R/R B309	11/18/2014		UNCLOGGED WITH PLUNGER	0.50
2014112960	MAINTENANCE ODW PLUMBING	M'S R/R A810 URINAL #2 WILL NOT FLUSH	M'S R/R A810	11/18/2014	AA BATTERIES-COV;AA BATTERIES ;	REPLACED BATTERIES	0.50
2014112966	MAINTENANCE ODW BLDG/EQUIP. REP	AREAS B2, B3, B4, B5 LIGHT LENSES NEED CLEANED AND DUSTED	AREAS B2, B3, B4, B5	11/18/2014		CLEANED BUGS AND DUSTED OUT LENSES	2.00
2014112968	MAINTENANCE ODW TEMPERATURE COLD	POLE 4Q TOO COLD	POLE 4Q	11/18/2014		TOOK THREE READINGS OF AREA: 72.2, 72.2 AND 72.3. MADE NO ADJUSTMENTS.	0.50
2014112977	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 HANDICAP STALL TOILET IS BACKED UP	W'S R/R A404	11/18/2014		TOILET WAS CLEAR UPONARRIVAL. TESTED FLUSH VALVE - OK. FLUSHED TOILET THREE TIMES. REMAINED CLEAR.	0.50
2014113062	MAINTENANCE ODW KITCHEN EQUIP	CANTEEN (EQUIPMENT ID K108-001-02) PILOT SOLENOID IS SPARKING DUE TO BAD COIL	CANTEEN	11/19/2014	SOLENOID-COV;SOLENOID ;	REPLACED PILOT SOLENOID GAS VALVE AND CHECKED FOR LEAKS. NONE FOUND. CHECKED FOR PROPER OVEN OPERATION. OK.	1.50
2014113063	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A34 HANDICAP TOILET IS CLOGGED	W'S R/R A34	11/19/2014		UNCLOGED THE COMMODE	0.50
2014113064	MAINTENANCE ODW INT. LIGHTING	AREA 10 LIGHTS OUT	AREA 10	11/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHT BULBS	0.50
2014113065	MAINTENANCE ODW INT. LIGHTING	AREA 7 COMPLETE FIXTURE BURNED OUT	AREA 7	11/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED LIGHT BALLAST AND THREE LIGHT BUBLS	0.75
2014113066	MAINTENANCE ODW INT. LIGHTING	AREA 5 LIGHT FIXTURE NOT WORKING	AREA 5	11/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.25
2014113067	MAINTENANCE ODW INT. LIGHTING	COURTYARD HALL LAMP OUT	COURTYARD HALL	11/19/2014		REPLACED LAMP	0.50
2014113110	MAINTENANCE ODW INT. LIGHTING	LEFT OF DOOR 2B LIGHT LENS IS FALLING DOWN. CLEAN OUT THE BUGS IN THE LENS AS WELL.	DOOR B2	11/19/2014		LIGHT LENS WAS CRACKED. REPLACED LENS AND REMOVED BUGS.	1.00
2014113132	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A810 #1 STOPPED UP	M'S R/R A810	11/20/2014		CLEARED CLOG WITH PLUNGER	0.50
2014113142	MAINTENANCE ODW BLDG/EQUIP. REP	RM 903 COMPLAINT OF AN ODOR	903	11/20/2014		CHECKED ROOM FOR ODORS. NONE DETECTED.	0.50
2014113143	MAINTENANCE ODW INT. LIGHTING	RM 1004 LIGHTS OUT	RM 1004	11/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014113145	MAINTENANCE ODW TEMPERATURE COLD	AREA 11 TOO COLD	AREA 11	11/20/2014		TOOK THREE READINGS OF AREA, 73.3, 73.3 AND 73.2. WITHIN RANGE. MADE NO ADJUSTMENTS.	0.50
2014113146	MAINTENANCE ODW INT. LIGHTING	B313 LIGHT FIXTURE NOT WORKING	B313	11/20/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR LAMPS	1.25
2014113148	MAINTENANCE ODW INT. LIGHTING	AREA 14 BALLAST IS BAD	AREA 14	11/20/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW	1.00
2014113218	MAINTENANCE ODW EXT. LIGHTING	COURTYARD LIGHT IS ON CONTINUOUSLY	COURTYARD	11/21/2014		REPLACED PHOTO CELL ON LIGHT SOUTH WALL	2.00

2014113225	MAINTENANCE ODW PLUMBING	W'S R/R A600 #14 COMMODE CONSTANTLY RUNNING	W'S R/R A600	11/21/2014	AA BATTERIES-COV;AA BATTERIES ;	REPLACED BATTERIES IN FLUSH HEAD	0.50
2014113226	MAINTENANCE ODW BLDG/EQUIP. REP	POLE 6P LIGHT LENS FELL AND SHATTERED	POLE 6P	11/21/2014		CUT AND REPLACED LIGHT LENS. CLEANED UP DEBRIS.	1.00
2014113227	MAINTENANCE ODW PLUMBING	W'S R/R A1003 SINK #3 CONSTANTLY RUNNING	W'S R/R A1003	11/21/2014		CLEANED OFF SENSOR AND ADJUSTED WATER FLOW	0.50
2014113228	MAINTENANCE ODW TEMPERATURE COLD	AREA 1 TOO COLD	AREA 1	11/21/2014		TOOK THREE TEMPS: 71.2, 71.2, 71.1. ADJUSTED TEMP 2 DEG.	0.50
2014113229	MAINTENANCE ODW INT. LIGHTING	CENTRAL PLANT HAS SEVERAL LIGHTS OUT	CENTRAL PLANT	11/21/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014113246	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A4 MAG HALL TOILET CLOGGED	M'S R/R A4	11/21/2014		CLEARED CLOGGED COMMODE	1.00
2014113261	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A35 CLOGGED	M'S R/R A35	11/21/2014		PLUNGED CLOGGED TOILET. NOW CLEAR.	0.50
2014113262	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A404 #3 CLOGGED	W'S R/R A404	11/21/2014		PLUNGED TOILET. NOW CLEAR.	0.50
2014113301	MAINTENANCE ODW BLDG/EQUIP. REP	700H RUBBER IS SEPARATING AT THE BOTTOM AND NEEDS REPAIRED	700H	11/24/2014		REGLUED RUBBER AND LEVELED (FILLED IN THE GAP)	1.00
2014113302	MAINTENANCE ODW TEMPERATURE HOT	COMMAND CENTER TOO HOT	COMMAND CENTER	11/24/2014		ROOFTOP UNIT WAS IN ECONOMIZER MODE, LOCKING OUT MECHANICAL COOLING. UNIT WAS ALREADY MECHANICALLY COOLING WHEN I ARRIVED AT COMMAND CENTER. SPACE = 70 DEG F.	0.50
2014113303	MAINTENANCE ODW PLUMBING	CHILDCARE RM 123 TOILET ON THE RIGHT SIDE IS LEAKING	CHILDCARE	11/24/2014	O-RINGS-COV;O-RINGS ;	REPLACED "O" RING. OK.	0.50
2014113304	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 109 LIGHT OUT OVER CHILDREN'S SINK	CHILDCARE	11/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP	0.50
2014113305	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 126/128 RESTROOM BETWEEN THE TWO ROOMS HAS A LIGHT OUT	CHILDCARE	11/24/2014		REPLACED LAMP	0.50
2014113321	MAINTENANCE ODW TEMPERATURE COLD	POLE 5GG TOO COLD	POLE 5GG	11/24/2014		TEMPERATE WAS 70 DEG F ON HAND-HELD THERMOMETER. RAISED ZONE 6 TEMPERATURE TWO DEGREES ON THERMOSTAT. CHECKED SETTIGNS ON ADJACENT ZONES.	0.50
2014113322	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT	AREA 4	11/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 23 LIGHT BULBS	2.50
2014113323	MAINTENANCE ODW INT. LIGHTING	M'S R/R A1005 LIGHTS OUT	M'S R/R A1005	11/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014113324	MAINTENANCE ODW BLDG/EQUIP. REP	M'S R/R A1005 LAMINATE COMING LOOSE FROM CABINET	M'S R/R A1005	11/24/2014		REGLUED LAMINATE BACK IN PLACE	0.50
2014113325	MAINTENANCE ODW INT. LIGHTING	W'S R/R A1003 LIGHTS OUT	W'S R/R A1003	11/24/2014	COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; COMPACT FLOURSCENT-COV;COMPACT FLOURSCENT ;; FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BULB 18W-COV;18W LIGHT BULB ;	REPLACED FIVE LIGHT BULBS	0.50
2014113326	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A1003 LAMINATE COMING OFF CABINET DOORS	W'S R/R A1003	11/24/2014		REGLUED LAMINATE BY HANDLE ON SECOND DOOR. REGLUED LAMINATE ON BOTTOM/LEFT OF SIXTH DOOR ON LEFT.	0.50
2014113327	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 110 BROKEN FLOOR TILES	CHILDCARE RM 110	11/24/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REMOVED THREE BROKEN FLOOR TILES AND REPLACED WITH NEW	0.50
2014113328	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 128 BROKEN FLOOR TILES	CHILDCARE RM 128	11/24/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REPLACED THREE FLOOR TILES	0.50
2014113339	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A404 EXHAUST FAN #23 NOT RUNNING	W'S R/R A404	11/24/2014	BEARINGS-COV;BEARINGS ;	REMOVED EXHAUST FAN MOTOR. NEEDS NEW BEARINGS. REBUILT EXHAUST FAN MOTOR. INSTALLED NEW BEARINGS AND REINSTALLED IN EXHAUST FAN #23 AND TESTED FOR PROPER OPERATION. OK.	2.50
2014113384	MAINTENANCE ODW PLUMBING CLOG	CHILDCARE RM 128 SINK STOPPED UP	CHILDCARE	11/25/2014		CLEARED CLOGGED SINK	1.00
2014113390	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A308 TOILET CLOGGED	M'S R/R A308	11/25/2014		UNCLOGGED WITH PLUNGER.	0.50
2014113391	MAINTENANCE ODW PLUMBING	W'S R/R A1003 WATER ON FLOOR IN STALL	W'S R/R A1003	11/25/2014		MOPPED UP WATER	0.50
2014113413	MAINTENANCE ODW DOOR	DOOR 18 CLOSEST TO THE CONTROL CENTER IS SQUEAKING	DOOR 18	11/26/2014		CHECKED ALL DOORS AND NONE OF THEM ARE MAKING ANY NOISE.	0.50
2014113414	MAINTENANCE ODW WATER FOUNTAIN	WATER FOUNTAIN BY M'S R/R A1005 WATER PRESSURE IS TOO LOW	M'S R/R A1005	11/26/2014		ADJUSTED PUSH ROD TO LET MORE WATER FLOW	0.50
2014113415	MAINTENANCE ODW PLUMBING	MAG HALL RM 5 #4 WILL NOT FLUSH	MAG HALL RM 5	11/26/2014	AA BATTERIES-COV;AA BATTERIES ;	REPLACED BATTERIES IN FLUSH HEAD	0.50
2014120011	MAINTENANCE ODW FLOOR TILE	POLE 7DD, IN FRONT OF COPIER, FLOOR TILE IS NOT FLUSH	POLE 7DD	12/1/2014		RESET FLOOR TILE	0.50
2014120554	MAINTENANCE ODW PLUMBING	M'S R/R A1005 TOILET CONSTANTLY RUNNING	M'S R/R A1005	12/1/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD WITH NEW SOLIS UNIT	0.50
2014120631	MAINTENANCE ODW EXT. LIGHTING	CENTRAL PLANT OUTSIDE LIGHT NOT WORKING	CENTRAL PLANT	12/1/2014	PHOTO CELL-COV;PHOTOCCELL ;	REPLACED PHOTO CELL	1.00
2014120632	MAINTENANCE ODW EXT. LIGHTING	NE CORNER OF B BLDG LIGHT NOT WORKING	NE CORNER OF B BLDG	12/1/2014		REPLACED LAMP	1.00
2014120633	MAINTENANCE ODW PLUMBING	W'S R/R A306 #1 STALL WILL NOT FLUSH	W'S R/R A306	12/1/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD	0.50
2014120634	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 10 SPARK FROM FLOOR PLUG AT NE CORNER BY POLE 6X	AREA 10	12/1/2014		CLEANED OUT STAPLES, PAPERCLIPS AND DIRT. CHECKED OUTLET, EQUIPMENT OK. REPLACED MISSING WFI COVER. MISS GIBSON TAPED COVER TO FLOOR. PUT LOOSE COVERS BACK ON TWO OTHER WFI'S NEXT TO THIS ONE. SLIGHT DISCOLORATION TO ORANGE PLUB.	0.50
2014120635	MAINTENANCE ODW INT. LIGHTING	MSU LIGHTS OUT	MSU	12/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS	0.50
2014120637	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	12/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 2 LIGHT BULBS	0.50
2014120638	MAINTENANCE ODW INT. LIGHTING	N SWITCH GEAR LIGHTS OUT	N SWITCH GEAR	12/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	RELACED 2 LIGHT BULBS	0.50
2014120759	MAINTENANCE ODW EXT. LIGHTING	COURTYARD EAST SECTION LIGHT NOT WORKING	COURTYARD	12/1/2014	PHOTO CELL-COV;PHOTOCCELL ;	REPLACED LAMP AND PHOTO CELL. MERCURY VAPOR LAMP.	1.00
2014120760	MAINTENANCE ODW INT. LIGHTING	RM 903 LIGHTS OUT	RM 903	12/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 8 LIGHT BULBS AND VACUUMED TWO LIGHT LENSES.	0.75
2014120761	MAINTENANCE ODW FLOOR TILE	CHILDCARE RM 126 FLOOR TILES NEED REPLACED	CHILDCARE RM 126	12/1/2014	12X12 VINLY FLOOR TILES-COV;12X12 VINLY FLOOR TILES ;	REPLACED TILES THAT HAD HOLES DRILLED INTO THEM FOR EXTERMINATING PURPOSES.	2.00
2014120763	MAINTENANCE ODW CARPET	CHILDCARE TEACHER'S LOUNGE VINYL REDUCER FROM CARPET NEEDS REPLACED	CHILDCARE TEACHER'S LOUNGE	12/1/2014		REPLACED THE VINYL REDUCER FROM THE CARPET INTO THE BATHROOM OF THE TEACHER'S LOUNGE.	0.50
2014120764	MAINTENANCE ODW BLDG/EQUIP. REP	LOADING DOCK DOOR 11 STEPS NEEDS REPAIRED	LOADING DOCK DOOR 11	12/1/2014		CLEANED RUST OFF OF METAL CAP. PUNCHED OUT HOLES FOR NEW FASTENERS. CLEANED AREA. REINSTALLED METAL CAP.	0.75
2014120765	MAINTENANCE ODW PLUMBING	M'S R/R A1005 URINAL #3 FLUSHES ON ITS OWN	M'S R/R A1005	12/1/2014		CLEANED OFF SENSING EYE WITH A RAG	0.50
2014120766	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 10 HALLWAY COVEBASE FALLING OFF WALL	AREA 10	12/1/2014		SCRAPED OFF OLD GLUE AND THEN REGLUED COVEBASE BACK INTO PLACE.	0.75
2014120767	MAINTENANCE ODW INT. LIGHTING	EAST-WEST HALLWAY LIGHTS OUT	EAST-WEST HALLWAY	12/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULB	0.50
2014120768	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	12/1/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS.	1.50

2014121695	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A600 FIVE TOILETS CLOGGED AND WATER IS ON THE FLOOR	W'S R/R A600	12/2/2014		CLEARED CLOG IN MAIN WITH HAND-OPERATED SNAKE. TIGHTENED/CHECKED ALL TOILET SEAT BOLTS.	0.75
2014121707	MAINTENANCE ODW DOOR	AREA 6 RM 603 GLASS DOORS DRAGGING	AREA 6 RM 603	12/2/2014		REPLACED TOP TRACK CAP AND CLEANED AND LUBRICATED BOTTOM ROLLER TRACK. TESTED DOOR FOR PROPER OPERATION. OK.	2.00
2014121732	MAINTENANCE ODW BLDG/EQUIP. REP	CHILDCARE TEACHER'S LOUNGE THRESHOLD BROKEN	CHILDCARE TEACHER'S LOUNGE	12/2/2014		REPLACED THRESHOLD	1.00
2014121733	MAINTENANCE ODW INT. LIGHTING	AREA 3 LOOSE COVER AT POLE 4H	AREA 3	12/2/2014		REPLACED LOOSE LENS COVER	0.50
2014121734	MAINTENANCE ODW PLUMBING	CONTROL CENTER R/R SINK FAUCET HANDLE CAME OFF	CONTROL CENTER R/R	12/2/2014		REINSTALLED AND TIGHTENED HANDLE	0.50
2014121735	MAINTENANCE ODW TEMPERATURE COLD	AREA 11 TOO COLD	AREA 11	12/2/2014		TOOK THREE READINGS OF AREA: 72.5, 72.5 AND 72.6. WITHIN RANGE. MADE NO ADJUSTMENTS.	0.50
2014121819	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R A600 LOCKED CABINET HANDLE FELL OFF	W'S R/R A600	12/2/2014		TIGHTENED DOWN SCREWS THAT HOLD THE HANDLE IN PLACE.	0.50
2014121824	MAINTENANCE ODW GATE/FENCE	VISITOR LOT FENCE LOOSE AT TOP BY FIRE GATE ON JOHNSON STREET SIDE	VISITOR LOT	12/2/2014		SCREWED FENCE BACK TOGETHER WITH LARGER SCREWS	1.00
2014122077	MAINTENANCE ODW ELECTRICAL	CHILDCARE PLAY AREA HAS A BROKEN OUTLET COVER ON PURPLE WALL	CHILDCARE	12/3/2014		REPLACED BROKEN COVERS ON PURPLE AND ORANGE WALLS	0.50
2014122078	MAINTENANCE ODW ELECTRICAL	CHILDCARE RM 112 BROKEN OUTLET COVER IN DIRECTOR'S OFFICE (REAR WALL UNDER LARGE BULLETIN BOARD)	CHILDCARE RM 112	12/3/2014		REPLACED BROKEN COVER	0.50
2014122080	MAINTENANCE ODW WATER FOUNTAIN	CHILDCARE RM 123 DEFLECTOR IS BROKEN ON WATER FOUNTAIN	CHILDCARE RM 123	12/3/2014		CHECKED AND ORDERED PARTS. REPLACED FLEXI-GUARD, ORIFICE ASSEMBLY AND ADAPTER.	1.00
2014122088	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 TOO HOT	AREA 1	12/3/2014		LOWERED SET POINT ON UNIT 14-1 FROM 75 DEG TO 73.5 DEG TO MATCH TEMPS IN THE REST OF AREA 1	0.50
2014122089	MAINTENANCE ODW TEMPERATURE HOT	AREA 11 POLE 4T SOME TOO HOT, SOME TOO COLD	AREA 11 POLE 4T	12/3/2014		TEMP AT THIS LOCATION IS 72.5 DEG. THIS IS WITHIN CONTRACT REQUIREMENTS OF 74 DEG +/- 2 DEG. NO CHANGE MADE.	0.50
2014122443	MAINTENANCE ODW PLUMBING	W'S R/R A34 SINK ON RIGHT WILL NOT RUN WHEN HANDS ARE PLACED UNDER FAUCET	W'S R/R A34	12/3/2014		BOTH SINKS ARE WORKING. NEITHER FAUCET WOULD FAIL WHEN PLACING HANDS UNDER FAUCET.	0.50
2014122448	MAINTENANCE ODW ELECTRICAL	RM 903 NO ELECTRIC UNDER FLOOR FOR TWO PLUGS	RM 903	12/3/2014		OUTLET UNDER FLOOR IS OK. (MAY BE A PLUG STRIP?) FLOOR PLUGS CHECKED OUT OK.	0.50
2014122453	MAINTENANCE ODW PLUMBING	W'S R/R A1003 #9 AND #11 WILL NOT FLUSH. #17 PIPE IS LEAKING.	W'S R/R A1003	12/3/2014		REPLACED BATTERIES IN #9 AND #11. REPLACED SPUD GASKET AND VACUUM BREAKER.	0.50
2014122457	MAINTENANCE ODW DOOR	DOOR 18 IS OFF OF HINGE	DOOR 18	12/3/2014		ADJUSTED DOOR TO RAISE PROPERLY AND SET IN PLACE.	0.50
2014122470	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B302 TOILET SEAT IS BROKEN (STALL NUMBER UNKNOWN)	W'S R/R B302	12/4/2014		REPLACED BROKEN MOUNTING HARDWARE TO CORRECT ISSUE (STALL #3)	0.50
2014122477	MAINTENANCE ODW BLDG/EQUIP. REP	BADGE ROOM AIR HANDLER ABOVE CEILING MAKING A NOISE	BADGE ROOM	12/4/2014		REPLACED BELT AND ADJUSTED BELT TENSION	1.75
2014122493	MAINTENANCE ODW WATER FOUNTAIN	AREA 11 WATER FOUNTAIN CLOGGED	AREA 11	12/4/2014		CLEARED CLOG WITH PLUNGER	0.50
2014122499	MAINTENANCE ODW PLUMBING	HEALTH UNIT TOILET RUNNING CONSTANTLY	HEALTH UNIT	12/4/2014		REPLACED FLUSH HEAD	0.50
2014122500	MAINTENANCE ODW INT. LIGHTING	HEALTH UNIT LIGHT OUT	HEALTH UNIT	12/4/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS IN TWO FIXTURES	1.00
2014122534	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 #6 CLOGGED	W'S R/R A1003	12/4/2014		SLOW TO FLUSH. PLUNGED TOILET. NOW CLEAR.	0.50
2014122537	MAINTENANCE ODW PLUMBING	W'S R/R B211 #6 TOILET WILL NOT FLUSH	W'S R/R B211	12/4/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED HEAD WITH REBUILT STOCK	0.50
2014122538	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B302 #8 TOILET SEAT BROKEN	W'S B302	12/4/2014	TOILET SEAT-COV;TOILET SEAT ;	REPLACED BROKEN SEAT	0.50
2014122539	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A1003 HANDICAP TOILET IS CLOGGED	W'S R/R A1003	12/4/2014		MM: PLUNGED AND SNAKED WITH NO LUCK. AG AND TD: SNAKED OUT COMMODE, REMOVED BROWN PAPER TOWELS AND WOMEN'S TISSUE. REINSTALLED LEAKING FLUSH HEAD.	2.75
2014122559	MAINTENANCE ODW TEMPERATURE COLD	AREA 1 POLE 8K TOO COLD	AREA 1 POLE 8K	12/5/2014		TOOK THREE READINGS OF AERA: 71.5, 71.5 AND 71.9. ADJUSTED AHU TO 74 DEG FROM 73.5 DEG.	0.50
2014122561	MAINTENANCE ODW CEILING TILE	CHILDCARE RM 130 CEILING TILE FELL	CHILDCARE RM 130	12/5/2014		RESPONDED WHEN CATHY PUTTHOFF NOTIFIED ME. CHECKED ROOM. TILE HAD BEEN REMOVED AND NO SAFETY ISSUE WAS PRESENT. REPLACED MISSING TILE. CHECKED FOR LEAKS ABOVE CEILING TILE AND FOUND NONE.	1.00
2014122562	MAINTENANCE ODW EXT. LIGHTING	GATEHOUSE #1 POLE LIGHT NOT WORKING	GATEHOUSE #1	12/5/2014		REPLACED LAMP (MULTI VAPOR LAMP, MVR 250/U)	2.00
2014122567	MAINTENANCE ODW DOOR	GUARD SHACK DOOR AT GATE 3 NEEDS LOOKED AT	GUARD SHACK GATE 3	12/5/2014		RAISED RIGHT SIDE OF NORTH SLIDING DOOR BECAUSE IT WAS DRAGGING AT BOTTOM AND LOCK WAS OUT OF ALIGNMENT. TIGHTENED SCREW IN TOP OF TRACK THAT WAS HITTING DOOR ROLLERS. VACUUMED FLOOR TRACK.	0.75
2014122575	MAINTENANCE ODW PLUMBING	M'S R/R B309 TOILET FLUSHES CONTINUOUSLY	M'S R/R B309	12/5/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD	0.50
2014122591	MAINTENANCE ODW INT. LIGHTING	AREA 3. 11 BULBS BURNED OUT. 5 LOOSE LENSES. 4 BROKEN LENSES. 1 CEILING TILE IS HANGING. (SEE ATTACHED DRAWING.)	AREA 3	12/5/2014		REPLACED LAMPS, REPAIRED LOOSE LENSES, REPLACED BROKEN FIXTURE LENS. AS OF 12/8/14, ALL LIGHTS, LENSES (LOOSE AND/OR BROKEN) AND CEILING TILE HAVE BEEN FIXED/REPLACED/REPAIRED.	3.00
2014122610	MAINTENANCE ODW INT. LIGHTING	HEALTH UNIT RM 41E LIGHT OUT	HEALTH UNIT	12/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LAMPS IN TWO FIXTURES. ALL LAMPS WORKING IN AREA.	0.50
2014122613	MAINTENANCE ODW LEAKS	RM B313 NEEDS 2 CEILING LEAKS REPAIRED	RM B313	12/8/2014		REPLACED ONE CEILING TILE. PAINTED TILES THAT HAD SMALL STAINS.	1.50
2014122614	MAINTENANCE ODW FLOOR TILE	CHILDCARE NEEDS 4 MISMATCHED FLOOR TILES IN THE HALLWAY RESTROOM REPLACED	CHILDCARE	12/8/2014		TORE OUT OLD TILES. CUT AND FIT PIECES AROUND DRAIN.	1.50
2014122615	MAINTENANCE ODW FLOOR TILE	CHILDCARE: TEACHER'S LOUNGE IN MAIN HALL ADJACENT TO EXTERIOR WALL NEEDS CHIPPED FLOOR TILES REPLACED; HALLWAY OUTSIDE DOOR 123 NEEDS MISMATCHED FLOOR TILES REPLACED; HALLWAY OUTSIDE OF ROOM 126 NEEDS 5 MISMATCHED FLOOR TILES REPLACED.	CHILDCARE	12/8/2014		TORE OUT OLD TILES. CLEANED AREA.	3.50
2014122616	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 7 ROOF'S RESTROOM EXHAUST FAN NOT WORKING	AREA 7 ROOF	12/8/2014		REPLACED ELECTRIC MOTOR WITH NEW. REPLACED ELECTRIC WIRES BETWEEN SWITCH AND MOTOR.	2.00
2014122617	MAINTENANCE ODW INT. LIGHTING	AREA 1 SEVERAL LAMPS OUT	AREA 1	12/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00

2014122618	MAINTENANCE ODW INT. LIGHTING	AREA 5 SEVERAL LAMPS OUT	AREA 5	12/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014122619	MAINTENANCE ODW ELECTRICAL	DOOR 18 HALLWAY ELECTRIC OUTLET DOES NOT WORK	DOOR 18 HALLWAY	12/8/2014		REPLACED OUTLET WITH ANOTHER 20 AMP, 110 VAC OUTLET	0.75
2014122620	MAINTENANCE ODW INT. LIGHTING	W'S R/R B302 LIGHTS BURNED OUT	W'S R/R B302	12/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	2.00
2014122621	MAINTENANCE ODW INT. LIGHTING	M'S R/R B309 LIGHTS OUT	M'S R/R B309	12/8/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	1.00
2014122640	MAINTENANCE ODW PLUMBING	W'S R/R B302 FAUCET CONTINUES TO RUN	W'S R/R B302	12/8/2014	SOLENOID REBUILT-COV;REBUILT SOLENOID ;	12-8-14: CHANGED BATTERIES AND TUREND OFF FAUCET SUPPLY LINE. 12-9-14: REPLACED SOLENOID VALVE WITH REBUILD.	1.50
2014122642	MAINTENANCE ODW PLUMBING	W'S R/R A306 WATER SPRAYING FROM PIPE CAUSING RESTROOM TO FLOOD	W'S R/R A306	12/8/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD, SPUD GASKET AND VACUUMED BREAKER	1.00
2014122651	MAINTENANCE ODW TEMPERATURE COLD	RM 49 TOO COLD	RM 49	12/9/2014		ROOM TEMP 71.9 DEG F. SET POINT 72 DEG F. RAISED SET POINT TO 74 DEG F ON UNIT 12-3.	0.50
2014122722	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 3 CHECK TO SEE IF THE MAN TRAP GATES HAVE POWER	GATEHOUSE 3	12/9/2014		THE GATE DOES HAVE POWER. DOES NOT CYCLE CORRECTLY.	1.00
2014122725	MAINTENANCE ODW INT. LIGHTING	AREA 12 LAMPS BURNED OUT	AREA 12	12/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	3.00
2014122726	MAINTENANCE ODW INT. LIGHTING	AREA 13 LAMPS BURNED OUT	AREA 13	12/9/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	1.50
2014122731	MAINTENANCE ODW INT. LIGHTING	CHILDCARE RM 130 LIGHT LENS FALLING	CHILDCARE RM 130	12/9/2014		WEST SIDE CLIP VIBRATED LOOSE. SECURED.	0.50
2014122743	MAINTENANCE ODW PLUMBING	W'S R/R 5 TOILET (UNKNOWN WHICH ONE) WILL NOT FLUSH	W'S R/R 5	12/10/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD AND CHECKED AND TIGHTENED SEAT BELTS.	1.00
2014122756	MAINTENANCE ODW INT. LIGHTING	AREA 10 OVERHEAD LIGHTS OUT	AREA 10	12/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 12 LIGHT BULBS AND CLEANED THREE LIGHT LENSES	0.75
2014122757	MAINTENANCE ODW INT. LIGHTING	AREA 13 BALLAST BAD	AREA 13	12/10/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED WITH NEW	1.00
2014122758	MAINTENANCE ODW INT. LIGHTING	MDF LAMPS BURNED OUT	MDF	12/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014122759	MAINTENANCE ODW INT. LIGHTING	W'S R/R B211 LIGHTS AND BALLAST OUT	W'S R/R B211	12/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.00
2014122760	MAINTENANCE ODW INT. LIGHTING	B317 LAMPS BURNED OUT	B317	12/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED WITH NEW	0.50
2014122761	MAINTENANCE ODW INT. LIGHTING	B314 SEVERAL LIGHTS OUT	B314	12/10/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.75
2014122789	MAINTENANCE ODW PLUMBING	W'S R/R A1003 #5 TOILET WILL NOT FLUSH	W'S R/R A1003	12/10/2014	FLUSH HEAD REBUILT-COV;FLUSH HEAD REBUILT ;	REPLACED FLUSH HEAD WITH REBUILT	1.00
2014122790	MAINTENANCE ODW INT. LIGHTING	M'S R/R B309 LIGHTS OUT IN STALL AREA	M'S R/R B309	12/10/2014		LOOKED AT LIGHTS ON TWO DIFFERENT ATTEMPTS. ALL STALL LIGHTS ARE ON AND WORKING. NO BULBS OUT.	0.50
2014122791	MAINTENANCE ODW TEMPERATURE COLD	RM 200 BADGE ROOM TOO COLD	BADGE ROOM	12/10/2014		SPACE TEMP IS 72.3 DEG. RAISED SET POINT FROM 73 DEG TO 74.5 DEG.	0.50
2014122805	MAINTENANCE ODW INT. LIGHTING	MAG HALL LIGHTS OUT IN HALL OUTSIDE MH 20-21	MAG HALL	12/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS.	0.50
2014122806	MAINTENANCE ODW INT. LIGHTING	SCAMPS ONE LIGHT FIXTURE HAS FLICKERING LIGHTS	SCAMPS	12/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND FOUR LIGHT BULBS	1.00
2014122807	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	12/11/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED THREE LIGHT BULBS AND VACUUMED ONE LIGHT FIXTURE	0.50
2014122830	MAINTENANCE ODW CEILING TILE	CHILDCARE RM 130 BATHROOM NEEDS STAINED CEILING TILES REPLACED	CHILDCARE RM 130	12/11/2014		REPLACED ONE STAINED CEILING TILE IN THE LEFT BATHROOM. REPLACED THE CEILING TILE WITH THE SPRINKLER HEAD IN IT.	0.75
2014122884	MAINTENANCE ODW INT. LIGHTING	RM 1101 IDF EMERGENCY LIGHT OUT	RM 1101	12/12/2014		REPLACED 2 "T8" BULBS	0.50
2014122886	MAINTENANCE ODW CEILING TILE	MAG HALL NURSE'S STATION WET CEILING TILE	MAG HALL	12/12/2014		CAUSED BY LEAKING DOMESTIC COLD WATER LINE. REMOVED LEAKING 1-1/4" NIPPLE AND REPLACED. INSTALLED NEW 1-1/4" DIELECTRIC UNION. CHECKED FOR LEAKS. OK. REINSULATED WATER LINE AND REPLACED TWO DAMAGED CEILING TILES.	2.50
2014122914	MAINTENANCE ODW DOOR	CSPC DOOR 10 IS OPENING TOO SLOWLY	CSPC DOOR 10	12/12/2014		ADJUSTED LIMIT SWITCH SO DOOR WOULD COMPLETELY OPEN AND ADJUSTED OPEN SPEED.	1.00
2014122925	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 #2 TOILET STOPPED UP	M'S R/R B309	12/12/2014		CHECKED THEM ALL. ALL TOILETS ARE WORKING.	0.50
2014122957	MAINTENANCE ODW GATE/FENCE	FIRE GATE AT JOHNSON ST. HAS A CRACK AT THE BOTTOM OF POST	FIRE GATE AT JOHNSON ST.	12/15/2014		MEASURED AND CUT ALUMINUM ANGLE AND INSTALLED ON INSIDE. PUT A 3/8" BOLT INTO THE POST.	0.75
2014122958	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	12/15/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED FOUR BULBS AND ONE BALLAST.	1.50
2014122959	MAINTENANCE ODW CEILING TILE	MAG HALL RM 30 HAS A CEILING TILE THAT IS HANGING DOWN	MAG HALL RM 30	12/15/2014		REPLACED CEILING TILE	1.00
2014122964	MAINTENANCE ODW TEMPERATURE HOT	RMS 49 AND 50 TOO WARM	RMS 49 AND 50	12/15/2014		ROOMS ARE 73 DEG F. CHANGED UNIT 12-3 SPACE TEMP SET POINT TO 71 DEG F.	0.50
2014122976	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A306 A STALL IS CLOGGED	W'S R/R A306	12/15/2014		CLEARED CLOGGED COMMODE	1.00
2014123011	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A700 TOILET CLOGGED	M'S R/R A700	12/16/2014		CLEARED CLOG WITH PLUNGER	0.50
2014123012	MAINTENANCE ODW PLUMBING	W'S R/R A1003 TOILET LEAKING	W'S R/R A1003	12/16/2014		REPLACED "O" RING ON SUPPLY LINE	0.50
2014123014	MAINTENANCE ODW INT. LIGHTING	POLE 8P LIGHT OUT	POLE 8P	12/16/2014		REPLACED LAMP	0.50
2014123043	MAINTENANCE ODW BUILDING SIGNAGE	RM 307 NEEDS THE VITA SIGN REMOVED AND DISCARDED	RM 307	12/16/2014		REMOVED SIGN	0.50
2014123045	MAINTENANCE ODW BLDG/EQUIP. REP	RM 39 MAIL SLOT NEEDS TO BE PERMANENTLY COVERED	RM 39	12/16/2014		INSTALLED 2-1/4" X 14" PVC PANEL OVER MAIL SLOT	0.50
2014123063	MAINTENANCE ODW INT. LIGHTING	W'S R/R B302 LIGHT COVER FELL OVER CABINET	W'S R/R B302	12/16/2014		PUT COVER BACK IN TRACK	0.50
2014123064	MAINTENANCE ODW PLUMBING CLOG	M'S R/R A1005 TOILET CLOGGED	M'S R/R A1005	12/16/2014		UNCLOGGED WITH PLUNGER	0.50
2014123065	MAINTENANCE ODW DOOR	AREA 1 DOOR NOT WORKING	AREA 1	12/16/2014		DOOR WAS KNOCKED OF ITS TRACK. REPLACED. CHECKED A FEW TIMES. OK.	0.50
2014123070	MAINTENANCE ODW DOOR	DOCK EMERGENCY DOOR LOCATED NEXT TO THE DOCK BAY DOORS IS MALFUNCTIONING	DOCK BAY DOORS	12/16/2014		TICKET STOPPED. THIS IS NOT AT OUR FACILITY.	0.00
2014123100	MAINTENANCE ODW PLUMBING	W'S R/R A309 POSSIBLE LEAK. WATER IS ON THE FLOOR.	W'S R/R A309	12/17/2014		2430 COULD NOT FIND A LEAK. MOPPED UP WATER. WILL RECHECK THE AREA. 0230 CHECKED FOR WATER ON FLOOR. FOUND NOTHING.	0.75
2014123101	MAINTENANCE ODW DOOR	RM 203 GUARD BREAKROOM DOOR - DOOR KNOB FELL OFF	RM 203	12/17/2014		REPLACED DOOR KNOB	0.50
2014123121	MAINTENANCE ODW DOOR	COMMAND CENTER DOOR RATTLES. KEY RING AROUND KEY LOCK MAY NEED TO BE TIGHTENED.	COMMAND CENTER	12/17/2014		DEADBOLT RATTLES IN DOORFRAME. PLACED A PIECE OF TAPE OVER BOLT TO KEEP IT FROM RATTLING. DEADBOLT IS NOT USED.	0.50
2014123146	MAINTENANCE ODW INT. LIGHTING	RM 903 LIGHTS OUT	RM 903	12/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014123147	MAINTENANCE ODW INT. LIGHTING	AREA 8 HALLWAY LIGHTS OUT BY LOADING DOCK DOOR	AREA 8	12/18/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2014123208	MAINTENANCE ODW PLUMBING	W'S R/R A309 TOILET LEAKING AND RUNNING CONTINUOUSLY	W'S R/R A309	12/18/2014	FLUSH HEAD NEW-COV;FLUSH HEAD ;	REPLACED FLUSH HEAD	0.50
2014123211	MAINTENANCE ODW INT. LIGHTING	POLE 6X LIGHT OUT	POLE 6X	12/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	BAD BALLAST. REPLACED BALLAST AND LAMPS.	1.25

2014123215	MAINTENANCE ODW PLUMBING	CHILDCARE RM 128 WATER FOUNTAIN AT FIRST CHILD SINK IS LEAKING	CHILDCARE RM 128	12/19/2014		12-19-14: ORDERED CARTRIDGE. 12-29-14: REPLACED CARTRIDGE.	1.25
2014123218	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 FAUCETS ARE LEAKING ON BOTH CHILD SINKS LOCATED IN THE BACK OF THE ROOM NEAR THE COURTYARD	CHILDCARE RM 130	12/19/2014		GOOSENECK ON LH SINK LEAKING. REPLACED "O" RING ON GOOSENECK. WATER FOUNTAIN RH SINK LEAKING. REPLACED CARTRIDGE.	1.50
2014123219	MAINTENANCE ODW DOOR	CHILDCARE RM 130 DOOR JAM COVERS ARE NEEDED ON THE BATHROOM DOORS	CHILDCARE RM 130	12/19/2014		DOOR GUARDS WERE INSTALLED ON BOTH BATHROOM DOORS.	2.50
2014123222	MAINTENANCE ODW INT. LIGHTING	MAG HALL 17 AND 18 LIGHTS OUT	MAG HALL 17 AND 18	12/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014123234	MAINTENANCE ODW TEMPERATURE COLD	AREA 7 TOO COLD	AREA 7	12/19/2014		INCREASED SPACE TEMP SETPOINTS ON UNITS 16 AND 17 FROM 71 DEG TO 72.5 DEG F.	0.50
2014123267	MAINTENANCE ODW BLDG/EQUIP. REP	AHU 11-9 SUPPLY FAN BELTS SLAPPING AND MAKING EXCESSIVE NOISE	RM 1002	12/22/2014	FAN BELT-COV;FAN BELT ;	REPLACED BELTS WITH NEW. WIPED OFF BOTH FAN PULLEY AND FAN SHAFT PULLEY.	1.00
2014123268	MAINTENANCE ODW INT. LIGHTING	AREA 6 LIGHT FIXTURE NOT WORKING	AREA 6	12/22/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.00
2014123269	MAINTENANCE ODW INT. LIGHTING	W'S R/R A600 LIGHTS OUT	W'S R/R A600	12/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014123270	MAINTENANCE ODW LEAKS	SOUTH END OF MDF (CHRIS) THERE IS A DOMESTIC WATER LINE LEAK	MDF	12/22/2014		REPLACED LEAKING DIELECTRIC UNION AND GALVANIZED NIPPLE. CHECKED FOR LEAKS. OK. PUT INSULATION ON PIPE AND REPLACED TILE.	5.00
2014123313	MAINTENANCE ODW INT. LIGHTING	MAG HALL LAMPS OUT	MAG HALL	12/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014123314	MAINTENANCE ODW INT. LIGHTING	POLE 4C LIGHT LENS SAGGING	POLE 4C	12/23/2014		REINSTALLED LIGHT LENS	0.50
2014123326	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 TOO WARM	AREA 1	12/23/2014		LOWERED SPACE TEMP. SETPOINT FROM 74.5 TO 72.5.	0.50
2014123334	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A600: STALL #4 TOILET PAPER DISPENSER BROKEN. LAST STALL TOILET PAPER DISPENSER COMPLETELY OFF AND LAYING ON THE FLOOR.	W'S R/R A600	12/23/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REPLACED DISPENSERS IN STALLS 4 AND 7	1.00
2014123337	MAINTENANCE ODW INT. LIGHTING	RM B 200A OVERHEAD LIGHT OUT	RM B 200A	12/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP	0.50
2014123351	MAINTENANCE ODW INT. LIGHTING	AREA 4 SEVERAL FIXTURES HAVE LIGHTS OUT, BROKEN AND LOOSE COVERS	AREA 4	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 40 LAMPS, 8 LENS COVERS, 2 WFI COVERS	12.00
2014123352	MAINTENANCE ODW INT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS	0.50
2014123353	MAINTENANCE ODW INT. LIGHTING	MSU LIGHTS OUT	MSU	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014123354	MAINTENANCE ODW DOOR	RM 307 DOOR NEEDS CUT FOR VENTILATION	RM 307	12/29/2014		CUT HOLE THROUGH DOOR. INSTALLED VENT COVERS NO BOTH SIDES. REINSTALLED DOOR.	1.00
2014123355	MAINTENANCE ODW INT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014123356	MAINTENANCE ODW INT. LIGHTING	AREA 4 LIGHTS OUT	AREA 4	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REINSERTED LOOSE PANELS AND REPLACED LAMPS	2.00
2014123357	MAINTENANCE ODW INT. LIGHTING	POLE 6B LIGHTS OUT	POLE 6B	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.00
2014123359	MAINTENANCE ODW PLUMBING CLOG	M'S R/R AT WAREHOUSE ALL SINKS ARE CLOGGED	M'S R/R AT WAREHOUSE	12/29/2014		REMOVED MIRROR AND SNAKED DRAINS	1.00
2014123360	MAINTENANCE ODW PLUMBING	M'S R/R A35 FAUCET RUNNING	M'S R/R A35	12/29/2014	C BATTERIES-COV;C BATTERIES ;; SOLENOID-COV;SOLENOID ;	REPLACED 4 "C" BATTERIES AND SOLENOID	1.00
2014123407	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET CLOGGED	W'S R/R B211	12/30/2014		UNCLOGGED WITH PLUNGER	0.50
2014123409	MAINTENANCE ODW INT. LIGHTING	HALL BETWEEN AREAS 3 AND 4 LIGHTS OUT	AREAS 3 AND 4	12/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014123411	MAINTENANCE ODW PLUMBING	CHILDCARE FACULTY LOUNGE TOILET NOT FLUSHING PROPERLY	CHILDCARE FACULTY LOUNGE	12/30/2014		OPENED WATER SUPPLY TO ALLOW MORE PRESSURE. FUNCTIONING NORMALLY.	0.50
2014123419	MAINTENANCE ODW PLUMBING	OUTSIDE DOOR 2 - WATER SPIGGOT IS DRIPING	DOOR 2	12/30/2014		WE WERE DRAINING THE LINE AND WE TURNED OFF WHEN JOB WAS COMPLETED.	0.50
2014123426	MAINTENANCE ODW PLUMBING	AREA 7 TOILET CONSTANTLY RUNNING IN W'S R/R	AREA 7	12/30/2014		NO TOILET WAS RUNNING UPON ENTERING R/R. FLUSHED ALL TOILETS. ALL RUNNING NORMALLY.	0.50
2014123427	MAINTENANCE ODW INT. LIGHTING	CHILDCARE STAFF LOUNGE LIGHT COVER NEEDS CLIPPED BACK INTO PLACE	CHILDCARE	12/30/2014		REPAIRED SPRING ON RIGHT SIDE LATCH AND THEN CLOSED LIGHT COVER.	0.50
2015012034	MAINTENANCE ODW INT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	1/5/2015		REPLACED SIX LIGHT BULBS AND VACUUMED TWO LIGHT FIXTURES	0.75
2015012039	MAINTENANCE ODW INT. LIGHTING	M'S R/R A700I LIGHTS OUT	M'S R/R A700I	1/5/2015	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2015012040	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 4 POLE 5L HAS A BROKEN LENS COVER	AREA 4 POLE 5L	1/5/2015		REPLACED COVER.	1.00
2015012041	MAINTENANCE ODW TEMPERATURE COLD	AREA 8K TOO COLD	AREA 8K	1/5/2015		TOOK READING OF AREA. 71.5, 71.5 AND 71.5. ADJUSTED TEMP 2 DEG.	0.50
2015012042	MAINTENANCE ODW CEILING TILE	AREA 5 HAS A WET TILE BETWEEN POLES 6P AND 7P	AREA 5	1/5/2015		PLACED PAN AND BUCKET UNDER LEAK	1.00
2015012043	MAINTENANCE ODW PLUMBING	W'S R/R A404 TOILETS WILL NOT FLUSH	W'S R/R A404	1/5/2015		FLUSHED ALL FOUR TOILETS. FUNCTIONING NORMALLY.	0.50
2015012044	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET CLOGGED	M'S R/R B309	1/5/2015		UNCLOGGED WITH PLUNGER	0.50

Totals

1361 1,393.65