

2014123215	MAINTENANCE ODW PLUMBING	CHILDCARE RM 128 WATER FOUNTAIN AT FIRST CHILD SINK IS LEAKING	CHILDCARE RM 128	12/19/2014		12-19-14: ORDERED CARTRIDGE. 12-29-14: REPLACED CARTRIDGE.	1.25
2014123218	MAINTENANCE ODW PLUMBING	CHILDCARE RM 130 FAUCETS ARE LEAKING ON BOTH CHILD SINKS LOCATED IN THE BACK OF THE ROOM NEAR THE COURTYARD	CHILDCARE RM 130	12/19/2014		GOOSENECK ON LH SINK LEAKING. REPLACED "O" RING ON GOOSENECK. WATER FOUNTAIN RH SINK LEAKING. REPLACED CARTRIDGE.	1.50
2014123219	MAINTENANCE ODW DOOR	CHILDCARE RM 130 DOOR JAM COVERS ARE NEEDED ON THE BATHROOM DOORS	CHILDCARE RM 130	12/19/2014		DOOR GUARDS WERE INSTALLED ON BOTH BATHROOM DOORS.	2.50
2014123222	MAINTENANCE ODW JINT. LIGHTING	MAG HALL 17 AND 18 LIGHTS OUT	MAG HALL 17 AND 18	12/19/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014123234	MAINTENANCE ODW TEMPERATURE COLD	AREA 7 TOO COLD	AREA 7	12/19/2014		INCREASED SPACE TEMP SETPOINTS ON UNITS 16 AND 17 FROM 71 DEG TO 72.5 DEG F.	0.50
2014123267	MAINTENANCE ODW BLDG/EQUIP. REP	AHU 11-9 SUPPLY FAN BELTS SLAPPING AND MAKING EXCESSIVE NOISE	RM 1002	12/22/2014	FAN BELT-COV;FAN BELT ;	REPLACED BELTS WITH NEW. WIPED OFF BOTH FAN PULLEY AND FAN SHAFT PULLEY.	1.00
2014123268	MAINTENANCE ODW JINT. LIGHTING	AREA 6 LIGHT FIXTURE NOT WORKING	AREA 6	12/22/2014	LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST	1.00
2014123269	MAINTENANCE ODW JINT. LIGHTING	W'S R/R A600 LIGHTS OUT	W'S R/R A600	12/22/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014123270	MAINTENANCE ODW LEAKS	SOUTH END OF MDF (CHRIS) THERE IS A DOMESTIC WATER LINE LEAK	MDF	12/22/2014		REPLACED LEAKING DIELECTRIC UNION AND GALVANIZED NIPPLE. CHECKED FOR LEAKS. OK. PUT INSULATION ON PIPE AND REPLACED TILE.	5.00
2014123313	MAINTENANCE ODW JINT. LIGHTING	MAG HALL LAMPS OUT	MAG HALL	12/23/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	1.00
2014123314	MAINTENANCE ODW JINT. LIGHTING	POLE 4C LIGHT LENS SAGGING	POLE 4C	12/23/2014		REINSTALLED LIGHT LENS	0.50
2014123326	MAINTENANCE ODW TEMPERATURE HOT	AREA 1 TOO WARM	AREA 1	12/23/2014		LOWERED SPACE TEMP. SETPOINT FROM 74.5 TO 72.5.	0.50
2014123334	MAINTENANCE ODW RESTROOM FIXTURE	W'S R/R A600: STALL #4 TOILET PAPER DISPENSER BROKEN. LAST STALL TOILET PAPER DISPENSER COMPLETELY OFF AND LAYING ON THE FLOOR.	W'S R/R A600	12/23/2014	TOILET PAPER DISPENSER-COV;TOILET PAPER DISPENSER ;	REPLACED DISPENSERS IN STALLS 4 AND 7	1.00
2014123337	MAINTENANCE ODW JINT. LIGHTING	RM B 200A OVERHEAD LIGHT OUT	RM B 200A	12/24/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMP	0.50
2014123351	MAINTENANCE ODW JINT. LIGHTING	AREA 4 SEVERAL FIXTURES HAVE LIGHTS OUT, BROKEN AND LOOSE COVERS	AREA 4	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED 40 LAMPS, 8 LENS COVERS, 2 WFI COVERS	12.00
2014123352	MAINTENANCE ODW JINT. LIGHTING	AREA 9 LIGHTS OUT	AREA 9	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED EIGHT LIGHT BULBS	0.50
2014123353	MAINTENANCE ODW JINT. LIGHTING	MSU LIGHTS OUT	MSU	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED FOUR LIGHT BULBS	0.50
2014123354	MAINTENANCE ODW DOOR	RM 307 DOOR NEEDS CUT FOR VENTILATION	RM 307	12/29/2014		CUT HOLE THROUGH DOOR. INSTALLED VENT COVERS NO BOTH SIDES. REINSTALLED DOOR.	1.00
2014123355	MAINTENANCE ODW JINT. LIGHTING	AREA 11 LIGHTS OUT	AREA 11	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED BULBS	0.50
2014123356	MAINTENANCE ODW JINT. LIGHTING	AREA 4 LIGHTS OUT	AREA 4	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REINSERTED LOOSE PANELS AND REPLACED LAMPS	2.00
2014123357	MAINTENANCE ODW JINT. LIGHTING	POLE 6B LIGHTS OUT	POLE 6B	12/29/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;; LIGHT BALLAST-COV;LIGHT BALLAST ;	REPLACED BALLAST AND LAMPS	1.00
2014123359	MAINTENANCE ODW PLUMBING CLOG	M'S R/R AT WAREHOUSE ALL SINKS ARE CLOGGED	M'S R/R AT WAREHOUSE	12/29/2014		REMOVED MIRROR AND SNAKED DRAINS	1.00
2014123360	MAINTENANCE ODW PLUMBING	M'S R/R A35 FAUCET RUNNING	M'S R/R A35	12/29/2014	C BATTERIES-COV;C BATTERIES ;; SOLENOID-COV;SOLENOID ;	REPLACED 4 "C" BATTERIES AND SOLENOID	1.00
2014123407	MAINTENANCE ODW PLUMBING CLOG	W'S R/R B211 TOILET CLOGGED	W'S R/R B211	12/30/2014		UNCLOGGED WITH PLUNGER	0.50
2014123409	MAINTENANCE ODW JINT. LIGHTING	HALL BETWEEN AREAS 3 AND 4 LIGHTS OUT	AREAS 3 AND 4	12/30/2014	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED LAMPS	0.50
2014123411	MAINTENANCE ODW PLUMBING	CHILDCARE FACULTY LOUNGE TOILET NOT FLUSHING PROPERLY	CHILDCARE FACULTY LOUNGE	12/30/2014		OPENED WATER SUPPLY TO ALLOW MORE PRESSURE. FUNCTIONING NORMALLY.	0.50
2014123419	MAINTENANCE ODW PLUMBING	OUTSIDE DOOR 2 - WATER SPIGGOT IS DRIPING	DOOR 2	12/30/2014		WE WERE DRAINING THE LINE AND WE TURNED OFF WHEN JOB WAS COMPLETED.	0.50
2014123426	MAINTENANCE ODW PLUMBING	AREA 7 TOILET CONSTANTLY RUNNING IN W'S R/R	AREA 7	12/30/2014		NO TOILET WAS RUNNING UPON ENTERING R/R. FLUSHED ALL TOILETS. ALL RUNNING NORMALLY.	0.50
2014123427	MAINTENANCE ODW JINT. LIGHTING	CHILDCARE STAFF LOUNGE LIGHT COVER NEEDS CLIPPED BACK INTO PLACE	CHILDCARE	12/30/2014		REPAIRED SPRING ON RIGHT SIDE LATCH AND THEN CLOSED LIGHT COVER.	0.50
2015012034	MAINTENANCE ODW JINT. LIGHTING	AREA 7 LIGHTS OUT	AREA 7	1/5/2015		REPLACED SIX LIGHT BULBS AND VACUUMED TWO LIGHT FIXTURES	0.75
2015012039	MAINTENANCE ODW JINT. LIGHTING	M'S R/R A700I LIGHTS OUT	M'S R/R A700I	1/5/2015	FLOURESCENT LGT-COV;FLOURESCENT LGT ;	REPLACED TWO LIGHT BULBS	0.50
2015012040	MAINTENANCE ODW BLDG/EQUIP. REP	AREA 4 POLE 5L HAS A BROKEN LENS COVER	AREA 4 POLE 5L	1/5/2015		REPLACED COVER.	1.00
2015012041	MAINTENANCE ODW TEMPERATURE COLD	AREA 8K TOO COLD	AREA 8K	1/5/2015		TOOK READING OF AREA. 71.5, 71.5 AND 71.5. ADJUSTED TEMP 2 DEG.	0.50
2015012042	MAINTENANCE ODW CEILING TILE	AREA 5 HAS A WET TILE BETWEEN POLES 6P AND 7P	AREA 5	1/5/2015		PLACED PAN AND BUCKET UNDER LEAK	1.00
2015012043	MAINTENANCE ODW PLUMBING	W'S R/R A404 TOILETS WILL NOT FLUSH	W'S R/R A404	1/5/2015		FLUSHED ALL FOUR TOILETS. FUNCTIONING NORMALLY.	0.50
2015012044	MAINTENANCE ODW PLUMBING CLOG	M'S R/R B309 TOILET CLOGGED	M'S R/R B309	1/5/2015		UNCLOGGED WITH PLUNGER	0.50

Totals

1361 1,393.65