

2015072740	MAINTENANCE ODW TEMPERATURE HOT	10N EXTRACTING TOO HOT	10N	7/8/2015	LOWERED SPACE TEMP TO SET POINT FROM 71 DEG TO 70 DEG F. SPACE TEMP IS 72 DEG.	0.50
2015072754	MAINTENANCE ODW BLDG/EQUIP. REP	W'S R/R B211 FIRST THREE SINKS ARE EMITTING AN ODOR	W'S R/R B211	7/8/2015	CHECKED SINKS, COULD NOT SMELL ANY ODOR.	0.50
2015072755	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 810 #2 TOILET CLOGGED	M'S R/R 810	7/8/2015	UNCLOGGED WITH PLUNGER	0.50
2015072756	MAINTENANCE ODW INT. LIGHTING	MSU OVERHEAD LIGHTS OUT	MSU	7/8/2015	REPLACED 12 LIGHT BULBS	0.50
2015072757	MAINTENANCE ODW PLUMBING CLOG	W'S R/R A309 #3 TOILET CLOGGED	W'S R/R A309	7/8/2015	UNCLOGGED TOILET. OK.	0.50
2015072765	MAINTENANCE ODW ELECTRICAL	AREA 1 STILL HAVING AN ISSUE WITH ELECTRICAL OUTLET	AREA 1	7/8/2015	MR: SPOKE TO TWO EMPLOYEES IN THE AREA. THEY STATED THAT THERE WAS NOTHING WRONG WITH THE ELECTRICAL OUTLET. IT HAS BEEN FINE SINCE IT WAS REPAIRED OVER TWO WEEKS AGO.	0.50
2015072781	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 #3 TOILET CLOGGED	M'S R/R 1005	7/8/2015	TOILET HAD BEEN STUFFED WITH PAPER TOWELS AND TOILET PAPER. CLEARED CLOG WITH PLUNGER.	0.50
2015072802	MAINTENANCE ODW DOOR	AREA 1 DOOR BEHIND DESK MONITOR - THE STRIKE PLATE IS READY TO FALL OFF	AREA 1	7/9/2015	REPLACED MISSING SCREW IN STRIKE PAD	0.50
2015072803	MAINTENANCE ODW INT. LIGHTING	SATELLITE CANTEEN LIGHT FIXTURE NOT WORKING AND A FEW LAMPS OUT	SATELLITE CANTEEN	7/9/2015	REPLACED 4 U-SHAPED LAMPS, 2 LAMPS, 1 BALLAST	1.50
2015072804	MAINTENANCE ODW INT. LIGHTING	IDF CLOSET BY NEW COMPUTER ROOM OVERHEAD LIGHTS OUT	IDF IN AREA 14	7/9/2015	THE ISSUE WAS THAT THE LIGHT SWITCH WAS NOT FLIPPED ON. TURNED ON LIGHT SWITCH.	0.50
2015072851	MAINTENANCE ODW BLDG/EQUIP. REP	RM 903 COVE BASE COMING OFF WALL, 5' PAST THRESHOLD AT TOP OF RAMP	RM 903	7/10/2015	REGLUED ANOTHER FOUR FOOT SECTION OF BLACK COVE BASE TO WALL	0.50
2015072852	MAINTENANCE ODW TEMPERATURE COLD	POLE 8K TOO COLD	POLE 8K	7/10/2015	TOOK THREE TEMPS OF AREA - 76, 76 AND 76.1. MADE NO ADJUSTMENT.	0.50
2015072853	MAINTENANCE ODW GATE/FENCE	GATEHOUSE 2 GATE WILL NOT RESPOND TO COMMAND FROM COMMAND CENTER	GATEHOUSE 2	7/10/2015	OPENED GATE AT GATEHOUSE MANUALLY	0.50
2015072854	MAINTENANCE ODW GATE/FENCE	FENCE NEAR GATEHOUSE 5, NORTH END GOING INTO SOUTH BREEZEWAY HAS A BROKEN SCREW IN TOP FENCE SUPPORT	GATEHOUSE 5	7/10/2015	DRILLED OUT BROKEN SCREW AND REPLACED. TIGHTENED THE OTHER THREE SCREWS.	0.50
2015072855	MAINTENANCE ODW TEMPERATURE HOT	COURTYARD CANTEEN - CHECK THE TEMP AROUND 11:00 AM TODAY AND DOCUMENT THE TEMP	COURTYARD CANTEEN	7/10/2015	FLUKE METER READING 72.4 DEG F, 77% RH. METASYS READING 72.1 DEG F, 76.5 RH. SPACE SETPOINT IS 73 DEG F. CANTEEN KITCHEN TEMP VIA FLUKE 74.4 DEG F.	0.50
2015072862	MAINTENANCE ODW PLUMBING CLOG	M'S R/R 1005 HANDICAP TOILET CLOGGED	M'S R/R 1005	7/10/2015	PLUNGED TOILET, OK. TIGHTENED SEAT BOLTS.	0.50
2015072869	MAINTENANCE ODW PLUMBING CLOG	W'S R/R 306 TOILET #8 CLOGGED; TOILET #1 SEAT BROKEN	W'S R/R 306	7/10/2015	PLUNGED THE TOILET, FLUSHED, OK. TOILET SEAT NOT BROKEN, JUST LOOSE. CHECKED ALL TOILET SEATS AND TIGHTENED THOSE WHICH NEEDED TO BE TIGHTENED.	0.75
2015072876	MAINTENANCE ODW INT. LIGHTING	AISLEWAY AT POLE 4F - LIGHT LENS LOOSE	POLE 4F	7/10/2015	REATTACHED LOOSE LENS LATCH TO LIGHT FIXTURE	0.50

1363

1,342.50