

**TECHNICAL EXHIBIT TE -10  
Infrared Testing Requirements**

<b>IRS PM CHECK</b>	<b>DESCRIPTION</b>	<b>FREQUENCY</b>
E-28	Motor Starters 100 Hp and Greater	3 Years
E-30	Switchboards, Medium Voltage, (per cubicle)	3 Years
E-30A	Switchboards Low Voltage, (per cubicle),	3 Years
E-36	Automatic Transfer Switch	Annual
E-33A	High Voltage Network and, Power Type Transformer Dry Type Transformer - - Power Type	Annual
E-33B	High Voltage Network and, Power Type Transformer Dry Type Transformer - - Network Type	Annual
E-34	Disconnects or Isolating Switch, Per Switch, (Above 600 Volts)	Annual
E-34A	Disconnects or Isolating switch (Low voltage, Less than 600 volts, 200 amps or more)	Annual
E-35	Motor Control Center (MCC)	Annual
E-37	Bus Duct, Low Voltage, & Connectors	3 Years
E-37A	Bus Duct, Metal Enclosed, & Connectors	3 Years
E-38	High Voltage Air Circuit Breaker	Annual
E-51	Motor Starters, Less than 100 Hp	Annual
E-57	Dry Type transformer	3 Years
E-58	Power Distribution Unit	Annual
E-59-66	Uninterruptible Power Systems	Annual