

TECHNICAL EXHIBIT TE-12  
Certification Testing Requirements

TIRSE-15-R-00002

IRS PM CHECK	DESCRIPTION	FREQUENCY
A-4	Unfired Pressure Vessels	Annual
B--7	Boiler Internal Inspection	Annual
B-8	Boiler External Inspection	Annual
E-20	Induction Disc Over Current Relay	Annual
E-21	/or Under Voltage Relay	Annual
E-25	Ground Fault Type Transformer or Differential Relay	Annual
E-26	Low Voltage Molded Case Circuit Breaker > 400 AMPS	1/3 Years
E-28	Motor Starters, 100 Hp and Greater	1/3 Years
E-32	High Voltage Network and Power Type Transformer (Oil Filled)	Annual
E-33	High Voltage Network and Power Dry Type Transformers	Annual
E-52	Auxiliary Protective Relays	Annual
F-22	Fire Extinguishers, Stored Pressure with Gauge	Annual
F-25	Fire Extinguishers, Stored Pressure with Gauge	1/5 Years
V-9	Backflow Preventer	Annual